DET-04-028-1 Revision 0 April 1982

ENRICO FERMI ATOMIC POWER PLANT UNIT 2 PLANT UNIQUE ANALYSIS REPORT VOLUME 1 GENERAL CRITERIA AND LOADS METHODOLOGY

> Prepared for: Detroit Edison Company

> Prepared by: NUTECH Engineers, Inc.

Prepared by:

L. D. Steinert Project Manager

Approved by:

Dr. A. B. Agginbotham, P.E. General Manager Engineering Department

Dr. N. W. Edwards, P.E. Senior Vice-President

Reviewed by:

ulford

T. J. Mulford C Engineering Manager

Issued by:

R. H. Kohrs, P.E. Project Director

4 Buchhoz

R. H. Buchholz Project General Manager



820504 0278

DET-04-028-1 Revision 0

#### REVISION CONTROL SHEET

REPORT NUMBER: DET-04-028-1 SUBJECT: Enrico Fermi Atomic Power Plant, Unit 2 Plant Unique Analysis Report Volume 1

Baskin, P.E./Engineering Manager . Lusta Curtis/Technical Editor

Kohis

H. Kohrs, P.E./Project Director

Vijay Ruman V. Kumar, P.E./Project Engineer

P.E./Engineering Manager Lehnert,

ulford Engineering Manager T. J. Mofford

Sanchez, F./Principal Engineer R. A.

Associate Engineer

L. D. Steinert/Project Manager

T. J. Wenner, P.E./Engineering Director

C. T. Wong, P. /Project Engineer

Indials

Initials

RHK

Initials

VK Initials

Initials

Initia

Initials

Con Initials



### REVISION CONTROL SHEET (Continuation)

TITLE: ENRICO FERMI ATOMIC POWER REPORT NUMBER: DET-04-028-1 PLANT, UNIT 2 PLANT UNIQUE ANALYSIS REPORT VOLUME 1

Revision 0

nutech

EFFEC- TIVE PAGE(S)	REV	PRE- PARED	ACCURACY CHECK	CRITERIA CHECK	EFFEC- TIVE PAGE(S)	REV	PRE- PARED	ACCURACY CHECK	CRITERIA CHECK
l-iii through l-xv	0	LOS	Ase	AJC	1-3.10 through 1-3.17	0	205	RA	NAW
1-1.1 through 1-1.7			PHK	PAK	1-4.1 through 1-4.41			Ras	Tym
1-1.8			RAL	ages all	1-4.42 through 1-4.70			VK	ngw
1-1.10			WEST	agu	1-4.71			Ras	-gm
1-1.11			WEST	NW	1-4.72			Kas	-du
1-1.12 through 1-1.16			Ras	7gm	1-4.73 through 1-4.88			VK	ngw
1-1.17 through 1-1.24			nge	PAK	1-4.89 through 1-4.128			Rees	79M
1-2.1 through 1-2.26			WESE	apr	1-5.1 through 1-5.10			Ras	Tgm
1-2.27			CTW	83	1-6.1		1	ASC	Asc
1-2.28			CTW	B	1-6.2	0	TROS	ASC	ASC
1-2.29 through 1-2.31			Ras	Tgm					
1-3.1 through 1-3.9	0	LOS	Ras	Tgm_					
all and									

1-iii

### ABSTRACT

The primary containment for the Enrico Fermi Atomic Power Plant, Unit 2, was designed, erected, pressure-tested, and ASME Code N-stamped during the early 1970's for the Detroit Edison Company by the Chicago Bridge and Iron Company. Since that time new requirements, defined in the Nuclear Regulatory Commission's Safety Evaluation Report NUREG-0661, which affect the design and operation of the primary containment system have evolved. The requirements to be addressed include an assessment of additional containment design loads postulated to occur during loss-of-coolant accident or a safety relief valve discharge event, as well as an assessment of the effects that these postulated events have on the operational characteristics of the containment system.

This plant unique analysis report documents the efforts undertaken to address and resolve each of the applicable NUREG-0661 requirements, and demonstrates, in accordance with NUREG-0661 acceptance criteria, that the design of the primary containment system is adequate and that original design safety margins have been restored. The report is composed of five volumes which are:

0	Volume	1	-	GENERAL CRITERIA AND LOADS METHODOLOGY
0	Volume	2	-	SUPPRESSION CHAMBER ANALYSIS
0	Volume	3	-	VENT SYSTEM ANALYSIS
0	Volume	4	-	INTERNAL STRUCTURES ANALYSIS
0	Volume	5	-	SAFETY RELIEF VALVE PIPING ANALYSIS

This particular volume, Volume 1, provides introductory and background information regarding the re-evaluation of the suppression chamber design. This includes a description of the Fermi 2 pressure suppression containment system, a description of

DET-04-028-1 Revision 0



the structural and mechanical acceptance criteria, and the hydrodynamic loads development methodology used in the analysis. This document has been prepared by NUTECH Engineers, Incorporated (NUTECH), acting as an agent responsible to the Detroit Edison Company.

The volume number precedes each number assigned to pages, sections, subsections, tables, and figures within a given volume.





# TABLE OF CONTENTS

			Page
ABSTRAC	r		l-iv
LIST OF	ACRONY	MS	1-ix
LIST OF	TABLES		1-xi
LIST OF	FIGURE	s	l-xiii
1-1.0	INTROD	DUCTION	1-1.1
	1-1.1	Scope of Analysis	1-1.8
	1-1.2	General Description of the Containment System	1-1.10
	1-1.3	Review of Phenomena	1-1.12
		1-1.3.1 LOCA-Related Phenomena 1-1.3.2 SRV Discharge Phenomena	1-1.13 1-1.15
	1-1.4	Evaluation Philosophy	1-1.17
1-2.0	PLANT	UNIQUE CHARACTERISTICS	1-2.1
	1-2.1	Plant Configuration	1-2.2
		<pre>1-2.1.1 Suppression Chamber 1-2.1.2 Vent System 1-2.1.3 Internal Structures 1-2.1.4 SRV Discharge Piping</pre>	1-2.6 1-2.14 1-2.23 1-2.27
	1-2.2	Operating Parameters	1-2.29
1-3.0	PLANT	UNIQUE ANALYSIS CRITERIA	1-3.1
	1-3.1	Hydrodynamic Loads: NRC Acceptance Criteria	1-3.2
		1-3.1.1 LOCA-Related Load Applications 1-3.1.2 SRV Discharge Load Applications	1-3.4 1-3.7 1-3.9



### TABLE OF CONTENTS

# (Continued)

	1-3.2	Componen Acceptan	t Analysis: ce Criteria	Structural	1-3.10
		1-3.2.1	Classifica Service Le	tion of Components	1-3.11
		1-3.2.3	Other Cons	iderations	1-3.17
L-4.0	HYDROD EVENT	YNAMIC LO SEQUENCE	ADS DEVELOP SUMMARY	MENT METHODOLOGY AND	1-4.1
	1-4.1	LOCA-Rel	ated Loads		1-4.3
		1-4.1.1	Containmen Temperatur	t Pressure and e Response	1-4.5
		1-4.1.2	Vent Syste	m Discharge Loads	1-4.6
		1-4.1.3	Pool Swell Shell	Loads on the Torus	1-4.8
		1-4.1.4	Pool Swell Structures	Loads on Elevated	1-4.10
			1-4.1.4.1	Impact and Drag Loads on the Vent System	1-4.11
			1-4.1.4.2	Impact and Drag Loads on Other Structures	1-4.15
			1-4.1.4.3	Pool Swell Froth Impingement Loads	1-4.19
			1-4.1.4.4	Pool Fallback Loads	1-4.25
		1-4.1.5	LOCA Water Structures	jet Loads on Submerged	1-4.28
		1-4.1.6	LOCA Bubbl Submerged	e-Induced Loads cn Structures	1-4.36
		1-4.1.7	Condensati	on Oscillation Loads	1-4.41
			1-4.1.7.1	CO Loads on the Torus Shell	1-4.42
			1-4.1.7.2	CO Loads on the Downcomers and Vent System	1-4.53
			1-4.1.7.3	CO Loads on Submerged Structures	1-4.67
		1-4.1.8	Chugging L	oads	1-4.71
			1-4.1.8.1	Chugging Loads on the Torus Shell	1-4.73
			1-4.1.8.2	Chugging Downcomer Lateral Loads	1-4.81
			1-4.1.8.3	Chugging Loads on Submerged Structures	1-4.85



### TABLE OF CONTENTS

# (Concluded)

Page

	1-4.2	Safety Relief Valve Discharge Loads	1-4.89
		1-4.2.1 SRV Actuation Cases 1-4.2.2 SRV Discharge Line Clearing	1-4.94 1-4.100
		1-4.2.3 SRV Loads on the Torus Shell	1-4.105
		1-4.2.4 SRV Loads on Submerged Structures	1-4.111
	1-4.3	Event Sequence	1-4.116
		1-4.3.1 Design Basis Accident	1-4.119
		1-4.3.2 Intermediate Break Accident	1-4.125
		1-4.3.3 Small Break Accident	1-4.127
1-5.0	SUPPRE	SSION POOL TEMPERATURE MONITORING SYSTEM	1-5.1
	1-5.1	Suppression Pool Temperature Response to SRV Transients	1-5.2
	1-5.2	Suppression Pool Temperature Monitoring System Design	1-5.9
1-6.0	LIST O	F REFERENCES	1-6.1



# LIST OF ACRONYMS

-

重

nutech

ADS	Automatic Depressurization System
ASME	American Society of Mechanical Engineers
BWR	Boiling Water Reactor
CDF	Cumulative Distribution Function
со	Condensation Oscillation
DBA	Design Basis Accident
DC/VH	Downcomer/Vent Header
FSAR	Final Safety Analysis Report
FSI	Fluid-Structure Interaction
FSTF	Full-Scale Test Facility
HPCI	High Pressure Coolant Injection
IBA	Intermediate Break Accident
I&C	Instrumentation & Control
LDR	Load Definition Report (Mark I Containment Program
LOCA	Loss-of-Coolant Accident
LTP	Long-Term Program
MCF	Modal Correction Factors
NEP	Non-Exceedance Probability
NOC	Normal Operating Conditions
NRC	Nuclear Regulatory Commission
NSSS	Nuclear Steam Supply System
PUAAG	Plant Unique Analysis Application Guide
PUA	Plant Unique Analysis
PUAR	Plant Unique Analysis Report

PULD Plant Unique Load Definition

DET-04-028-1 Revision 0

l-ix

# LIST OF ACRONYMS (Concluded)

Quarter-Scale Test Facility OSTF RUIC Reactor Core Isolation Cooling Residual Heat Removal System RHRS RPV Reactor Pressure Vessel Resultant-Static-Equivalent Load RSEL Small Break Accident SBA Stuck Open Safety Relief Valve SCRV Suppression Pool Temperature Monitoring System SPTMS SRSS Square Root of the Sum of the Squares Safety Relief Valve SRV Safety Relief Valve Discharge Line SRVDL STP Short-Term Program

# LIST OF TABLES

Number	<u>Litle</u>	Page
1-1.0-1	Fermi 2 Containment Modification Status	1-1.7
1-2.2-1	Suppression Chamber Operating Parameters	1-2.30
1-3.2-1	Event Combinations and Service Levels for Class MC Components and Internal Structures	1-3.13
1-3.2-2	Event Combinations and Service Levels for Class 2 and 3 Piping	1-3.15
1-4.0-1	Plant Unique Analysis/NUREG-0661 Load Sections Cross-Reference	1-4.2
1-4.1-1	Hydrodynamic Mass and Acceleration Drag Volumes for Two-Dimensional Structural Components (Length L For All Structures)	1-4.33
1-4.1-2	Plant Unique Parameters for LOCA Bubble Drag Load Development	1-4.39
1-4.1-3	DBA Condensation Oscillation Torus Shell Pressure Amplitudes	1-4.46
1-4.1-4	FSTF Response to Condensation Oscillation	1-4.48
1-4.1-5	Condensation Oscillation Onset and Duration	1-4.49
1-4.1-6	Downcomer Internal Pressure Loads for DBA Condensation Oscillation	1-4.57
1-4.1-7	Downcomer Differential Pressure Loads for DBA Condensation Oscillation	1-4.58
1-4.1-8	Downcomer Internal Pressure Loads For IBA Condensation Oscillation	1-4.59
1-4.1-9	Downcomer Differential Pressure Loads For IBA Condensation Oscillation	1-4.60
1-4.1-10	Condensation Oscillation Loads on the Vent System	1-4.61
1-4.1-11	Amplitudes at Various Frequencies for Condensation Oscillation Source Function for Loads on Submerged Structures	1-4.70
1-4.1-12	Chugging Onset and Duration	1-4.76

DET-04-028-1 Revision 0

## LIST OF TABLES (Concluded)

Number	Title	Page
1-4.1-13	Post-Chug Rigid Wall Pressure Amplitudes on Torus Shell Bottom Dead Center	1-4.77
1-4.1-14	Probability of Exceedance for Multiple Downcomers Chugging	1-4.84
1-4.1-15	Amplitudes at Various Frequencies for Chugging Source Function for Loads on Submerged Structures	1-4.87
1-4.2-1	SRV Load Case/Initial Conditions	1-4.99
1-4.2-2	Plant Unique Initial Conditions for Actuation Cases Used for SRVDL Clearing Transient Load Development	1-4.103
1-4.2-3	SRVDL Analysis Parameters	1-4.104
1-4.2-4	Comparison of Analysis and Monticello Test Results	1-4.108
1-4.3-1	SRV and LOCA Structural Loads	1-4.118
1-4.3-2	Event Timing Nomenclature	1-4.120
1-4.3-3	SRV Discharge Load Cases for Mark I Structural Analysis	1-4.121
1-5.1-1	Summary of Fermi 2 Pool Temperature Response to SRV Transients	1-5.5





LIST OF FIGURES

Number	Title	Page
1-2.1-1	Elevation View of Containment	1-2.4
1-2.1-2	Plan View of Suppression Chamber	1-2.5
1-2.1-3	Suppression Chamber Section - Midbay Vent Line Bay	1-2.10
1-2.1-4	Suppression Chamber Section - Mitered Joint	1-2.11
1-2.1-5	Quencher and Quencher Supports - Plan View and Elevation	1-2.12
1-2.1-6	Quencher and Support Locations	1-2.13
1-2.1-7	Vent Header Plan View	1-2.16
1-2.1-8	Vent Line to Vent Header Intersection	1-2.17
1-2.1-9	Developed View of Vent Header and Downcomer Bracing System	1-2.18
1-2.1-10	Downcomer to Vent Header Intersection	1-2.19
1-2.1-11	Vacuum Breaker Penetration - Plan View	1-2.20
1-2.1-12	Vacuum Breaker Penetration - Detail	1-2.21
1-2.1-13	SRV Penetration in Vent Line	1-2.22
1-2.1-14	Catwalk Frame	1-2.24
1-2.1-15	Catwalk Supports	1-2.25
1-2.1-16	Monorail Supports	1-2.26
1-2.1-17	SRV Pipe Routing in Wetwell - Plan View	1-2.28
1-4.1-1	Downcomer Impact and Drag Pressure Transient	1-4.13
1-4.1-2	Application of Impact and Drag Pressure Transient to Downcomer	1-4.14
1-4.1-3	Pulse Shape for Water Impact on Cylindrical Targets	1-4.17
1-4.1-4	Pulse Shape for Water Impact on Flat Targets	1-4.18

1-xiii



## LIST OF FIGURES (Continued)

Number	Title	Page
1-4.1-5	Froth Impingement Zone - Region I	1-4.23
1-4.1-6	Froth Impingement Zone - Region II	1-4.24
1-4.1-7	Quarter-Scale Downcomer Water Slug Ejection, Test 7	1-4.35
1-4.1-8	Quarter-Scale Drywell Pressure Time-History	1-4.40
1-4.1-9	Condensation Oscillation Baseline Rigid Wall Pressure Amplitudes on Torus Shell Bottom Dead Center	1-4.50
1-4.1-10	Mark I Condensation Oscillation - Torus Vertical Cross-Sectional Distribution for Pressure Oscillation Amplitude	1-4.51
1-4.1-11	Mark I Condensation Oscillation - Multipli- cation Factor to Account for the Effect of the Pool-to-Vent Area Ratio	1-4.52
1-4.1-12	Downcomer Dynamic Load	1-4.62
1-4.1-13	Downcomer Pair Internal Pressure Loading for DBA CO	1-4.63
1-4.1-14	Downcomer Pair Differential Pressure Loading for DBA CO	1-4.64
1-4.1-15	Downcomer CO Dynamic Load Application	1-4.65
1-4.1-16	Downcomer Internal Pressure Loading for IBA CO	1-4.66
1-4.1-17	Typical Chug Average Pressure Trace on the Torus Shell	1-4.72
1-4.1-18	Mark I Chugging - Torus Asymmetric Longitudinal Distribution for Pressure Amplitude	1-4.78
1-4.1-19	Mark I Chugging - Torus Vertical Cross- Sectional Distribution for Pressure Amplitude	1-4.79
1-4.1-20	Post-Chug Rigid Wall Pressure Amplitudes on Torus Shell Bottom Dead Center	1-4.80

# LIST OF FIGURES (Concluded)

Number	Title	Page
1-4.2-1	T-quencher and SRV Line	1-4.91
1-4.2-2	T-quencher Arm Hole Pattern - Elevation View	1-4.92
1-4.2-3	T-quencher Hole Pattern - Section Views	1-4.93
1-4.2-4	Comparison of Predicted and Measured Shell Pressure Time-Histories for Monticello Test 801	1-4.109
1-4.2-5	Modal Correction Factors for Analysis of SRV Discharge Torus Shell Loads	1-4.110
1-4.2-6	Plan View of Fermi 2 T-quencher Arm Jet Sections	1-4.115
1-4.3-1	Loading Condition Combinations for the Vent Header, Main Vents, Downcomers, and Torus Shell During a DBA	1-4.122
1-4.3-2	Loading Condition Combinations for Submerged Structures During a DBA	1-4.123
1-4.3-3	Loading Condition Combinations for Small Structures Above Suppression Pool During a DBA	1-4.124
1-4.3-4	Loading Condition Combinations for the Vent Header, Main Vents, Downcomers, Torus Shell and Submerged Structures During an IBA	1-4.126
1-4.3-5	Loading Condition Combinations for the Vent Header, Main Vents, Downcomers, Torus Shell and Submerged Structures During a SBA	1-4.128
1-5.1-1	Local Pool Temperature Limit for Enrico Fermi Unit 2	1-5.8

The primary containment for the Enrico Fermi Atomic Power Plant, Unit 2 was designed, erected, leak-tested and N-stamped in accordance with the ASME Boiler and Pressure Vessel Code during the early 1970's. Subsequently, while in the course of performing large-scale testing for the Mark III containment system and in-plant testing for Mark I containment systems, new suppression chamber hydrodynamic loads were identified. The new loads are related to the postulated loss-of-coolant accident (LOCA) and safety relief valve (SRV) operation.

The identification of these new loads presented a generic open item for utilities with Mark I containments. To determine the magnitude, time characteristics, etc., of the dynamic loads in a timely manner and to identify courses of action needed to resolve any outstanding concerns, the utilities with Mark I containments formed the Mark I Owners Group. The Mark I Owners Group established a program which consisted of two parts: 1) a short-term program which was completed in 1976,

DET-04-028-1 Revision 0



and 2) a long-term program which was completed with the submittal of the Mark I Containment Program Load Definition Report (LDR) (Reference 1), the Mark I Containment Program Structural Acceptance Criteria Plant Unique Analysis Application Guide (PUAAG) (Reference 2) and supporting reports on experimental and analytical tasks of the Long-Term Program (LTP). The NRC reviewed these LTP generic documents and issued acceptance criteria to be used during the implementation of the Mark I plant unique analyses. The NRC acceptance criteria are described in Appendix A of NUREG-0661 (Reference 3).

The objective of the LTP was to establish final design loads and load combinations and to verify that existing or modified containment and related structures are capable of withstanding these loads with acceptable design margins. However, the original LTP completion schedule was not compatible with the construction schedule for the Fermi 2 plant. To comply with the objectives of the LTP and to meet the plant construction schedule, Detroit Edison Company committed to a containment modification program that provided design, analysis, and implementation of

DET-04-028-1 Revision 0

nutech

modifications before the final loads and load combinations were determined by the Mark I Owners Group.

In Amendment 12 to the Final Safety Analysis Report (FSAR), Article 3.8.2, Detroit Edison Company submitted an interim LTP plant unique analysis (PUA). Reference 17 to Article 3.8 of the FSAR described the program which was implemented by Detroit Edison Company to provide an early assessment of the Fermi 2 containment design for the original design loads and the newly defined suppression pool hydrodynamic loads. The loads employed in the interim PUA were established using available generic documents, with the objective of developing realistic design loads which would allow early plant modifications with a high probability of bounding the final loads.

Results of the interim PUA indicated that extensive modifications would be required to the suppression chamber, vent system, and suppression chamber internal piping and structures to re-establish the original design margins. The nature and extent of the modifications were discussed in the interim PUA report (Reference 4). Detroit Edison Company

DET-04-028-1 Revision 0 1-1.3

proceeded at risk to install extensive modifications in anticipation that they would be required to meet the LTP acceptance criteria.

Most of the modifications required by the interim PUA have been installed. The installation of selected modifications was delayed until some of the specific Owners Group concerns about the NRC acceptance criteria were resolved. These selected designs were re-evaluated in light of the resulting NRC criteria, and in some cases, the proposed modifications were The Fermi 2 containment modification redesigned. status is provided in Table 1-1.0-1. The configuration and geometry of the torus is discussed in Section 1-2.1.1. The installation of the remaining modifications required by the interim PUA and associated engineering evaluations will be completed before fuel load.

This plant unique analysis report (PUAR) describes the final LTP PUA for the Fermi 2 containment. The report documents the evaluation of the modified Fermi 2 suppression chamber and internals which was performed in accordance with the requirements of NUREG-0661. The alternate criteria allowed by

DET-04-028-1 Revision 0



NUREG-0661, Appendix A, Article 2.13.9 was used in the evaluation of safety relief valve discharge loads. As such, a series of in-plant tests will be performed after fuel load to confirm that the computed loadings and predicted structural responses for SRV discharges are conservative.

The predicted response of the suppression chamber shell provided by this PUAR for each of the loads and load combinations is an essential input for evaluating the piping attached to the torus. Detroit Edison Company is currently evaluating the response of the torus-attached piping to pool hydrodynamic loads. The schedule for installation of any required modifications to torus-attached piping extends beyond the Fermi 2 fuel load date. However, Detroit Edison Company is conducting a scoping analysis of selected torus-attached piping systems in order to justify interim plant operation. The scoping analysis will establish that acceptable safety margins exist in the torus-attached piping. All modifications to the torus-attached piping required as a result of the LTP PUA acceptance criteria are scheduled to be installed prior to returning to power after the first refueling cycle.

DET-04-028-1 Revision 0



Accordingly, with the submittal of this PUAR, Detroit Edison Company believes that the Fermi 2 containment modification program has addressed the requirements of NUREG-0661 and the Fermi 2 Safety Evaluation Report (NUREG-0798 and NUREG-0798, Supplement No. 1).

DET-04-028-1 Revision 0

### TABLE 1-1.0-1

	DESC	RIPTION	APPROXIMATE MODIFICATION DATES	REMARKS
	RING BEAM	1 REINFORCEMENT	6/79	
	COLUMN RE	INFORCEMENT	10/78	
TORUS	COLUMN CO	ONNECTION REINFORCEMENT	12/79	
	MITERED J	JOINT SADDLES	6/82	
	ADDITIONA	AL COLUMN ANCHOR BOLTS	6/82	
	DOWNCOME	R SHORTENING	2/80	
	VENT HEAL AND BRACI	DER/DOWNCOMER STIFFENING ING	11/78	
	REINFORCE COLUMNS A	ED EXISTING VENT SYSTEM	2/79	ORIGINAL COLUMNS REPLACED
VENT	VENT HEAD LINE BAYS	DER DEFLECTOR (NON-VENT 5)	2/80	
5151EM	VENT HEAD LINE BAYS	DER DEFLECTOR (VENT	9/82	
	VENT LINE	E/VENT HEADER STIFFENING	6/79	
	REINFORCE HEADER CO	D VACUUM BREAKER TO VENT	7/79	
		ADDITIONAL SUPPORTS	5/78	
	MONO- RAIL	STRENGTHEN EXISTING SUPPORTS	5/78	REMOVED EXISTING COLUMN SUPPORTS
INTERNAL STRUCTURES		EXTENDED MONORAIL	5/78	REPLACED WITH HANGER SUPPORTS
	CAMUATY	ADDITIONAL SUPPORTS	8/78	
	CAIWALK	GRATING (DELIVER TO SITE)	3/80	REMOVED CHECKERED
		GRATING INSTALLATION	1/82	WITH GRATING
	REROUTED	PIPING IN WETWELL	4/80	
	ADDITION	AL WETWELL SUPPORTS	4/79	
COU DIDING	REINFORCE	ON VENT LINE	11/78	
SRV PIPING	ADDED QUENCHER/RAMSHEAD SUPPORTS		1/80	

### FERMI 2 CONTAINMENT MODIFICATION STATUS



QUENCHERS

ADDITIONAL QUENCHER SUPPORTS

nutech

9/82

9/82

### 1-1.1 Scope of Analysis

The structural and mechanical elements addressed in the various volumes of this report include the following.

o Containment Vessel

----

-

- The torus shell with associated penetrations, reinforcing rings and support attachments
  - The torus supports
    - The vent lines between the drywell and the vent header, including SRV penetrations
- The local region of the drywell at the vent line penetration
  - The bellows between the vent lines and the torus shell
  - The vent header and attached downcomers
    - The vent header supports
    - The vacuum breaker nozzle penetrations to the vent header

nute

- o Internal Structures
  - The internal structural elements including the monorail, catwalk, and their supports
  - The vent header deflectors and their supports
- The safety relief valve (SRV) discharge piping and supports
- o Miscellaneous
  - The instrumentation and control (I&C) conduit and tubing inside or attached to the torus
  - The Suppression Pool Temperature Monitoring System (SPTMS)



3



### 1-1.2 General Description of the Containment System

The Mark I containment is a pressure suppression system which houses the Boiling Water Reactor (BWR) pressure vessel, the reactor coolant recirculating loops, and other branch connections of the Nuclear Steam Supply System (NSSS). The containment consists of a drywell, a pressure suppression chamber (wetwell or torus) which is approximately half-filled with water, and a vent system which connects the drywell to the wetwell suppression pool. The suppression chamber is toroidal in shape and is located below and encircles the drywell. The drywell-to-wetwell vents are connected to a vent header contained within the air space of the wetwell. Downcomers project downward from the vent header and terminate below the water surface of the suppression pool. The pressure suppression chamber is described in greater detail in Sections 1-2.1.1 through 1-2.1.3 and in Volumes 2 and 3.

BWR's utilize safety relief valves (SRV's) attached to the main steam lines as a means of primary system overpressure protection. The outlet of each valve is connected to discharge piping which is routed to the

DET-04-028-1 Revision 0



suppression pool. The discharge lines end in T-quencher discharge devices. The SRV discharge lines are described in greater detail in Section 1-2.1.4 and Volume 5.





### 1-1.3 Review of Phemomena

The following subsections provide a brief qualitative description of the various phenomena that could occur during the course of a postulated LOCA and during SRV actuations. A detailed description of the hydrodynamic loads which these phenomena could impose upon the suppression chamber and related structures is given in the LDR (Reference 1). Section 1-4.0 presents the load definition procedures used to develop the Fermi 2 hydrodynamic loads.

DET-04-028-1 Revision 0

Immediately following a postulated Design Basis Accident (DBA) LOCA, the pressure and temperature of the drywell and vent system atmosphere rapidly increase. With the drywell pressure increase, the water initially present in the downcomers is accelerated into the suppression pool until the downcomers clear of water. Following downcomer water clearing, the downcomer air, which is at essentially drywell pressure, is exposed to the relatively low pressure in the wetwell, producing a downward reaction force on the torus. The consequent bubble expansion causes the pool water to swell in the torus (pool swell), compressing the airspace above the pool. This airspace compression results in an upward reaction force on the torus. Eventually, the bubbles "break through" to the torus airspace equalizing the pressures. An air/water froth mixture continues upward due to the momentum previously imparted to the water slug causing impingement loads on elevated structures. The transient associated with this rapid drywell air venting to the pool typically lasts for 3 to 5 seconds.

DET-04-028-1 Revision 0



Following air carryover, there is a period of high steam flow through the vent system. The discharge of steam into the pool and its subsequent condensation causes pool pressure oscillations which are transmitted to submerged structures and the torus shell. This phenomenon is referred to as condensation oscillation (CO). As the reactor vessel depressurizes, the steam flowrate to the vent system decreases. Steam condensation during this period of reduced steam flow is characterized by movement of the water/steam interface up and down within the downcomer as the steam volumes are condensed and replaced by surrounding pool water. This phenomenon is referred to as chugging.

Postulated Intermediate Break Accident (IBA) and Small Break Accident (SBA) LOCA's produce drywell pressure transients which are sufficiently slow that the dynamic effects of vent clearing and pool swell are negligible. However, CO and chugging occur for an IBA and chugging occurs for a SBA.

DET-04-028-1 Revision 0



Fermi 2 is equipped with 15 SRV's to control primary system pressure transients. The SRV's are mounted on the main steam lines inside the drywell with discharge pipes routed down the main vents into the suppression pool. When a SRV is actuated, steam released from the primary system is discharged into the suppression pool where it condenses.

Prior to the initial actuation of a SRV, the safety relief valve discharge lines (SRVDL's) contain air at atmospheric pressure and suppression pool water in the submerged portion of the piping. Following SRV actuation, steam enters the SRVDL compressing the air within the line and expelling the water slug into the suppression pool. During water clearing, the SRVDL undergoes a transient pressure loading.

Once the water has been cleared from the T-quencher discharge device, the compressed air enters the pool in the form of high pressure bubbles. These bubbles expand, resulting in an outward acceleration of the surrounding pool water. The momentum of the accelerated water results in an overexpansion of the

DET-04-028-1 Revision 0



bubbles, causing the bubble pressure to become negative relative to the ambient pressure of the surrounding pool. This negative bubble pressure slows and reverses the motion of the water, leading to a compression of the bubbles and a positive pressure relative to that of the pool. The bubbles continue to oscillate in this manner as they rise to the pool surface. The positive and negative pressures developed due to this phenomenon attenuate with distance and result in an oscillatory pressure loading on the submerged portion of the torus shell and internal structures.

### 1-1.4 Evaluation Philosophy

The development of event sequences, assumptions, load definitions, analysis techniques, and all the other facets comprising the Fermi 2 plant unique analysis are specifically formulated to provide a conservative evaluation. This section describes, in qualitative terms, some of the conservative elements inherent in the Fermi 2 plant unique analysis.

### Event Sequences and Assumptions

Implicit in the analysis of loss-of roolant accidents is the assumption that the event will occur although the probability of such pipe breaks is low. No credit is taken for detection of leaks to prevent LOCA's. Furthermore, various sizes of pipe breaks are evaluated to consider various effects. The large, instantaneous pipe breaks are considered to evaluate the initial, rapidly occurring events such as vent system pressurization and pool swell. Smaller pipe breaks are analyzed to maximize prolonged effects such as condensation oscillation and chugging.

DET-04-028-1 Revision 0



The various LOCA's analyzed are assumed to occur coincident with plant conditions which maximize the parameter of interest. For example, the reactor is assumed to be at 102% of rated power; a single failure is assumed; no credit is taken for normal auxiliary power. Operator action which can mitigate effects of LOCA's is assumed to be unavailable for a specified period. Other assumptions are also selected to maximize the parameter to be evaluated. This approach results in a conservative evaluation since the plant conditions are not likely to be in this worst case situation if a LOCA were to occur.

### Test Results and Load Definitions

The load definitions utilized in the Fermi 2 PUA are based on conservative test results and analyses. For example, the LOCA steam condensation loads (condensation oscillation and chugging) are based on tests in the Mark I Full-Scale Test Facility (FSTF). The FSTF is a full size 1/16th segment of a Mark I torus. To ensure that appropriately conservative results would be obtained, the FSTF was specifically designed and constructed to promote rapid air and

DET-04-028-1 Revision 0



steam flow from the drywell to the wetwell. While this maximizes hydrodynamic loads, it does not take into account the features of actual plants which would mitigate the effects of the LOCA. Actual Mark I drywells have piping and equipment in the drywell which would absorb some of the energy released during a LOCA. There are other features of the FSTF which are not typical of actual plant configurations, yet contribute to more conservative load definitions. Pre-heating of the drywell to minimize condensation and heat losses is an example of a non-prototypical feature. Additionally, the load definitions developed from FSTF data apply the maximum observed load over the entire period during which the load may occur. This conservative treatment takes no credit for the load variation observed in the tests.

LOCA pool swell loads were developed from similarly conservative tests at the Quarter-Scale Test Facility (QSTF). These tests were performed with the driving medium consisting of 100% non-condensibles. This maximizes the pool swell because this phenomenon would be driven by condensible steam if a LOCA were to occur in an actual plant. The QSTF tests also minimized the loss coefficient and maximized the

DET-04-028-1 Revision 0



drywell pressurization rate, thus maximizing the pool swell loads. The drywell pressurization rate used in the tests was calculated using conservative analytical modeling and initial conditions. Structures above the pool are assumed to be rigid when analyzed for pool swell impact loads. This assumption maximizes loads and is also used to evaluate loads on submerged structures.

The methods used to develop safety relief valve (SRV) loads are based on conservative assumptions, modeling techniques, and full and subscale test data. SRV loads are calculated assuming a minimum SRV opening time, a maximum steam flow rate, and a maximum steam line pressure, all of which maximize the SRV loads. Appropriate assumptions are also applied to conservatively predict SRV load frequency ranges. SRV loads on submerged structures are similar', determined with the additional assumptions that maximize the pressure differential across the structure due to bubble pressure phasing. The conservatism in the SRV load definition approach has been demonstrated by in-plant tests performed at several other plants. All such tests have confirmed that actual plant responses are significantly less than predicted. The

DET-04-028-1 Revision 0



Fermi 2 in-plant SRV tests are expected to confirm similar conservatisms.

### Load Combinations

Conservative assumptions have also been made in developing the combinations of loading phenomena to be evaluated. Many combinations of loading phenomena are investigated even though it is very unlikely for such combinations of phenomena to occur. For example, mechanistic analysis has shown that a SRV cannot actuate during the pool swell phase of a design basis LOCA. However, that combination of loading phenomena is evaluated. Both the pool swell and SRV load phenomena involve pressurized air bubbles in the pool and the structural response to these two different bubbles is assumed to be additive. However, this is a very conservative since two bubbles in a pool cannot assumption physically combine to form one bubble at a pressure higher than either separate bubble. This rationale is also valid for other hydrodynamic phenomena in the pool such as CO and chugging which are also combined with SRV discharge.

DET-04-028-1 Revision 0


When evaluating the structural response to combinations of loading phenomena, the peak responses due to the various loading phenomena are assumed to occur at the same time. While this is not an impossible occurrence, the probability that the actual responses will combine in that fashion is very remote. Furthermore, the initiating events themselves (e.g., LOCA or earthquake) are of extremely low probability.

#### Analysis Techniques

The methods used for analyzing LOCA and SRV loads also contribute to conservatism. In the analyses these loads are assumed to be smooth curves of regular or periodic shape. This simplifies load definitions and analyses but maximizes predicted responses. Data from full scale tests show actual forcing functions to be much less "pure" or "perfect" than those assumed for analysis.

The analyses generally treat a non-linear problem as a linear, elastic problem with the load "tuned" to the structural frequencies which produce maximum response. The non-linearities which exist in both the pool and structural dynamics would preclude the

DET-04-028-1 Revision 0 1-1.22



attainment of the elastic transient and steady state responses that are predicted mathematically.

Inherent in the structural analyses are additional conservatisms. Damping is assumed to be low to maximize response, but in reality, damping is likely to be much higher. Likewise, allowable stress levels are low compared to the expected material capabilities. Conservative boundary conditions are also used in the analyses.

#### Conclusion

The loads, methods, and results described above and elsewhere in this report demonstrate that the margins of safety which actually existed for the original design loads have not only been restored but have been increased. The advancements in understanding the hydrodynamic phenomena and in the structural analyses and modeling techniques have substantially increased since the original design and analysis were completed. This increased understanding and analysis capability is applied to the original loads as well as to the newly defined loads. Thus not only have

DET-04-028-1 Revision 0 1-1.23



the original safety margins been restored, but even greater margins now exist than in the original design.

### 1-2.0 PLANT UNIQUE CHARACTERISTICS

This section describes the general plant unique geometric and operating parameters pertinent to the re-evaluation of the suppression chamber design. Specific details are provided in subsequent volumes where the detailed analyses of individual components are described.





### 1-2.1 Plant Configuration

The containment vessel is a Mark I dc ign with a drywell and toroidal suppression chamber as illustrated in Figures 1-2.1-1 and 1-2.1-2. The structural components affected by the LOCA and SRV discharge loads include the suppression chamber and its column supports, the vent system and its support system, and the intersection of the vent lines with the drywell. Other items connected to the suppression chamber such as the electrical conduit, catwalk, monorail and the horizontal seismic supports are also included in this plant unique analysis.

The suppression chamber is in the general form of a torus but is actually constructed of 16 mitered cylindrical shell segments, as shown in Figure 1-2.1-2. A reinforcing ring with two supporting columns and a saddle is provided at each mitered joint.

The suppression chamber is connected to the drywell by eight vent lines. Within the suppression chamber, the vent lines are connected to a common vent header. Also connected to the vent header are

DET-04-028-1 Revision 0



downcomer which terminate below the water level of the suppression pool. A bellows assembly connecting the suppression chamber to the vent line allows for differential movement between the drywell and the suppression chamber.



DET-04-028-1 Revision 0





ELEVATION VIEW OF CONTAINMENT

DET-04-028-1 Revision 0



PLAN VIEW OF SUPPRESSION CHAMBER

DET-04-028-1 Revision 0



### 1-2.1.1 Suppression Chamber

The inside diameter of the mitered cylinders which make up the suppression chamber is 30'-6" (Figure 1-2.1-3). The suppression chamber shell thickness is typically 0.587" above the horizontal centerline and 0.658" below the horizontal centerline except at penetration locations where it is locally thicker.

The suppression chamber shell is reinforced at each mitered joint location by a T-shaped ring beam (Figure 1-2.1-4). A typical ring beam is located in a plane parallel to and on the vent line bay side of each mitered joint. The ring beam is braced laterally with stiffeners connecting the ring beam web to the suppression chamber shell.

The suppression chamber is supported vertically at each mitered joint location by inside and outside columns and by a saddle support which spans the inside and outside columns (Figure 1-2.1-4). The columns, associated column connection plates, and the saddle support are located parallel to the mitered joint in the plane of the ring beam web.

nutec

DET-04-028-1 Revision 0

The outside column members are constructed from rolled sections with cover plates. The inside column members are similarly constructed. The connection of the column members to the suppression chamber shell is achieved with web plates, flange plates, cover plates and stiffener plates.

The anchorage of the suppression chamber to the basemat is achieved by a system of base plates, stiffeners and anchor bolts located at each column, and at two locations on each saddle support. Six epoxy-grouted anchor bolts are provided at each column base plate location. Twelve epoxy-grouted anchor bolts are provided at each saddle base plate location. A total of 36 anchor bolts at each mitered joint location provide the principal mechanism for transfer of uplift loads to the basemat.

To optimize reductions of the SRV containment loads for Fermi 2, Detroit Edison Company elected to develop an alternate quencher design (Figure 1-2.1-5). Since Fermi 2 has larger SRV discharge line volumes than most Mark I plants, different quencher arm diameters and hole distributions were utilized to reduce loading beyond that which is

DET-04-028-1 Revision 0



available with the standard Mark I T-quencher device. Small-scale tests were used for screening various designs and for quantifying the performance of selected devices. The hole diameter and minimum spacing were maintained the same as the standard Mark I T-quencher described in the LDR to ensure steam condensation performance. A series of in-plant tests will be conducted after fuel load to confirm the performance of the Fermi T-quencher.

There are a total of 15 T-quenchers located at the mitered joints with the quencher arms located in the plane of the vertical centerline of the suppression chamber (Figure 1-2.1-6). Each quencher is supported at the mitered joint by a ramshead support (Figure 1-2.1-5). The quencher arms are supported laterally by a pipe beam located inside the vertical centerline of the suppression chamber at the same elevation as the quenchers and spanning the mitered joint ring beam. Loads which act on the quencher arms and the lateral quencher support beam are transferred to the ring beam.

DET-04-028-1 Revision 0 1-2.8

The suppression chamber also provides support for other containment-related structures such as the catwalk and monorail.



DET-04-028-1 Revision 0 1-2.9





SUPPRESSION CHAMBER SECTION-MIDBAY VENT LINE BAY

DET-04-028-1 Revision 0





SUPPRESSION CHAMBER SECTION-MITERED JOINT

t - 1



PLAN VIEW



FIGURE 1-2.1-5





DET-04-028-1 Revision 0



QUENCHER AND SUPPORT LOCATIONS

DET-04-028-1 Revision 0



The Fermi 2 vent system is constructed from cylindrical segments joined together to form a manifold-like structure which connects the drywell to the suppression chamber. A partial plan view of the vent system is provided in Figure 1-2.1-7. The cylinder connected to the end of the vent line has an inside diameter of 6'. Beyond the vent line intersection the vent header inside diameter is 4'3". There are 80 downcomers which protrude from the vent header as shown in the partial plan view in Figure 1-2.1-7.

The vent system is supported by two column members at each mitered joint location as shown in Figure 1-2.1-4. Stiffening for the vent line to vent header intersection is shown in Figure 1-2.1-8. The intersections of the downcomers and the vent header are reinforced with a system of stiffener plates and bracing members as shown in Figures 1-2.2-9 and 1-2.1-10. The bracing system shown in Figure 1-2.1-9 stiffens the downcomer intersection in a direction parallel to the vent header longitudinal axis. For horizontal loadings in a direction perpendicular to the vent header longitudinal axis, the downcomer to

DET-04-028-1 Revision 0



vent header intersection is stiffened by means of the collar and crotch plates shown in Figure 1-2.1-10.

The drywell/wetwell vacuum breaker penetrations are stiffened by providing a pipe beam between the ring plates with stiffener plates connecting the pipe beam to the vacuum breaker nozzles. The arrangement of the pipe beam and stiffeners is shown in Figures 1-2.1-11 and 1-2.1-12.

The vent system also provides support for a portion of the SRV piping inside the vent line and suppression chamber as shown in Figure 1-2.3-13. Loads which act on the SRV piping are transferred to the vent system by the penetration assembly on the vent line, and by support plates located under the vent line and vent header.









NOTE:

VENT HEADER DEFLECTOR, DOWNCOMER BRACING, ETC. NOT SHOWN FOR CLARITY.

Figure 1-2.1-7

VENT HEADER PLAN VIEW







VENT LINE TO VENT HEADER INTERSECTION

DET-04-028-1 Revision 0





#### NOTES:

- VIEW DEVELOPED NORMAL TO AXES OF VENT HEADER AND DOWNCOMER.
- VENT HEADER SUPPORT COLUMN DETAILS NOT SHOWN FOR CLARITY.
- VENT HEADER DEFLECTORS AND SRV PIPING NOT SHOWN FOR CLARITY.

### Figure 1-2.1-9

DEVELOPED VIEW OF VENT HEADER AND DOWNCOMER BRACING SYSTEM





DOWNCOMER TO VENT HEADER INTERSECTION

DET-04-028-1 Revision 0





VACUUM BREAKER PENETRATION - PLAN VIEW

DET-04-028-1 Revision 0







VACUUM BREAKER PENETRATION - DETAIL





DET-04-028-1 Revision 0

The location of the catwalk relative to other major components within the suppression chamber is shown in Figures 1-2.1-3 and 1-2.1-4. The catwalk is located parallel to the suppression chamber vertical centerline of each mitered cylinder. As shown in Figure 1-2.1-14, the catwalk frame is supported by hangers at the mitered joint ring beam and between each mitered joint. The support hangers consist of two angles which extend vertically upward from the catwalk as shown in Figure 1-2.1-15.

The location of the monorail relative to the other major components within the suppression chamber is shown in Figure 1-2.1-3 and 1-2.1-4. The monorail forms a complete circle around the inside of the suppression chamber. The monorail support system consists of two angles providing vertical support and two angles providing horizontal support as shown in Figure 1-2.1-16. This design provides support to the monorail beam for both the vertical and horizontal components of pool swell.

DET-04-028-1 Revision 0



NOTE:

(1) SEE FIGURE 1-2.1-15 FOR SECTION A-A

Figure 1-2.1-14

CATWALK FRAME



DET-04-028-1 Revision 0



(FROM FIGURE 1-2.1-14)

NOTE:

(1) HANDRAIL NOT SHOWN FOR CLARITY

Figure 1-2.1-15

CATWALK SUPPORTS

DET-04-028-1 Revision 0





MONORAIL SUPPORTS



DET-04-028-1 Revision 0

The outlet of each SRV is connected to discharge piping which is routed to the suppression pool. Routing of the SRV discharge piping is such that all eight of the vent lines are used with no more than two SRV lines being routed through any single vent line. The SRV piping in the drywell is supported by hangers, struts and snubbers connected to the back-up steel structures.

The use of all eight vent lines for routing of the 15 SRV lines results in only one SRV line terminating at any one reinforcing beam. The SRV piping exits the vent line through a stiffened insert plate as shown in Figure 1-2.1-13. Each line is then routed to the nearest mitered joint where the T-quencher is supported from the ring beam and T-quencher arm supports. Figures 1-2.1-3, 1-2.1-4, and 1-2.1-17 show typical SRV pipe routing in the wetwell.



DET-04-028-1 Revision 0 1-2.27



SRV PIPE ROUTING IN WETWELL - PLAN VIEW



DET-04-028-1 Revision 0 Plant operating parameters are used to determine many of the hydrodynamic loads utilized in the re-evaluation of the Fermi 2 suppression chamber design. Table 1-2.2-1 is a summary of the operating parameters used to determine the Fermi 2 hydrodynamic loads.



DET-04-028-1 Revision 0



## Table 1-2.2-1

COMPONENTS	CONDITION/ITEM	VALUE
DRYWELL	FREE AIR VOLUME <sup>(1)</sup> NORMAL OPERATING PRESSURE	163,730 cu ft +0% +1GH 1.8 psig LOW -0.5 psig
	NORMAL OPERATING TEMPERATURE	NOMINAL BULK 135°F MAX BULK 150°F MIN BULK 105°F
	NORMAL OPERATING RELATIVE HUMIDITY RANGE	HIGH 90% LOW 0%
	PRESSURE SCRAM INITIATION SETPOINT	2 psig ± 0.2 psig
	DESIGN INTERNAL PRESSURE	56 psig
	DESIGN EXTERNAL PRESSURE MINUS INTERNAL PRESSURE	2 psid
	DESIGN TEMPERATURE	340°F
SUPPRESSION CHAMBER	POOL VOLUME	MAX (HIGH WATER LEVEL) 124,220 ft <sup>3</sup> MIN (LOW WATER LEVEL) 121,080 ft <sup>3</sup>
	FREE AIR VOLUME <sup>(2)</sup>	MIN (HIGH WATER LEVEL) 137,370 ft <sup>3</sup> MAX (LOW WATER LEVEL) 140,500 ft <sup>3</sup>
	LOCA VENT SYSTEM DOWNCOMER SUBMERGENCE (DISTANCE OF DOWNCOMER DISCHARGE PLANE BELOW WATER LEVEL)	MIN (LOW WATER LEVEL) 3.00 ft MAX (HIGH WATER LEVEL) 3.33 ft
	WATER LEVEL DISTANCE TO TORUS CENTERLINE	MAX (LOW WATER LEVEL) 0.9166 ft MIN (HIGH WATER LEVEL) 0.5833 ft
	SUPPRESSION POOL SURFACE EXPOSED TO SUPPRESSION CHAMBER AIRSPACE	10,788 ft <sup>2</sup>
	NORMAL OPERATING PRESSURE RANGE	HIGH 1.8 psig LOW -0.5 psig

## SUPPRESSION CHAMBER OPERATING PARAMETERS

DET-04-028-1 Revision 0

#### Table 1-2.2-1

#### SUPPRESSION CHAMBER OPERATING PARAMETERS

(Concluded)

COMPONENTS	CONDITION/ITEM	VALUE	
	TEMPERATURE RANGE OF SUPPRESSION POOL	HIGH (TECH SPEC) LOW	950F 40 <sup>0</sup> F
	NORMAL OPERATING TEMPERATURE RANGE OF SUPPRESSION CHAMBER FREE AIR VOLUME	HIGH LOW	900F 500F
SUPPRESSION CHAMBER	NORMAL OPERATING RELATIVE HUMIDITY RANGE	HIGH LOW	60% 40%
	DESIGN INTERNAL PRESSURE	56 psig	
	EXTERNAL PRESSURE MINUS INTERNAL PRESSURE	2 psid	
	DESIGN TEMPERATURE	2810F	
	NORMAL OPERATING PRESSURE DIFFERENTIAL DRYWELL-TO-WETWELL	ZERO	
DOWNCOMER	ID AT DISCHARGE OD AT DISCHARGE TOTAL NUMBER OF DOWNCOMERS	1.958 ft 2 ft 80	
	LONG-TERM POST-LOCA CONTAINMENT LEAK RATE	MAX 0.5%/DA	Y
CONTAINMENT	DRYWELL-TO-WETWELL LEAKAGE SOURCE BYPASSING SUPPRESSION POOL WATER	MAX 0.108 ft2	
	SERVICE WATER TEMPERATURE LIMITS	MAX NORMAL ( (TECH SPEC) MIN NORMAL	890F 400F

SAFETY RELIEF VALVE (3)	SET POINT (psig)	CAPACITY AT 103% OF SET POINT (1bm/hr)
5	1110	884,700
5	1120	892,600
5	1130	900,500

NOTES :

(1) INCLUDES FREE AIR VOLUME OF THE LOCA VENT SYSTEM.

(2) DOES NOT INCLUDE FREE AIR VOLUME OF THE LOCA VENT SYSTEM.

(3) ADS CONSISTS OF FIVE SAFETY RELIEF VALVES.

#### 1-3.0 PLANT UNIQUE ANALYSIS CRITERIA

This section describes the acceptance criteria for the hydrodynamic loads and structural evaluations used in the plant unique analysis.

The acceptance criteria used in the PUA have been developed from the NRC review of the Long Term Program Load Definition Report (LDR), the Plant Unique Analysis Applications Guide (PUAAG), and the supporting analytical and experimental programs conducted by the Mark I Owners Group. These criteria are documented in NUREG-0661 for both hydrodynamic definition load and structural applications. Sections 1. and 2. of NUREG-0661 give Introduction and Background; Section 3. presents a detailed discussion of the Hydrodynamic Load Evaluation; Section 4. presents the Structural and Mechanical Analyses and Acceptance Criteria, and Appendix A presents the Hydrodynamic Acceptance Criteria.

•



#### 1-3.1 Hydrodynamic Loads: NRC Acceptance Criteria

Appendix A of NUREG-0661 resulted from the NRC evaluation of the load definition procedures for suppression pool hydrodynamic loads which were proposed by the Mark I Owners Group for use in their plant-unique analyses. This NRC evaluation addressed only those events or event combinations which involve suppression pool hydrodynamic loads. Unless otherwise specified, all loading conditions or structural analysis techniques used in the plant unique analysis, but not addressed in NUREG-0661, are in accordance with the Fermi 2 FSAR. The NRC hydrodynamic loads acceptance criteria are used with a coupled fluid-structure analytical model.

Wherever feasible, the conservative hydrodynamic acceptance criteria of NUREG-0661 were incorporated directly into the detailed plant unique load determinations and associated structural analyses. Where this simple, direct approach resulted in unrealistic hydrodynamic loads, more detailed plant unique analyses were performed. Many of these analyses have indicated that a specific interpretation of the generic rules was well-founded. These specific

DET-04-028-1 Revision 0 1-3.2


applications of the generic hydrodynamic acceptance criteria are identified in the following sections and are discussed in greater detail in Section 1-4.0.



## 1-3.1.1 LOCA-Related Load Applications

The hydrodynamic loads criteria are based on NRC review of and revision to experimentally-formulated hydrodynamic loads. Pool swell loads derived from plant unique quarter-scale two-dimensional tests are used to obtain net torus up-and-down loads and local pressure distributions. Vent system impact and drag loads resulting from pool swell effects are also based on experimental results, using analytical techniques where appropriate.

Condensation oscillation and chugging loads were derived from Full-Scale Test Facility (FSTF) results. Downcomer loads are based on test data, using comparisons of plant unique and FSTF dynamic load factors.

The acceleration drag volumes used in determining loads on submerged structures are calculated based upon the values in published technical literature rather than on the procedure which might be inferred from NUREG-0661, where the structure is idealized as a circumscribed circle for both velocity drag and for acceleration drag (see Section 1-4.1-5).

DET-04-028-1 Revision 0



Condensation oscillation and post-chug torus shell and submerged structure loads are defined in terms of 50 harmonics. Random phasing of the loading harmonics is assumed, based on FSTF data and subsequent analysis (see Section 1-4.1.7.1).

NUREG-0661 states that the FSI effect on condensation oscillation and chugging submerged structure loads can be accounted for by adding the shell boundary accelerations to the local fluid acceleration. For Fermi 2, the FSI effect for a given structure is included by adding the pool fluid acceleration at the location of the structure, rather than the shell boundary acceleration (see Section 1-4.1.7.3).

NUREG-0661 states that the multiple downcomer load during chugging should be based on an exceedance probability of  $10^{-4}$  per LOCA. More realistic probability levels are calculated for Fermi 2 by correlating the FSTF chugging duration and number of downcomers to the Fermi 2 chugging duration and the number of downcomers. The force per downcomer calculated in this manner for Fermi 2 results in a probability that the force will be exceeded not more

DET-04-028-1 Revision 0 1-3.5

than once per LOCA as a function of the number of downcomers chugging (see Section 1-4.1.8.2).

DET-04-028-1 Revision 0



The analysis techniques for SRV loads were developed to define T-quencher air clearing loads on the torus generically. However, a number of Mark I licensees have indicated that the generic load definition procedures are overly conservative for their plant design, especially when the procedures are coupled with conservative structural analysis techniques. To allow for these special cases, the NRC has stipulated requirements whereby in-plant tests could be used to derive the plant specific structural response to the SRV air clearing loads on the torus.

Because of the various phenomena associated with the air clearing phase of SRV discharge, some form of analysis procedure is necessary to extrapolate from test conditions to the design cases. Therefore, the NRC requirements are predicated on formulating a coupled load-structure analysis technique which is calibrated to the plant specific conditions for the simplest form of discharge (i.e., single valve, first actuation) and then applied to the design basis event conditions.

DET-04-028-1 Revision 0



SRV torus shell loads are evaluated using the alternate approach of NUREG-0661, which allows the use of in-plant SRV tests to calibrate a coupled load-structure analytical model. This method utilizes shell pressure waveforms more characteristic of those observed in tests. A series of in-plant SRV tests will be performed after fuel load to confirm that the computed loadings and predicted structural responses for SRV discharges are conservative (see Section 1-4.2.3).

For SRV bubble-induced drag loads on submerged structures, a bubble pressure multiplier is used which bounds the maximum peak positive bubble pressure and the maximum bubble pressure differential observed during the Monticello T-quencher tests (see Section 1-4.2.4). The improved performance characteristics of the Fermi 2 T-quencher would actually result in loads lower than those based on Monticello test data.

DET-04-028-1 Revision 0



As part of the PUA, each licensee is required to either demonstrate that previously submitted pool temperature response analyses are sufficient or provide plant-specific pool temperature response analyses to assure that SRV discharge transients will not exceed specified pool temperature limits. A suppression pool temperature monitoring system is also required to ensure that the suppression pool bulk temperature is within the allowable limits set forth in the plant technical specifications. Specific implementation of these considerations is discussed in Section 1-5.0.

Several loads are classified as secondary loads because of their inherent low magnitudes. These loads include: seismic slosh pressure loads; post-swell wave loads; asymmetric pool swell pressure loads; sonic and compression wave loads; and downcomer air clearing loads. These secondary loads are treated as negligible compared to other loads in the PUA which is in accordance with Appendix A of NUREG-0661.

DET-04-028-1 Revision 0 1-3.9

# 1-3.2 Component Analysis: Structural Acceptance Criteria

Section 4.0 of NUREG-0661 presents the NRC evaluation of the generic structural and mechanical acceptance criteria and of the general analysis techniques proposed by the Mark I Owners Group for use in the plant-unique analyses. Because most of the Mark I facilities were designed and constructed at different times, there are variations in the codes and standards to which they were constructed and subsequently licensed. For this reassessment of the suppression chamber, the criteria described in this subsection were developed to provide a consistent and uniform basis for acceptability. In this evaluation, references to "original design criteria" mean those specific criteria in the Fermi 2 Final Safety Analysis Report (FSAR).

DET-04-028-1 Revision 0



1-3.2.1 Classification of Components

The structures described in Section 1-1.1 were categorized in accordance with their functions in order to assign the appropriate service limits. The general components of a Mark I suppression chamber have been classified in accordance with the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code as specified in NUREG-0661.



DET-04-028-1 Revision 0



#### 1-3.2.2 Service Level Assignments

The criteria used in the plant-unique analyses to evaluate the acceptability of the existing Mark I containment designs or to provide the basis for any plant modifications generally follow Section III of the ASME Boiler and Pressure Vessel Code through the Summer 1977 Addenda.

#### Service Limits

The service limits are defined in terms of the Winter 1976 Addenda which introduced Levels A, B, C, and D. The selection of specific service limits for each load combination was dependent on the functional requirements of the component analyzed and the nature of the applied load. The assignments of service levels for each load combination are given in Tables 1-3.2-1 and 1-3.2-2. Details regarding service level assignments and other aspects of Tables 1-3.2-1 and 1-3.2-2 are described in Reference 2.

DET-04-028-1 Revision 0



# Table 1-3.2-1

# EVENT COMBINATIONS AND SERVICE LEVELS FOR CLASS MC

COMPONENTS AND INTERNAL STRUCTURES

EVENT COMBINATIONS		CPU	SRV + EQ		SBA IBA CO, CH		SBA IBA		A + EQ A + EQ CO, CH		SBA IBA	+SRV +SRV	SBA IBA	* 5 + 5	RV SRV	EQ EQ	D	ва		DBA	+ EQ	2	DBA+SR		DBA	+ E	Q +	SRV	
											JAN		CO, CH			co,	си	PS (1)	со, сн	PS		co,	, СН	PS	CO, CH	PS		co,	СН
TYPE OF EARTHQUAKE				0	s			0	S	0	S			0	S	0	S			0	S	0	S			0	S	0	s
COMBINATION NUMBER			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27
	NORMAL (2)	N	x	Х	X	X	х	x	x	x	x	x	X	x	х	х	х	х	x	X	х	х	X	х	х	х	x	X	X
EARTHQUAKE		EQ		X	X			х	x	х	X			x	x	x	х	1.6		x	х	x	x			x	X	x	X
	SRV DISCHARGE	SRV	х	х	x							х	x	X	х	х	х							x	x(7)	×	х	x(7)	X(7)
	LOCA THERMAL	ΓA				x	x	х	х	x	j x	X	x	x	х	х	х	х	х	x	x	х	X	x	х	x	х	x	X
	LOCA REACTIONS	RA				X	X	х	x	х	X	х	x	х	х	х	х	х	х	x	х	х	х	х	х	х	х	х	x
LOADS	LOCA QUASI-STATIC PRESSURE	PA				x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x	x
	LOCA POOL SWELL	PPS				-												x		x	x			x		x	x		
	LOCA CONDENSATION OSCILLATION	PCO					x			x	x		x			x	x		x			x	x		x			x	x
	LOCA CHUGGING P	сн			-		x			x	x		x			x	x		x	-		x	x		x			x	x
STRUCTURAL ELEMENT		ROW	-		-			-			-						-	-	-		-		-	-		-	-	-	-
EXTERNAL CLASS MC	TORUS, EXTERNAL VENT PIPE, BELLONS, DRYNELL (AT VENT), ATTACIMENT WELDS, TORUS SUP- PORTS, SEISMIC RESTRAINTS	1	A	в	с	A	A	в	с	в	с	A	A	в	с	в	с	A (3, 6)	A	B (3, 6)	с	в	с	c	с	с	с	с	с
INTERNAL VENT PIPE	GENERAL AND ATTACHMENT WELDS	2	A	в	с	A	A	в	с	в	с	A	A	в	с	в	с	A (3, 5)	A	B (3, 5)	с	в	с	с	с	с	c	с	с
	AT PENETRATIONS (e.g., HEADER)	3	A	в	с	A	A	в	с	в	с	A	A	в	с	в	с	A (3)	A	B (3)	с	в	с	с	с	с	с	с	с
VENT HEADER	GENERAL AND ATTACHMENT WELDS	4	A	в	с	A	A	в	с	в	с	A	A	в	с	в	с	A (3, 5)	A	B (3, 5)	с	в	с	с	с	с	с	c	с
	AT PENETRATIONS (e.g., DOWNCOMERS)	5	A	в	с	A	A (4)	в	с	B (4)	с	A	A (4)	в	с	B (4)	с	A (3, 4,5)	A (4)	8 (3, 4,5)	с	B (4)	с	с	с	с	с	c	с
DOWNCOMERS	GENERAL AND ATTACHMENT WELDS	6	A	в	с	A	A	в	с	в	с	A	A	в	с	в	с	A (3, 5)	A	B (3, 5)	с	в	с	с	с	с	с	с	с
IN	INTERNAL SUPPORTS 7		A	В	C	A	A	В	С	В	C	A	A	в	С	В	С	A	A	В	C	В	с	C	C	C	C	C	C
INTERNAL	GENERAL	8	A	В	С	A	A	С	D	C	D	С	С	D	Е	D	Е	E	E	E	E	E	ε	E	Е	Е	E	E	E
STRUCTURES	VENT DEFLECTOR	9	A	В	С	A	A	C	D	С	D	С	С	D	D	D	D	D	D	D	D	D	D	D	D	D	D	D	D

DET-04-028-1 Revision 0

1-3.13

#### NOTES TO TABLE 1-3.2-1

- (1) Reference 2 states "Where the drywell to wetwell pressure differential is normally utilized as a load mitigator, an additional evaluation shall be performed without SRV loadings but assuming loss of the pressure differential. In the additional evaluation, Level D Service Limits shall apply for all structural elements except Row 8 Internal Structures, which need not be evaluated. If drywell to wetwell pressure differential is not employed as a load mitigator, the listed service limits shall be applicable". Since Fermi 2 does not utilize a drywell-wetwell differential pressure, the listed service limits are applied.
- (2) Normal loads (N) consist of the combination of dead loads (D), live loads (L), thermal effects during operation  $(T_{\Omega})$  and pipe reactions during operation  $(R_{\Omega})$ .
- (3) Evaluation of primary-plus-secondary stress intensity range (NE-3221.4) and of fatigue (NE-3221.5) is not required.
- (4) When considering the limits on local membrane stress intensity (NE-3221.2) and primarymembrane-plus-primary-bending stress (NE-3221.3), the S<sub>mc</sub> value may be replaced by 1.3 S<sub>mc</sub>.

(NOTE: The modification to the limits does not affect the normal limits on primary-plussecondary stress intensity range (NE-3221.4 or NE-3228.3) nor the normal limits on fatigue evaluation (NE-3221.5(e) or Appendix II-1500). The modification is that the limits on local membrane stress intensity (NE-3221.2) and on primary-membrane-plus-primary bending stress intensity (NE-3221.3) have been modified by using 1.3  $S_{mc}$  in place of the normal  $S_{mc}$ .

This modification is a conservative approximation to results from limit analysis testing as reported in Reference 3 of Reference 2 and is consistent with the requirements of NE-3228.2).

- (5) Service Level Limits specified apply to the overall structural response of the vent system. An additional evaluation will be performed to demonstrate that shell stresses due to the local pool swell impingement pressures do not exceed Service Level C limits.
- (6) For the torus shell, the S<sub>mc</sub> value may be replaced by 1.0 S<sub>mc</sub> times the dynamic load factor derived from the torus structural model. As an alternative, the 1.0 multiplier may be replaced by the plant unique ratio of the torus dynamic failure pressure to the static failure pressure.
- (7) SRV actuation is assumed to occur coincident with the pool swell event. Although SRV actuation can occur later in the DBA, the resulting air loading on the torus shell is negligible since the air and water initially in the line will be cleared as the drywell to wetwell AP increases during the DBA transient.

# Table 1-3.2-2

### EVENT COMBINATIONS AND SERVICE LEVELS

# FOR CLASS 2 AND 3 PIPING

EVENT COMBINATIONS			CDU	SRV + EQ		SBA IBA CO CH		SBA IBA		+ EQ + EQ		SBA+SRV IBA+SRV		SBA + S IBA + S		SRV + EQ SRV + EQ		DBA		1	DBA	+ EQ	2	DBA+SRV		DBA	+ E	Q +	SRV
		1.1.1	SRV							co,	СН		CO, CH			co,	СН	PS (1)	CO, CH	PS		co,	СН	PS	CO, CH	PS		co,	СН
TYPE OF EARTHQUAKE				0	S			0	S	0	S			0	S	0	S			0	S	0	s			0	S	0	S
COMBINATION NUMBER			1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27
LOADS	NORMAL (2)	N	х	х	х	х	×	х	х	x	х	х	х	х	х	х	х	х	х	x	х	х	x	к	X	X	x	X	х
	EARTHQUAKE	EQ		х	x			x	х	x	x			х	х	х	х			x	х	х	x			x	x	x	x
	SRV DISCHARGE	SRV	х	х	X							X	x	х	х	х	х							X	X(6)	X	x	X(6)	X(6)
	THERMAL	TA	х	х	x	х	X	x	X	х	X	X	х	х	х	х	X	х	х	x	x	х	x	x	x	x	x	x	x
	PIPE PRESSURE	PA	Х	х	x	х	X	X	x	x	x	х	х	х	X	x	x	х	х	x	x	х	x	x	X	X	x	X	X
	LOCA POOL SWELL	Pps																X		x	x			X		X	x		
	LOCA CONDENSATION OSCILLATION	PCO					x			x	x		х			x	x		x			x			x			x	
	LOCA CHUGGING	PCH					X			х	x		X			x	x		x			x	x		x			x	x
STRUCTURAL ELEMENT ROW		ROW																			-			-		-	$\vdash$		
ESSENTIAL PIPING SYSTEMS	WITH IBA/DBA	10	в	в (3)	B (3)	B (4)	B (4)	B (4)	B (4)	B (4)	B (4)	B (4)	в (4)	B (4)	B (4)	B (4)	B (4)	B (4)	B (4)	в (4)	В (4)	в (4)	в (4)	B (4)	в (4)	в (4)	в (4)	в (4)	B (4)
	WITH SBA	11				B (3)	B (3)	B (4)	B (4)	B (4)	B (4)	B (3)	8 (3)	B (4)	B (4)	B (4)	B (4)	+	-	-	-	-	-	-	-	-	-	-	-
NONESSENTIAL PIPING SYSTEMS	WITH IBA/DBA	12	В	C (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)
	WITH SBA	13				C (5)	C (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	D (5)	-	-	-	-	-		-			-	-	-

nutech

\*

#### NOTES TO TABLE 1-3.2-2

- (1) Reference 2 states "Where drywell to wetwell pressure differential is normally utilized as a load mitigator, an additional evaluation shall be performed without SRV loadings but assuming the loss of the pressure differential. Service Level D limits shall apply for all structural elements of the piping system for this evaluation. The analysis need only be accomplished to the extent that integrity of the first pressure boundary isolation valve is demonstrated. If the normal plant operating condition does not employ a drywell to wetwell pressure differential, the listed service level assignments shall be applicable." Since Fermi 2 does not utilize a drywell to wetwell differential pressure, the listed service limits are applied.
- (2) Normal loads (N) consist of dead loads (D).
- (3) As an alternative, the 1.2 S<sub>h</sub> limit in Equation (9) of NC-3652.2 may be replaced by 1.8 S<sub>h</sub>, provided that all other limits are satisfied. Fatigue requirements are applicable to all columns, with the exception of 16, 18, 19, 22, 24 and 25.
- (4) Footnote (3) applies except that instead of using 1.8 S<sub>h</sub> in Equation (9) of NC-3652.2, 2.4 S<sub>h</sub> is used.
- (5) Equation (10) of NC or ND-3659 will be satisfied, except the fatigue requirements are not applicable to columns 16, 18, 19, 22, 24 and 25 since pool swell loadings occur only once. In addition, if operability of an active component is required to ensure containment integrity, operability of that component must be demonstrated.
- (6) SRV actuation is assumed to occur coincident with the pool swell event. Although SRV actuation can occur later in the DBA, the resulting air loading on the torus shell is neglible since the air and water initially in the line will be cleared as the drywell to wetwell AP increases during the DBA transient.

Revision ( 0 00 1 1

The general structural analysis techniques proposed by the Mark I Owners Group are utilized with sufficient detail to account for all significant structural response modes and are consistent with the methods used to develop the loading functions defined in the LDR. For those loads considered in the original design but not redefined by the LDR, either the results of the original analysis are used or a new analysis is performed, based on the methods employed in the original plant design.

The damping values used in the analysis of dynamic loading events are those specified in Regulatory Guide 1.61, "Damping Values for Seismic Design of Nuclear Power Plants" which is in accordance with NUREG-0661.

The structural responses resulting from two dynamic phenomena are combined by the absolute sum method. Time phasing of the two responses is such that the combined state of the stress results in the maximum stress intensity.

DET-04-028-1 Revision 0



1-4.0 HYDRODYNAMIC LOADS DEVELOPMENT METHODOLOGY AND EVENT SEQUENCE SUMMARY

> This section presents the load definition procedures used to develop the Fermi 2 hydrodynamic loads and is organized in accordance with NUREG-0661, Section 3. Table 1-4.0-1 provides a cross-reference between the sections of this PUAR and the sections of Appendix A of NUREG-0661 where each load or event is addressed.





#### Table 1-4.0-1

### PLANT UNIQUE ANALYSIS/NUREG-0661 LOAD SECTIONS

### CROSS-REFERENCE

LOAD/EVENT	PUA SECTION	NUREG-0661 APPENDIX A SECTION
CONTAINMENT PRESSURE AND TEMPERATURE RESPONSE	1-4.1.1	2.0
VENT SYSTEM DISCHARGE LOADS	1-4.1.2	2.2
POOL SWELL LOADS ON TORUS SHELL	1-4.1.3	2.3 & 2.4
POOL SWELL LOADS ON ELEVATED STRUCTURES	1-4.1.4	2.6 - 2.10
POOL SWELL LOADS ON SUBMERGED STRUCTURES	1-4.1.5 & 1-4.1.6	2.14.1 & 2.14.2
CONDENSATION OSCILLATION LOADS ON TORUS SHELL	1-4.1.7.1	2.11.1
CONDENSATION OSCILLATION LOADS ON DOWNCOMERS AND VENT	1-4.1.7.2	2.11.2
CONDENSATION OSCILLATION LOADS ON SUBMERGED STRUCTURES	1-4.1.7.3	2.14.5
CHUGGING LOADS ON TORUS SHELL	1-4.1.8.1	2.12.1
CHUGGING LOADS ON DOWNCOMERS	1-4.1.8.2	2.12.2
CHUGGING LOADS ON SUBMERGED STRUCTURES	1-4.1.8.3	2.14.6
SRV ACTUATION CASES	1-4.2.1	2.13.7
SRV DISCHARGE LINE CLEARING LOADS	1-4.2.2	2.13.2 & 2.13.1
SRV LOADS ON TORUS SHELL	1-4.2.3	2.13.3
SRV LOADS ON SUBMERGED STRUCTURES	1-4.2.4	2.14.3 & 2.14.4
DESIGN BASIS ACCIDENT	1-4.3.1	3.2.1*
INTERMEDIATE BREAK ACCIDENT	1-4.3.2	3.2.1*
SHALL BREAK ACCIDENT	1-4.3.2	3.2.1*

\* SECTIONS OF THE MAIN BODY OF NUREG-0661

DET-04-028-1 Revision 0



# 1-4.1 LOCA-Related Loads

This subsection describes the procedures used to define the Fermi 2 LOCA-related hydrodynamic loads. The sources of structural loads generated during a LOCA are primarily a result of the following conditions.

- Pressures and temperatures within the drywell,
  vent system and wetwell
- Fluid flow through the vent system
- Initial LOCA bubble formation in the pool and the resulting displacement of water due to pool swell
- Steam flow into the suppression pool (condensation oscillation and chugging)

For postulated pipe breaks inside the drywell, three LOCA categories are considered. These three categories, selected on the basis of break size, are referred to as the Design Basis Accident (DBA), Intermediate Break Accident (IBA) and Small Break Accident (SBA).

DET-04-028-1 Revision 0 1-4.3



The DBA for the Mark I containment design is the instantaneous guillotine rupture of the largest pipe in the primary system (recirculation suction line). This LOCA leads to a specific combination of dynamic, quasi-static and static loads. However, the DBA does not represent the limiting case for all loads and structural responses. Consequently, an Intermediate Break Accident (IBA) and a Small Break Accident (SBA) are also evaluated. The IBA is evaluated as a 0.1 ft<sup>2</sup> instantaneous liquid line break in the primary system, and the SBA is evaluated as a 0.01 ft<sup>2</sup> instantaneous steam line break in the primary system.



1-4.1.1 Containment Pressure and Temperature Response

The drywell and suppression chamber transient pressure and temperature responses are calculated using the General Electric Company Pressure Suppression Containment Analytical Model (Reference 5). This analytical model calculates the thermodynamic response of the drywell, vent system, and suppression chamber volumes to mass and energy released from the primary system following a postulated LOCA.

The containment pressure and temperature analyses are performed in accordance with Appendix A of NUREG-0661 and are documented in Reference 6.



#### 1-4.1.2 Vent System Discharge Loads

Of the three postulated LOCA categories, the DBA causes the most rapid pressurization of the containment system, the largest vent system mass flow rate, and therefore, the most severe vent system thrust loads. The pressurization of the containment for the IBA and SBA is much less rapid than for the DBA. Thus, the resulting vent system thrust loads for the SBA and IBA are bounded by the DBA thrust loads. Consequently, vent system thrust loads are only evaluated for the DBA.

Reaction loads occur on the vent system (main vent, vent header, and downcomers) following a LOCA due to pressure imbalances between the vent system and the surrounding torus airspace, and due to forces resulting from changes in flow direction.

The LDR thrust equations consider these forces due to pressure distributions and momentum to define horizontal and vertical thrust forces. These equations are included in the analytical procedures applied to the main vents, vent header, and downcomer portions of the vent system.

DET-04-028-1 Revision 0 1-4.6



Because main vents and downcomers are located symmetrically about the center of the vent system, the horizontal vent system thrust loads cancel each other, resulting in a zero effective horizontal vent system thrust load.

The bases, analytical procedures, and assumptions used to calculate thrust loads are described in the LDR. The Fermi 2 plant unique DBA thrust loads for the main vent, the vent header, and downcomers are based on a zero initial drywell/wetwell pressure differential. The thrust loads used in this PUA are documented in Reference 6.

The analysis of the vent system is presented in Volume 3 of the PUAR. The vent system discharge loads are developed in accordance with Appendix A of NUREG-0661.

.

DET-04-028-1 Revision 0

1-4.7

1-4.1.3 Pool Swell Loads on the Torus Shell

During the postulated LOCA, the air initially in the drywell and vent system is injected into the suppression pool, producing a downward reaction force on the torus followed by an upward reaction force. These vertical loads create a dynamic imbalance of forces on the torus, which acts in addition to the weight of the water applied to the torus. This dynamic force history lasts for only a few seconds.

The bases, assumptions, and justifications for the pool swell loads on the torus shell due to the DBA are described in the LDR. The pool swell loads on the torus shell are based on a series of Fermi 2 unique tests conducted in the Quarter-Scale Test Facility (QSTF) (Reference 7). The loads developed from these QSTF tests are documented in Reference 6. The pool swell loads on the torus shell used in the PUA are based on the information in Reference 6 with the addition of the upload and download margins specified in Appendix A of NUREG-0661.

From the plant unique average submerged pressure and the torus air pressure time histories, the local

DET-04-028-1 Revision 0 1-4.8



average submerged pressure transients at different locations on the shell are calculated using the LDR methodology and the criteria given in NUREG-0661.

In order to perform pool swell analysis of the torus shell and supports, shell loads are divided into static and dynamic components. This is accomplished by subtracting the airspace pressures from the average submerged pressures.

Torus shell load development procedures, methodology and assumptions are in accordance with Appendix A of NUREG-0661.





1-4.1.4 Pool Swell Loads on Elevated Structures

This subsection describes the load definition procedures used to define the following hydrodynamic loads on the main vent line and other structures initially above normal water level.

Pool swell impact and drag

Froth impingement, Region I

Froth impingement, Region II

· Pool fallback load

Froth fallback load

The analysis of the effect of pool swell loads on elevated structures is presented in Volumes 3 and 4 of this PUAR.

nute

1-4.1.4.1 Impact and Drag Loads on the Vent System

In the event of a postulated design basis LOCA, the pool surface rises during the pool swell phase and impacts structures in its path. The resulting loading condition of primary interest is the impact on the vent system. The impact phenomenon consists of two events: the impact of the pool on the structure and the drag on the structure as the pool flows past it following impact. The load definition includes both the impact and drag portions of the loading transient.

The vent system components which are potentially impacted during pool swell include the downcomers, the vent header deflector, and the main vents. There are no vent header impact or drag loads for Fermi 2 due to the presence of the vent header deflector. This was determined from plant unique quarter-scale tests with a deflector in place (Reference 7).

A generic pressure transient is specified for the downcomers and is assumed to apply uniformly over the bottom 50-degrees of the angled portion of the

DET-04-028-1 Revision 0 1-4.11

downcomer. The amplitude of the load is 8.0 psid and is applied as shown in Figures 1-4.1-1 and 1-4.1-2.

The vent header deflector loads are developed on a plant unique basis. The bases, assumptions, and justifications for vent header deflector impact loads are provided in the LDR. Reference 6 presents the full-scale loads for the Fermi 2 deflector. These loads are based on a zero initial drywell-to-wetwell pressure differential and include the load definition requirements specified in Appendix A of NUREG-0661.

Pool swell impact and drag loads on the main vent line are calculated using the procedure specified in Appendix A of NUREG-0661. The pool swell loads on the vent header, the downcomers, and the vent header deflector are also calculated in accordance with Appendix A of NUREG-0661.

DET-04-028-1 Revision 0 1-4.12

nute



### Figure 1-4.1-1

DOWNCOMER IMPACT AND DRAG PRESSURE TRANSIENT

DET-04-028-1 Revision 0





### Figure 1-4.1-2

APPLICATION OF IMPACT AND DRAG PRESSURE

TRANSIENT TO DOWNCOMER

DET-04-028-1 Revision 0

1-4.1.4.2 Impact and Drag Loads on Other Structures

As the pool surface rises due to the bubbles forming at the downcomer exits, it may impact structures located in the wetwell airspace. In the present context, "other structures" are defined as all structures located above the initial pool surface, exclusive of the vent system.

The LDR presents the bases, assumptions and methodology used in determining the pool swell impact and drag loads on structures located above the pool surface. These load specifications correspond to impact on "rigid" structures. When performing structural dynamic analysis, the "rigid body" impact loads are applied. However, the mass of the impacted structure is adjusted by adding the hydrodynamic mass of impact, except for gratings. The value of hydrodynamic mass is obtained using the methods described in the LDR.

In performing the structural dynamic analysis, drag following impact (Figures 1-4.1-3 and 1-4.1-4) is included in the forcing function. The transient

nutec

DET-04-028-1 Pevision 0 1-4.15

calculation is continued until the maximum stress in the structure is identified.

Impact and drag load development and application is in accordance with Appendix A of NUREG-0661.



DET-04-028-1 Revision 0



Figure 1-4.1-3

PULSE SHAPE FOR WATER IMPACT ON CYLINDRICAL TARGETS

DET-04-028-1 Revision 0

1-4.17







PULSE SHAPE FOR WATER IMPACT ON FLAT TARGETS

DET-04-028-1 Revision 0



#### 1-4.1.4.3 Pool Swell Froth Impingement Loads

During the final stages of the pool swell phase of a DBA LOCA, the rising pool breaks up into a two-phase froth of air and water. This froth rises above the pool surface and may impinge on structures within the torus airspace. Subsequently, when the froth falls back, it creates froth fallback loads. There are two mechanisms by which froth may be generated.

#### Region I Froth

As the rising pool strikes the bottom of the vent header deflector, a froth spray is formed, which travels upward and to both sides of the vent header. This is defined as the Region I froth impingement zone and is shown in Figure 1-4.1-5.

#### Region II Froth

A portion of the water above the expanding air bubble becomes detached from the bulk pool. This water is influenced only by its own inertia and gravity. The "bubble breakthrough" creates a froth which rises

DET-04-028-1 Revision 0 1-4.19

into the airspace beyond the maximum bulk pool swell height. This is defined as the Region II froth impingement zone and is shown in Figure 1-4.1-6.

LDR methods are used to define the froth impingement loads for Region I. For the Region I froth formation, the LDR method assumes the froth density to be 20% of full water density for structures with maximum cross-section dimensions of less than 1', and a proportionally lower density for structures greater than 1'. The load is applied in the direction most critical to the structure within the region of load application as defined in the LDR. The load is applied as a step function for a duration of 80 milliseconds.

The froth density of Region II is assumed to be 100% water density for structures or sections of structures with a maximum cross-sectional dimension less than or equal to 1', 25% water density for structures greater than 1', and 10% water density for structures located within the projected region directly above the vent header. The load is applied in the direction most critical to the structure within the region of load application as defined in

DET-04-028-1 Revision 0 1-4.20



the LDR. The load is applied as a rectangular pulse with a duration of 100 milliseconds.

For some structures, the procedures described above result in unrealistically conservative loads. In these situations the alternate procedure outlined in Appendix A of NUREG-0661 is used. This procedure consists of calculating Region I froth loads from high-speed QSTF movies. In this case, the froth source velocity, mean jet angle, and froth density in Region I are derived from a detailed analysis of the QSTF plant specific high-speed films.

With either methodology for Region I, the vertical component of the source velocity is decelerated to the elevation of the target structure to obtain the froth impingement velocity. The load is applied in the direction most critical to the structure within the sector obtained from QSTF movies. The QSTF movies were used to check if a structure was impinged by Region I froth. Uncertainty limits for each parameter are applied to assure a conservative load specification.

DET-04-028-1 Revision 0 1-4.21


The froth fallback pressure is based on the conservative assumption that all of the froth fallback momentum is transferred to the structure. The froth velocity is calculated by allowing the froth to fall freely from the height of the upper torus shell directly above the subject structure. The froth fallback pressure is applied uniformly to the upper projected area of the structure being analyzed in the direction most critical to the behavior of the structure. The froth fallback is specified to start when the froth impingement load ends and lasts for 1.0 second. The range of direction of application is directed downward ±45 degrees from the vertical.

The pool swell froth impingement and froth fallback loads used in the PUA are in accordance with Appendix A of NUREG-0661.

DET-04-028-1 Revision 0





FROTH IMPINGEMENT ZONE - REGION I

DET-04-028-1 Revision 0







FROTH IMPINGEMENT ZONE - REGION II

1-4.24

DET-04-028-1 Revision 0



#### 1-4.1.4.4 Pool Fallback Loads

This subsection describes pool fallback loads which apply to structures within the torus that are below the upper surface of the pool at its maximum height and above the downcomer exit level. After the pool surface has reached maximum height as a result of pool swell, it falls back under the influence of gravity and creates drag loads on structures inside the torus shell. The structures affected are between the maximum bulk pool swell height and the downcomer exit level, or immersed in an air bubble extending beneath the downcomer exit level.

For structures immersed in the pool, the drag force during fallback (as described in the LDR) is the sum of standard drag (proportional to velocity squared) and acceleration drag (proportional to acceleration). For structures which are beneath the upper surface of the pool but within the air bubble, there is an initial load associated with resubmergence of the structure by either an irregular impact with the bubble-pool interface or a process similar to froth fallback. This initial load is bounded by the

DET-04-028-1 Revision 0

1-4.25

standard drag because conservative assumptions are made in calculating the standard drag.

The load calculation procedure, as described in the LDR, requires determination of the maximum pool swell height above the height of the top surface of the structure. Freefall of the bulk fluid from this height is assumed and this produces both standard drag and acceleration drag, with the total drag given by the sum.

The LDR procedure results in a conservative calculation of the velocity since it is unlikely that any appreciable amount of pool fluid will be in freefall through this entire distance. The maximum pool swell height is determined from the QSTF plant unique tests (Reference 7).

The procedures outlined in Appendix A of NUREG-0661 are used to account for interference effects associated with both standard and acceleration drag forces.

nute

DET-04-028-1 Revision 0

Structures which may be enveloped by the LOCA bubble are evaluated for potential fallback loads as a result of bubble collapse to ensure that such loads are not larger than the LOCA bubble-drag loads (Section 1-4.1.6).

The fallback load is applied uniformly over the upper projected surface of the structure in the direction most critical to the behavior of the structure. The range of ±45 degrees from the vertical is applied to both the radial and longitudinal planes of the torus.

The procedures used in the PUA to determine pool fallback loads are in accordance with Appendix A of NUREG-0661.



#### 1-4.1.5 LOCA Waterjet Loads on Submerged Structures

As the drywell pressurizes during a postulated DBA LOCA, the water slug initially standing in the submerged portion of the downcomer vents is accelerated downward into the suppression pool. As the water slug enters the pool, it forms a jet which could potentially load structures which are intercepted by the discharge. Forces due to the pool acceleration and velocity induced by the advancing jet front are also created.

LOCA water jet loads affect structures which are enclosed by the jet boundaries and last from the time that the jet first reaches the structure until the time when the last particle of the water slug passes the structure. Pool motion can create loads on structures which are within the region of motion for the duration of the water jet. The assumptions included in the methodology are presented in the LDR.

The calculation procedure used to obtain LOCA jet loads is based on experimental data obtained from tests performed at the Quarter-Scale Test Facility (Reference 7) and on the analytical model described

DET-04-028-1 Revision 0



in Reference 1. Plant unique downcomer clearing information, obtained experimentally during the QSTF testing in the form of LOCA jet fluid velocity and acceleration time-histories, is shown in Figure 1-4.1-7.

As the jet travels through the pool, the particles at the rear of the water slug, which were discharged from the downcomer at higher velocities, catch up with particles at the front of the water slug, which were discharged at lower velocities. When this "overtaking" occurs both particles are assumed to continue on at the higher velocity. As the rear particles catch up to the particles in front, the jet becomes shorter and wider. When the last fluid particle leaving the downcomer catches up to the front of the jet, the jet dissipates.

Forces due to pool motion induced by the advancing jet are calculated for structures that are within four downcomer diameters below the downcomer exit elevation. The f ow field, standard drag and acceleration drag are calculated using the equations in the LDR.

DET-04-028-1 Revision 0



Structures that are within four downcomer diameters below the downcomer exit elevation will sustain a loading, first from the flow field induced by the jet, then from the jet itself if it is within the cross-section of the jet. Forces resulting from the flow field are due to standard drag and acceleration drag. The force from the jet is due to standard drag only, since particles within the jet travel at constant discharge velocity (i.e., there is no acceleration).

The standard drag force on the submerged structure is computed based on the normal component of velocity intercepting the structure, the projected area of the structure intercepted by the normal component of velocity, and the jet or flow field area.

For LOCA water jet loads, downcomers are modeled as jet sources for submerged structures based on the location of the structure.

Structures are divided into several sections following the procedure given in the LDR and the criteria given in NUREG-0661. For each section, the

DET-04-028-1 Revision 0



location, acceleration drag volume, drag coefficient and orientation are input into the LOCA jet model.

The LOCA water jet loads on circular cross-section structures due to standard and acceleration drag are developed in accordance with Appendix A of NUREG-0661. For structures with sharp corners, these drag loads are calculated considering forces on an equivalent cylinder of diameter  $D_{eq} = 2^{1/2} L_{max}$ where Lmax is the maximum transverse dimension. For acceleration drag, this technique results in unrealistic loads on some structures such as I-beams due to the significant increase in the acceleration drag volume. For Fermi 2 applications this represents two to three times the published acceleration drag volumes. In these cases the acceleration drag volumes in Table 1-4.1-1 are used in the acceleration drag load calculation. A literature search concluded that these acceleration drag volumes are appropriate in this application. References 8 and 9 show that the values in Table 1-4.1-1 are applicable for the cases evaluated in this analysis.

•

DET-04-028-1 Revision 0



The LOCA water jet load is a transient load and therefore is applied dynamically. The LOCA jet loads are presented in Volume 4.



## HYDRODYNAMIC MASS AND ACCELERATION DRAG VOLUMES

## FOR TWO-DIMENSIONAL STRUCTURAL COMPONENTS

(LENGTH L FOR ALL STRUCTURES)

BODY	SECTION THROUGH BODY AND UNIFORM FLOW DIRECTION	HYDRODYNAMIC MASS	ACCELERATION DRAG VOLUME V <sub>A</sub>
CIRCLE	↔ Ø <sup>R</sup>	ρπR <sup>2</sup> L	27R <sup>2</sup> L
ELLIPSE		ρπa <sup>2</sup> L	πa(a+b)L
ELLIPSE		ρπb²L	πb(a+b)L
PLATE	[]2a	ρπa <sup>2</sup> L	πa <sup>2</sup> L
RECTANGLE	2a	a/b ρπa²L   10 1.14 ρπa²L   5 1.21 ρπa²L   2 1.36 ρπa²L   1 1.51 ρπa²L   1/2 1.70 ρπa²L   1/5 1.98 ρπa²L   1/102.23 ρπa²L	aL(4b+a) aL(4b+1.14πa) aL(4b+1.21πa) aL(4b+1.36πa) aL(4b+1.51πa) aL(4b+1.70πa) aL(4b+1.98πa) aL(4b+2.23πa)
DIAMOND		a/b .85 ρπa²L   1 0.76 ρπa²L   1/2 0.67 ρπa²L   1/5 0.61 ρπa²L	aL(2b+0.85πa) aL(2b+0.76πa) aL(2b+0.67πa) aL(2b+0.61πa)
I-BEAM		$\frac{a}{c} = 2.6 \frac{b}{c} = 2.6$ 2.11 oma <sup>2</sup> L	(2.11πa <sup>2</sup> +2c(2a+b-c))L

DET-04-028-1 Revision 0



### HYDRODYNAMIC MASS AND ACCELERATION DRAG VOLUMES

FOR TWO-DIMENSIONAL STRUCTURAL COMPONENTS

(LENGTH L FOR ALL STRUCTURES)

(Concluded)

BODY	BODY AND FLOW DIRECTION	HYDRODYNAMIC MASS	ACCELERATION DRAG VOLUME V <sub>A</sub>
RECTANGULAR PLATE		b/a 1 0.478 ρπ/4a <sup>2</sup> b 1.5 0 680 ρπ/4a <sup>2</sup> b 2 0.840 ρπ/4a <sup>2</sup> b 2.5 0.953 ρπ/4a <sup>2</sup> b 3 ρπ/4a <sup>2</sup> b ρπ/4a <sup>2</sup> b	0.478π/4a <sup>2</sup> b 0.680π/4a <sup>2</sup> b 0.840π/4a <sup>2</sup> b 0.953π/4a <sup>2</sup> b π/4a <sup>2</sup> b π/4a <sup>2</sup> b
TRIANGULAR PLATE		$\frac{\rho a^3 (\tan \theta)^{3/2}}{3\pi}$	$\frac{a^3 (\tan \theta)^{3/2}}{3\pi}$
SPHERE	() <sub>R</sub>	p2/3R <sup>3</sup>	2πR <sup>3</sup>
CIRCULAR DISK		8/3R <sup>3</sup>	8/3R <sup>3</sup>
ELLIPTICAL DISK	- a b	b/a pπ/6ba <sup>2</sup> 3 0.9 pπ/6ba <sup>2</sup> 2 0.826 pπ/6ba <sup>2</sup> 1.5 0.748 oπ/6ba <sup>2</sup> 1 0.637 pπ/6ba <sup>2</sup>	π/6ba <sup>2</sup> 0.9π/6ba <sup>2</sup> 0.826π/6ba <sup>2</sup> 0.748π/6ba <sup>2</sup> 0.637π/6ba <sup>2</sup>





Figure 1-4.1-7

QUARTER-SCALE DOWNCOMER WATER SLUG EJECTION, TEST 7

DET-04-028-1 Revision 0

1-4.1.6 LOCA Bubble - Induced Loads on Submerged Structures

During the initial phase of the DBA, pressurized drywell air is purged into the suppression pool through the submerged downcomers. After the vent clearing phase of a DBA, a single bubble is formed around each downcomer. During the bubble growth period, unsteady fluid motion is created within the suppression pool. During this period, all submerged structures below the pool surface will be exposed to transient hydrodynamic loads.

The bases of the flow model and load evaluation for the definition of LOCA bubble-induced loads on submerged structures are presented in Section 4.3.8 of the LDR.

After contact between bubbles of adjacent downcomers, the pool swell flow field above the downcomer exit elevation is derived from QSTF plant unique tests (Reference 7). After bubble contact, the load will act only vertically. This pool swell drag load is computed using the method described in Section 1-4.1.4.2.

nute

DET-04-028-1 Revision 0

The parameters which affect load determination are torus geometry, downcomer locations, and thermodynamic properties. These plant specific data are presented in Table 1-4.1-2. The DBA plant unique transient drywell pressure time-history, which is an input into the model, is presented in Figure 1-4.1-8.

The number of downcomer vents modeled is dependent on the location of the submerged structure. The torus is modeled as a rectangular cell with dimensions as given in Table 1-4.1-2.

The structures are divided into sections and the loads on each section are calculated following the procedure given in the LDR and the criteria given in NUREG-0661.

The procedure used for calculating drag loads on structures with circular and sharp-cornered crosssections is in accordance with Appendix A of NUREG-0661. For some structures with sharp corners such as I-beams, the acceleration drag volumes are calculated using the information in Table 1-4.1-1.

DET-04-028-1 Revision 0



The LOCA bubble loads are transient loads and are therefore applied dynamically. The plant specific loads for submerged structures are presented in Volume 4 of the PUAR.



DET-04-028-1 Revision 0

## PLANT UNIQUE PARAMETERS FOR LOCA BUBBLE DRAG LOAD DEVELOPMENT

	VALUE	
NUMBER OF DOWNCOMERS		8-10
WATER DEPTH	IN TORUS (ft)	14.67
CELL	WIDTH (ft)	30.48
CEDD	LENGTH (ft)	33.15-44.76
VERTICAL DIS TO TORUS CEN	STANCE FROM DOWNCOMER EXIT NTERLINE (ft)	3.932
DOWNCOMER	INSIDE RADIUS (ft)	0.979
DOWNCOMER	SUBMERGENCE (ft)	3.33
UNDISTURBED PRESSURE AT BUBBLE CENTER ELEVATION BEFORE THE BUBBLE APPEARS (psig)		16.07
INITIAL	PRESSURE BEFORE LOCA (psig)	14.2
DRYWELL TEMPERATURE BEFORE LOCA (°F)		135
OVERALL VENT PIPE FRICTION FACTOR (f1/d)		5.51
INITIAL LOCA	14.88	





Figure 1-4.1-8

QUARTER-SCALE DRYWELL PRESSURE TIME-HISTORY

DET-04-028-1 Revision 0

## 1-4.1.7 Condensation Oscillation Loads

This subsection describes the condensation oscillation loads on the various structures and components in the suppression chamber.

Following the pool swell transient of a postulated LOCA, there is a period during which condensation oscillations occur at the downcomer exit. Condensation oscillations are associated with the pulsating movement of the steam-water interface caused by variations in the condensation rate at the downcomer exit. These condensation oscillations cause periodic pressure oscillations on the torus shell, submerged structures and in the vent system. The loads specified for condensation oscillation are based on the Full-Scale Test Facility (FSTF) tests (References 10, 11 and 12). The LDR and NUREG-0661 discuss the bases, assumptions and methodology for computation of the condensation oscillation loads.

•

DET-04-028-1 Revision 0



1-4.1.7.1 CO Loads on the Torus Shell

Loads on the submerged portion of the torus shell during the condensation oscillation phenomenon consist of pressure oscillations superimposed on the prevailing local static pressures.

The condensation oscillation load on the torus shell is a rigid wall load specified in terms of the pressure at the torus bottom dead center. It is used conjunction with a flexible wall in coupled fluid-structural model of the torus. The LDR load definition for condensation oscillation consists of 50 harmonic loadings with amplitudes which vary with frequency. Three alternate rigid wall pressure amplitude variations with frequency are specified in A fourth alternate load case is also the LDR. considered based on the results of Test M12 from the supplemental test series conducted at the FSTF (References 11 and 12). The rigid wall pressure amplitude variation with frequency is given in Table 1-4.1-3 and Figure 1-4.1-9. The alternate frequency spectrum which produces the maximum total response is used for design.

DET-04-028-1 Revision 0 1-4.42

nute

The effects of all harmonics must be summed to obtain the total response of the structure. Random phasing of the loading harmonics is assumed, based on experimental observations and subsequent analysis.

The implementation of the random phasing approach is accomplished by multiplying the absolute sum of the responses of all 50 harmonics by a scale factor. This scale factor is calculated using cumulative distribution function (CDF) curves of the responses at 14 locations on the FSTF torus shell. Each of the CDF curves is generated using 200 sets of random phase angles. Using this approach, a scale factor of 0.65 is developed which results in a non-exceedance probability of 84% at a confidence level of 90%. This scale factor is applied to the absolute sum of the responses of all 50 harmonics for all Fermi 2 torus shell locations evaluated.

Table 1-4.1-4 compares measured and calculated FSTF response to CO loads. The calculated FSTF response in Table 1-4.1-4 is determined using CO load Alternates 1, 2, and 3 and the random phasing approach described above. In all cases the calculated response is greater than the measured

DET-04-028-1 Revision 0



response, demonstrating the conservatism of this approach. Although not shown in Table 1-4.1-4, CO load Alternate 4 adds approximately 20% to the calculated shell response. Thus using Alternate 4 in the Fermi 2 analysis contributes additional conservatism to the comparison shown in Table 1-4.1-4.

The onset times and durations for condensation oscillation are specified in Table 1-4.1-5. Test results indicate that for the postulated IBA, condensation oscillation loads are bounded by chugging loads. Test results also indicate that for the postulated SBA, condensation oscillation loads are not significant, and therefore none are specified.

The longitudinal condensation oscillation pressure distribution along the torus centerline is uniform. The cross-sectional variation of the torus wall pressure varies linearly with elevation from zero at the water surface to a maximum at the torus bottom (Figure 1-4.1-10).

nute

DET-04-028-1 Revision 0

Since torus dimensions and the number of downcomers vary, the magnitude of the condensation oscillation load differs for each Mark I plant. A multiplication factor was developed to account for the effect of the pool-to-vent area ratio. This factor is 0.86 for Fermi 2 and was developed using the method described in the LDR (Figure 1-4.1-11). The Fermi 2 unique condensation oscillation load is determined by multiplying the amplitude of the baseline rigid wall load (Table 1-4.1-3) by this factor.



DBA CONDENSATION OSCILLATION TORUS SHELL PRESSURE AMPLITUDES

INTERVALS (Hz)	ALTERNATE 1 0.29	ALTERNATE 2	ALTERNATE 3	ALTERNATE
0-1	0.29		a second s	
0-1		0.29	0.29	0.25
1-2	0.25	0.25	0.25	0.28
2-3	0.32	0.32	0.32	0.33
3-4	0.48	0.48	0.48	0.56
4-5	1.86	1.20	0.24	2.71
5-6	1.05	2.73	0.48	1.17
6-7	0.49	0.42	0.99	0.97
7-8	0.59	0.38	0.30	0.47
8-9	0.59	0.38	0.30	0.34
9-10	0.59	0.38	0.30	0.47
10-11	0.34	0.79	0.18	0.49
11-12	0.15	0.45	0.12	0.38
12-13	0.17	0.12	0.11	0.20
13-14	0.12	0.08	0.08	0.10
14-15	0.06	0.07	0.03	0.11
15-16	0.10	0.10	0.02	0.08
16-17	0.04	0.04	0.04	0.04
17-18	0.04	0.04	0.04	0.05
18-19	0.04	0.04	0.04	0.03
19-20	0.27	0.27	0.27	0.34
20-21	0.20	0.20	0.20	0.23
21-22	0.30	0.30	0.30	0.49
22-23	0.34	0.34	0.34	0.37
23-24	0.33	0.33	0.33	0.31
24-25	0.16	0.16	0.16	0.22

DET-04-028-1 Revision B



.

## DBA CONDENSATION OSCILLATION TORUS SHELL PRESSURE AMPLITUDES (Concluded)

FREQUENCY	MAXIMUM PRESSURE AMPLITUDE (psi)				
INTERVALS (Hz)	ALTERNATE 1	ALTERNATE 2	ALTERNATE 3	ALTERNATE	
25-26	0.25	0.25	0.25	0.50	
26-27	0.58	0.58	0.58	0.51	
27-28	0.13	0.13	0.13	0.39	
28-29	0.19	0.19	0.19	0.27	
29-30	0.14	0.14	0.14	0.09	
30-31	0.08	0.08	0.08	0.08	
31-32	0.03	0.03	0.03	0.07	
32-33	0.03	0.03	0.03	0.05	
33-34	0.03	0.03	0.03	0.04	
34-35	0.05	0.05	0.05	0.04	
35-36	0.08	0.08	0.08	0.07	
36-37	0.10	0.10	0.10	0.11	
37-38	0.07	0.07	0.07	0.06	
38-39	0.06	0.06	0.06	0.05	
39-40	0.09	0.09	0.09	0.03	
40-41	0.33	0.33	0.33	0.08	
41-42	0.33	0.33	0.33	0.19	
42-43	0.33	0.33	0.33	0.19	
43-44	0.33	0.33	0.33	0.13	
44-45	0.33	0.33	0.33	0.18	
45-46	0.33	0.33	0.33	0.30	
46-47	0.33	0.33	0.33	0.18	
47-48	0.33	0.33	0.33	0.19	
48-49	0.33	0.33	0.33	0.17	
49-50	0.33	0.33	0.33	0.21	

•



	CALCULATED FSTF RESPONSE AT 84% NEP <sup>(1)</sup>	MAXIMUM MEASURED FSTF RESPONSE		
RESPONSE QUANTITY		М8	MllB	M12
BOTTOM DEAD CENTER AXIAL STRESS (ksi)	3.0	2.3	1.6	2.7
BOTTOM DEAD CENTER HOOP STRESS (ksi)	3.7	2.6	1.4	2.9
BOTTOM DEAD CENTER DISPLACEMENT (in.)	0.17	0.11	0.08	0.14
INSIDE COLUMN FORCE (kips)	184	93	80	109
OUTSIDE COLUMN FORCE (kips)	208	110	89	141

## FSTF RESPONSE TO CONDENSATION OSCILLATION

NOTE :

(1) USING CO LOAD ALTERNATES 1, 2 AND 3.



BREAK SIZE	ONSET TIME AFTER BREAK	DURATION AFTER ONSET
DBA	5 SECONDS	30 SECONDS
IBA	5 SECONDS(1)	300 SECONDS <sup>(1)</sup>
SBA	NOT APPLICABLE	NOT APPLICABLE

#### CONDENSATION OSCILLATION ONSET AND DURATION

NOTE:

 FOR THE IBA, CHUGGING LOADS AS DEFINED IN SECTION 1-4.1.8.2. ARE USED.





ALL AMPLITUDES REPRESENT ONE-HALF OF THE PEAK-TO-PEAK AMPLITUDE.

## Figure 1-4.1-9

CONDENSATION OSCILLATION BASELINE RIGID WALL PRESSURE AMPLITUDES ON TORUS SHELL BOTTOM DEAD CENTER

DET-04-028-1 Revision 0



NOTES:

1. A = LOCAL PRESSURE OSCILLATION AMPLITUDE.

2. A<sub>MAX</sub> = MAXIMUM PRESSURE OSCILLATION AMPLITUDE (AT TORUS BOTTOM DEAD CENTER).

Figure 1-4.1-10

MARK I CONDENSATION OSCILLATION - TORUS VERTICAL CROSS-SECTIONAL DISTRIBUTION FOR PRESSURE OSCILLATION AMPLITUDE

1-4.51





MARK I CONDENSATION OSCILLATION - MULTIPLICATION FACTOR TO ACCOUNT FOR THE EFFECT OF THE POOL-TO-VENT AREA RATIO

1-4.52

nutecr

1-4.1.7.2 CO Loads on the Downcomer and Vent System

#### Downcomer Dynamic Loads

The downcomers experience loading during the condensation oscillation phase of the blowdown. The procedure for defining the dynamic portion of this loading for both a DBA and an IBA is presented in this section. Condensation oscillation loads do not occur for the SBA. The bases, assumptions, and loading definition details are presented in the LDR.

The downcomer dynamic load involves two components:

- An internal pressure load of equal magnitude in each downcomer in a pair and
- A differential pressure load between downcomers in a pair

Both the internal pressure load and the differential pressure load have three frequency bands over which they are applied. Figure 1-4.1-12 shows a typical downcomer and a schematic of downcomer loading conditions during the CO phase of a blowdown.

DET-04-028-1 Revision 0 1-4.53

Table 1-4.1-6 lists the downcomer internal pressure loads for the DBA CO period. Figure 1-4.1-13 shows the internal pressure load and the three frequency bands over which they are applied. The dominant downcomer frequency is determined from a harmonic analysis where the dominant downcomer frequency is shown to occur in the frequency range of the second condensation oscillation downcomer load harmonic (see Volume 3). The first and third condensation oscillation downcomer load harmonics are therefore applied at frequencies equal to 0.5 and 1.5 the value of the dominant downcomer frequency.

Table 1-4.1-7 defines the downcomer differential pressure loads for the DBA CO period. Application of the dominant harmonic differential pressures is the same as for the internal pressure application previously discussed. Figure 1-4.1-14 shows the differential pressure amplitudes and frequency ranges.

Figure 1-4.1-15 shows how the downcomer CO dynamic loads are applied to the different downcomer pairs on the Fermi 2 vent header system. The total response

DET-04-028-1 Revision 0



of the downcomer/vent header intersection to the CO dynamic load is the sum of the responses from the internal and differential pressure components. All eight load cases are evaluated and the case with the maximum response is used for design.

Table 1-4.1-8 provides the downcomer internal pressure loads for the IBA CO period. Figure 1-4.1-16 shows these downcomer internal pressure load values and the range of application. Table 1-4.1-9 gives the downcomer differential pressure loads for the IBA CO period. The procedure used to evaluate the IBA CO downcomer loads is the same as that used for the DBA CO downcomer loads. The load cases for the IBA loads are also the same as for the DBA loads; therefore, Figure 1-4.1-15 is used.

#### Vent System Loads

Loads on the vent system during the condensation oscillation phenomenon result from harmonic pressure oscillations superimposed on the prevailing local static pressures in the vent system.

DET-04-028-1 Revision 0



Condensation oscillation loads are specified for all three components of the vent system: the main vents, the vent header, and the downcomers (Table 1-4.1-10). These loads, as determined from FSTF data, are generic and are thus directly applicable to all Mark I plants.

In addition to the oscillating pressure described above, a uniform static pressure is applied to the main vents, vent header, and the downcomers to account for the nominal submergence of the downcomers.

## DOWNCOMER INTERNAL PRESSURE LOADS FOR DBA CONDENSATION OSCILLATION

FREQUENCY	PRESSURE (psi)	APPLIED FREQUENCY RANGE (Hz)
DOMINANT	3.6	4-8
SECOND HARMONIC	1.3	8-16
THIRD HARMONIC	0.6	12-24


FREQUENCY	PRESSURE (psi)	APPLIED FREQUENCY RANGE (Hz)
DOMINANT	2.85	4-8
SECOND HARMONIC	2.6	8-16
THIRD HARMONIC	1.2	12-24

## DOWNCOMER DIFFERENTIAL PRESSURE LOADS FOR DBA CONDENSATION OSCILLATION



FREQUENCY	PRESSURE (psi)	APPLIED FREQUENCY RANGE (Hz)
DOMINANT	1.1	6-10
SECOND HARMONIC	0.8	12-20
THIRD HARMONIC	0.2	18-30

## DOWNCOMER INTERNAL PRESSURE LOADS FOR IBA CONDENSATION OSCILLATION

DET-04-028-1 Revision 0



FREQUENCY	PRESSURE (psi)	APPLIED FREQUENCY RANGE (Hz)
DOMINANT	0.2	6-10
SECOND HARMONIC	0.2	12-20
THIRD HARMONIC	0.2	18-30

## DOWNCOMER DIFFERENTIAL PRESSURE LOADS FOR IBA CONDENSATION OSCILLATION

DET-04-028-1 Revisico 0



### CONDENSATION OSCILLATION LOADS

ON THE VENT SYSTEM

COMPONENTS		DBA	IBA
	AMPLITUDE	±2.5 psi	±2.5 psi
MAIN VENT	FREQUENCY RANGE	AT FREQUENCY OF MAXIMUM RESPONSE IN 4-8 Hz RANGE	AT FREQUENCY OF MAXIMUM RESPONSE IN 6-10 Hz RANGE
AND VENT HEADER	FORCING FUNCTION	SINUSOIDAL	SINUSOIDAL
	SPATIAL DISTRIBUTION	UNIFORM	UNIFORM
	AMPLITUDE	±5.5 psi	±2.1 psi
	FREQUENCY RANGE	AT FREQUENCY OF MAXIMUM RESPONSE IN 4-8 Hz RANGE	AT FREQUENCY OF MAXIMUM RESPONSE IN 6-10 Hz RANGE
DOWNCOMERS	FORCING FUNCTION	SINUSOIDAL	SINUSOIDAL
	SPATIAL DISTRIBUTION	UNIFORM	UNIFORM







 $\nabla$ 





SWING MOTION DUE TO AP

F<sub>XB</sub> F<sub>XB</sub> F<sub>XB</sub>

VERTICAL LOADING DUE TO P

Figure 1-4.1-12 DOWNCOMER DYNAMIC LOAD





NOTES:

 THE AMPLITUDES SHOWN ARE HALF-RANGE (ONE-HALF OF THE PEAK-TO-PEAK VALUE)

Figure 1-4.1-13

DOWNCOMER PAIR INTERNAL PRESSURE LOADING FOR DBA CO

DET-04-028-1 Revision 0

nutech



NOTES:

1. THE AMPLITUDES SHOWN ARE HALF RANGE (ONE-HALF OF THE PEAK-TO-PEAK VALUE).

Figure 1-4.1-14

DOWNCOMER PAIR DIFFERENTIAL PRESSURE LOADING FOR DBA CO





- D/C WITH INITIAL DIFFERENTIAL PRESSURE LOAD.
- ALL D/C'S HAVE INTERNAL PRESSURE LOAD IN PHASE WITH DIFFERENTIAL PRESSURE LOAD.
- ANALYZED ALL EIGHT CASES-USED MAXIMUM RESPONSE FOR DESIGN.

Figure 1-4.1-15

DOWNCOMER CO DYNAMIC LOAD APPLICATION

DET-04-028-1 Revision B

nutech



NOTES:

 THE AMPLITUDES SHOWN ARE HALF-RANGE (ONE-HALF OF THE PEAK-TO-PEAK VALUE).

Figure 1-4.1-16

DOWNCOMER INTERNAL PRESSURE LOADING FOR IBA CO

DET-04-028-1 Revision 0



1-4.1.7.3 CO Loads on Submerged Structures

The condensation oscillation phase of the postulated LOCA induces bulk pool motion, creating drag loads on structures submerged in the pool. The basis of the flow model used to determine condensation oscillation loads on submerged structures is presented in the LDR.

Condensation oscillations are described by fluid sources located at downcomer vent exits. The average source strengths are determined from wall load measurements. By using potential flow theory and the method of images to account for the effects of solid walls and the free surface, the velocity and acceleration flow fields within the torus are established. For each structure, the loads are computed using both the average source strength applied at all downcomers and the maximum source strength applied at the nearest downcomer.

The fluid-structure interaction (FSI) effects are included when the local fluid acceleration is less than twice the boundary acceleration. Pool fluid

DET-04-028-1 Revision 0 1-4.67

accelerations are computed within the torus using frequency decomposed radial shell accelerations obtained from the torus analysis described in Volume 2. The FSI effects for a given structure are computed using the pool fluid accelerations at the actual location of the structure.

Drag forces on submerged structures can be separated into two components, standard drag, and acceleration drag. The sum of these two effects gives the total drag load on a submerged structure. The calculations for condensation oscillation submerged structure loads use the same procedure as used for calculating LOCA bubble-induced drag loads on submerged structures. Acceleration drag volumes for some structures with sharp corners (e.g., I-beams) are calculated using equations from Table 1-4.1-1 instead of volumes derived by circumscribed cylinders, as noted in Section 1-4.1.5.

The source amplitudes used for condensation oscillation submerged structure loads are in accordance with NUREG-0661 and are presented in Table 1-4.1-11. The source forcing function has the form of a sinusoidal wave characterized by the appropriate amplitude and

DET-04-028-1 Revision 0



frequency taken from Table 1-4.1-11. The LDR defines the total drag force as the summation of the resulting responses from all 50 harmonics. As described in Section 1-4.1.7.1, the summation is performed to achieve a non-exceedance probability of 84%.



DET-04-028-1 Revision 0



AMPLITUDES AT VARIOUS FREQUENCIES FOR CONDENSATION OSCILLATION SOURCE FUNCTION FOR LOADS ON SUBMERGED STRUCTURES

FREQUENCY (Hz)	AMPLITUDE (ft <sup>3</sup> /sec <sup>2</sup> )	FREQUENCY (Hz)	AMPLITUDE (ft <sup>3</sup> /sec <sup>2</sup> )
0-1	28.38	26-27	56.75
1-2	24.46	27-28	12.72
2-3	31.31	28-29	18.59
3-4	46.97	29-30	13.70
4-5	182.00	30-31	7.83
5-6	267.13	31-34	2.94
6-7	96.87	34-35	4.89
7-10	57.73	35-36	7.83
10-11	77.30	36-37	9.79
11-12	44.03	37-38	6.85
12-13	16.63	38-39	5.87
13-14	11.74	39-40	8.81
14-15	6.85	40-41	32.29
15-16	9.79	41-42	32.29
16-19	3.91	42-43	32.29
19-20	26.42	43-44	32.29
20-21	19.57	44-45	32.29
21-22	29.36	45-46	32.29
22-23	33.27	46-47	32.29
23-24	32.29	47-48	32.29
24-25	15.66	48-49	32.29
25-26	24.46	49-50	32.29

DET-04-028-1 Revision 0



#### 1-4.1.8 Chugging Loads

This subsection describes the chugging loads on the various structures and components in the Fermi 2 suppression chamber.

Chugging occurs during a postulated LOCA when the steam flow through the vent system falls below the rate necessary to maintain steady condensation at the downcomer exits. The corresponding flow rates for chugging are less than those of the condensation oscillation phenomenon. During chugging, steam bubbles form at the downcomer exits, oscillate as they grow to a critical size (approximately downcomer diameter), and begin to collapse independently in time. The resulting load on the torus shell due to a chug cycle consists of a low frequency oscillation (pre-chug) which corresponds to the oscillating bubbles at the downcomer exit as they grow, followed by a higher frequency "ring-out" of the torus shellpool water system (post-chug) in response to the collapsing bubbles (Figure 1-4.1-17).

DET-04-028-1 Revision 0 1-4.71



TIME



DET-04-028-1 Revision 0



1-4.1.8.1 Chugging Loads on the Torus Shell

During the chugging regime of a postulated LOCA, the chugging loads on the torus shell occur as a series of chug cycles. The chugging load cycles are divided into pre-chug and post-chug portions. The bases for pre-chug and post-chug rigid wall load definitions are presented in the LDR.

For the pre-chug portion of the chug cycle, both symmetric and asymmetric loading conditions are used to conservatively account for any randomness in the chugging phenomenon. The asymmetric loading is based on both low and high amplitude chugging data conservatively distributed around the torus in order to maximize the asymmetric loading.

In order to bound the post-chug portion of the chug cycle, symmetric loads are used. Asymmetric loads are not specified since any azimuthal response would be governed by the asymmetric pre-chug low frequency load specification.

The chugging onset times and durations for the DBA, IBA, and SBA are in accordance with the LDR and are

DET-04-028-1 Revision 0 1-4.73

presented in Table 1-4.1-12. Fermi 2 utilizes turbine driven feedwater pumps and the IBA scenario for this configuration is described in Section 2.2 of the LDR. For the IBA, the ADS is assumed to be initiated 300 seconds after the break and the reactor is assumed to be depressurized 200 seconds after ADS initiation, at which time chugging ends. For the SBA, the reactor is assumed to be depressurized 600 seconds after ADS initiation, at which time chugging ends. These chugging durations are reflected in Table 1-4.1-12.

a. Pre-Chug Load

The symmetric pre-chug torus shell pressure load is specified as  $\pm 2$  psi applied uniformly along the torus longitudinal axis. The longitudinal distribution of the asymmetric pre-chug pressure load which varies from  $\pm 0.4$ to  $\pm 2.0$  psi, is shown in Figure 1-4.1-18. The pre-chug cross-sectional distribution for both symmetric and asymmetric cases is the same as for condensation oscillation as shown in Figure 1-4.1-19. The pre-chug loads are applied at the single frequency producing the maximum

DET-04-028-1 Revision 0



response in the range of 6.9 to 9.5 hertz. The pre-chug load of 0.5 second duration is applied at 1.4 second intervals for the appropriate total chugging duration shown in Table 1-4.1-12.

b. Post-Chug Load

The amplitude versus frequency variation for the post-chug torus shell pressure load is defined in Table 1-4.1-13 and Figure 1-4.1-20. The load is applied uniformly along torus longitudinal axis. the The cross-sectional variation is the same for the condensation oscillation and pre-chug loads as shown in Figure 1-4.1-19. The steady state responses from the application of the pressure amplitudes at each frequency given in Figure 1-4.1-20 are summed. The summation is performed as described in Section 1-4.1.7.1 for the condensation oscillation load. The postchug load of 0.5 second duration is applied at 1.4 second intervals for the appropriate total duration defined in Table 1-4.1-12.

nute

DET-04-028-1 Revision 0

BREAK SIZE	ONSET TIME AFTER BREAK	DURATION AFTER ONSET
DBA	35 SECONDS	30 SECONDS
IBA	305 SECONDS	200 SECONDS
SBA	300 SECONDS	900 SECONDS

## CHUGGING ONSET AND DURATION

FREQUENCY RANGE* (Hz)	PRESSURE (PSI)	FREQUENCY RANGE* (Hz)	PRESSURE (PSI)
0-1	0.04	25-26	0.04
1-2	0.04	26-27	0.28
2-3	0.05	27-28	0.18
3-4	0.05	28-29	0.12
4-5	0.06	29-30	0.09
5-6	0.05	30-31	0.03
6-7	0.1	31-32	0.02
7-8	0.1	32-33	0.02
8-9	0.1	33-34	0.02
9-10	0.1	34-35	0.02
10-11	0.06	35-36	0.03
11-12	0.05	36-37	0.05
12-13	0.03	37-38	0.03
13-14	0.03	38-39	0.04
14-15	0.02	39-40	0.04
15-16	0.02	40-41	0.15
16-17	0.01	41-42	0.15
17-18	0.01	42-43	0.15
18-19	0.01	43-44	0.15
19-20	0.04	44-45	0.15
20-21	0.03	45-46	0.15
21-22	0.05	46-47	0.15
22-23	0.05	47-48	0.15
23-24	0.05	48-49	0.15
24-25	0.04	49-50	0.15

POST-CHUG RIGID WALL PRESSURE AMPLITUDES ON TORUS SHELL BOTTOM DEAD CENTER

1월년, 24, 김 영양 유리 강경 승규가 이 사람이 같아.

\*HALF-RANGE (= 1/2 PEAK-TO-PEAK AMPLITUDE)





 $270^{\circ}$ 

PLAN VIEW OF TORUS



NOTES:

1. THE AMPLITUDE SHOWN HERE REPRESENTS ONE-HALF OF THE PEAK-TO-PEAK AMPLITUDE.

2. HIGHEST VALUE IN BAY APPLIED OVER THE ENTIRE BAY.

#### Figure 1-4.1-18

MARK I CHUGGING - TORUS ASYMMETRIC LONGITUDINAL DISTRIBUTION FOR PRESSURE AMPLITUDE

DET-04-028-1 Revision 0





#### NOTES:

- 1. A = LOCAL PRESSURES OSCILLATION AMPLITUDE
- 2. A MAX = MAXIMUM PRESSURE OSCILLATION AMPLITUDE (AT TORUS BOTTOM DEAD CENTER)

Figure 1-4.1-19

MARK I CHUGGING - TORUS VERTICAL CROSS-SECTIONAL DISTRIBUTION FOR PRESSURE AMPLITUDE

1-4.79



NOTE:

THE AMPLITUDE SHOWN HERE REPRESENTS ONE-HALF OF THE PEAK-TO-PEAK AMPLITUDE.

Figure 1-4.1-20

POST-CHUG RIGID WALL PRESSURE AMPLITUDES

ON TORUS SHELL BOTTOM DEAD CENTER

DET-04-028-1 Revision 0

During the chugging phase of a postulated LOCA, vapor bubbles which form at the downcomer exit collapse suddenly and intermittently to produce lateral loads on the downcomer. The procedure for defining the dynamic portion of this loading for a DBA, IBA, and SBA is presented in this section.

The basis for the chugging lateral load definition is the data obtained from the instrumented downcomers of the Mark I Full-Scale Test Facility. The load definition was developed for, and is directly applicable to, downcomer pairs which are untied. Based on FSTF observations, this load definition is also applicable to tied downcomers.

The FSTF downcomer lateral loads are defined as Resultant-Static-Equivalent Loads (RSEL) which when applied statically to the end of the downcomer, reproduce the measured bending response near the downcomer/vent header (DC/VH) junction at any given time.

•

DET-04-028-1 Revision 0



The loads associated with chugging obtained from the FSTF data are scaled to determine plant-specific loads for Fermi 2. The maximum downcomer design load, histograms of load reversals, and the maximum vent system loading produced by synchronous chugging of the downcomers are determined from the FSTF loads.

NUREG-0661 states that for multiple downcomer chugging the force per downcomer should be based on a probability of exceedance of 10<sup>-4</sup> per LOCA. This requirement relates to the potential for a number of downcomers experiencing a lateral load in the same direction at the same time. Correlation between load magnitude and probability level was derived from a statistical analysis of FSTF data. A probability of exceedance of 10<sup>-4</sup> per LOCA bounds all the load cases up to about 120 downcomers chugging at the same time in a given plant. Thus for the cases when fewer downcomers are chugging (Fermi 2 has only 80 downcomers),  $10^{-4}$  is a very conservative probability level. More realistic probability levels are calculated for Fermi 2 by correlating the FSTF chugging duration and number of downcomers to the Fermi 2 chugging duration and the number of downcomers. The force per downcomer calculated in

DET-04-028-1 Revision 0



this manner for Fermi 2 results in a probability that the force will be exceeded once per LOCA as a function of the number of downcomers chugging. The resulting exceedance probabilities for various cases of multiple downcomers chugging are presented in Table 1-4.1-14.

For fatigue evaluation of the downcomers, the required stress reversals at the downcomer/vent header junction are obtained from the FSTF, RSEL reversal histograms. The plant unique junction stress reversals are obtained by scaling the FSTF, RSEL reversals by the ratio of the chugging duration specified for Fermi 2 to that of the FSTF. Chugging durations for the DBA, IBA, and SBA are specified in Table 1-4.1-12.



DET-04-028-1 Revision 0



PROBABILITY OF EXCEEDANCE FOR MULTIPLE

DOWNCOMERS CHUGGING

NUMBER OF DOWNCOMERS	PROBABILITY OF EXCEEDANCE
5	2.91 x 10 <sup>-3</sup>
10	$1.45 \times 10^{-3}$
20	7.27 x 10 <sup>-4</sup>
40	3.64 x 10-4
80	$1.82 \times 10^{-4}$



1-4.1.8.3 Chugging Loads on Submerged Structures

Chugging at the downcomer exits induces bulk water motion and therefore creates drag loads on structures submerged in the pool. The submerged structure load definition method for chugging follows that used to predict drag forces caused by condensation oscillations (see Section 1-4.1.7.3), except that the source strength for chugging is proportional to the wall load measurement corresponding to the chugging regime.

The bases and assumptions of the flow model for the chugging load definition are presented in the LDR. The source amplitudes for pre-chug and post-chug regimes are presented in Table 1-4.1-15.

The load development procedure for chugging loads on submerged structures is the same as presented in Section 1-4.1.7.3 for condensation oscillation and is in accordance with NUREG-0661. The responses from the 50 harmonics are summed as described in Section 1-4.1.7.1. Acceleration drag volumes for structures with sharp corners (e.g., I-beams) are calculated

DET-04-028-1 Revision 0

1-4.85

using equations from Table 1-4.1-1. Fluid-structure interaction effects are included as described in Section 1-4.1.7.3.

DET-04-028-1 Revision 0



## AMPLITUDES AT VARIOUS FREQUENCIES FOR

## CHUGGING SOURCE FUNCTION

FOR LOADS ON SUBMERGED STRUCTURES

CHUGGING	FREQUENCY (Hz)	AMPLITUDE (ft <sup>3</sup> /sec <sup>2</sup> )
PRE	6.9 - 9.5	195.70
	0-2	11.98
	2-3	10.36
	3-4	9.87
	4-5	17.40
	5-6	17.00
	6-10	18.88
	10-11	87.90
	11-12	76.18
	12-13	41.01
PUSI	13-14	35.89
	14-15	6.82
	15-16	6.20
	16-17	3.14
	17-18	4.18
	18-19	2.94
	19-20	16.82
	20-21	17.53
1.5	21-22	30.67







AMPLITUDES AT VARIOUS FREQUENCIES FOR CHUGGING SOURCE FUNCTION FOR LOADS ON SUBMERGED STRUCTURES

(Concluded)

CHUGGING	FREQUENCY (Hz)	AMPLITUDE (ft <sup>3</sup> /sec <sup>2</sup> )
	22-24	92.39
	24-25	134.50
	25-26	313.84
동네감정	26-27	377.83
	27-28	251.89
왕으로	28-29	163.32
	29-30	116.66
	30-31	43.14
POST	31-32	21.57
F051	32-33	37.91
1	33-34	50.54
	34-35	42.54
	35-36	61.87
	36-37	41.95
	37-38	20.97
	38-39	24.47
	39-40	29.37
	40-50	224.90

DET-04-028-1 Revision 0

#### 1-4.2 Safety Relief Valve Discharge Loads

This section discusses the procedures used to determine loads created when one or more SRV's is actuated.

When an SRV actuates, pressure and thrust loads are exerted on the SRVDL piping and the T-quencher discharge device. In addition, the expulsion of water followed by air into the suppression pool through the T-quencher results in pressure loads on the submerged portion of the torus shell and drag loads on submerged structures.

The T-quencher utilized in the Fermi 2 plant is a plant unique version of the Mark I T-quencher described in the LDR. The Fermi 2 T-quencher has 20" diameter arms which are mitered at the connection to the ramshead portion. This is accomplished to provide symmetrical torus shell loads upon SRV actuation, since the T-quenchers are installed on the torus ring girders at the miter joints. Figure 1-4.2-1 illustrates this mitering concept and connection to the SRVDL.

DET-04-028-1 Revision 0



To minimize torus shell pressure loads and to ensure adequate steam condensation performance, the Fermi 2 T-quencher utilizes the same hole diameter and minimum spacing as the Mark I T-quencher. The hole pattern distribution along the arms was modified to accommodate Fermi 2 unique supports without sacrifice to the extended water clearing duration concept of the quencher. The details of the hole distribution along the arm are illustrated in Figures 1-4.2-2 and 1-4.2-3.

Analytical predictions of torus shell pressures for Fermi 2 T-quencher discharges indicate improved performance over the standard Mark I T-quencher. The torus shell loads are predicted utilizing the Fermi 2 T-quencher geometry and the hydrodynamic modeling techniques and analytical models used in the development of the Mark I T-quencher as contained in the Mark I LDR.

As allowed in Section 2.13.9 of Appendix A of NUREG-0661, plant unique SRV testing at Fermi 2 will be performed to confirm that the computed loadings and predicted structural responses for SRV discharges are conservative.

DET-04-028-1 Revision 0



VIEW A-A

Figure 1-4.2-1

T-QUENCHER AND SRV LINE

DET-04-028-1 Revision 0





Figure 1-4.2-2

T-QUENCHER ARM HOLE PATTERN - ELEVATION VIEW

nutech

DET-04-028-1 Revision 0







T-QUENCHER HOLE PATTERN - SECTION VIEWS
This section provides a discussion on the selection of SRV discharge cases which are considered for design load evaluations. The load cases summarized in Table 1-4.2-1 are described as follows:

Load Case Al.l (Normal Operating Condition (NOC), First Actuation)

> A first actuation of an SRV may occur under normal operating conditions. That is the SRVDL is cold, there is air in the drywell, and the water in the SRV is at its normal operating level.

Load Case A1.2 (SBA/IBA, First Actuation)

First actuation of SRV(s) is assumed to occur at the predicted time of ADS actuation. At this time the SRVDL is full of air at the pressure corresponding to the drywell pressure minus the vacuum breaker set point. The water level inside the line is depressed below the normal operating level because the drywell

DET-04-028-1 Revision 0



pressure is higher than the wetwell pressure by a pressure differential equal to the downcomer submergence.

Load Case A1.3 (DBA, First Actuation)

The same assumptions are used as for Case Al.1, except for SRV flowrate. This load case is bounded by Case Al.1.

Load Case B (First Actuation, Leaking SRV)

SRV first actuation may occur under NOC for leaking SRV's. For T-quenchers, Load Case Al.1 bounds the leaking SRV load.

Load Case C3.1 (NOC, Subsequent Actuation, Normal Water Leg)

After the SRV is closed, following a first actuation (Case Al.1), the steam in the line is condensed causing a rapid pressure drop which draws water back into the line. At the same time, the vacuum breaker allows air from the drywell to enter the discharge line. The air

DET-04-028-1 Revision 0 1-4.95

repressurizes the line and the water refloods to a point which is higher than its equilibrium height, and oscillates back to its equilibrium point. A subsequent actuation is assumed to occur after the water level oscillations have damped out and the water leg returns to the normal level.

Load Case C3.2 (SBA/IBA, Subsequent Actuation)

Following SRV closure after the SBA/IBA first actuation (Case Al.2), the water will reflood back into the line while air from the drywell flows through the vacuum breaker into the SRVDL. The SRV is assumed to actuate after the water level oscillations damped out and the level stabilized at a point determined by the drywell-to-wetwell ΔP minus the vacuum breaker set point.

Load Case C3.3 (SBA/IBA, Subsequent Actuation, Steam in SRVDL)

This case differs from the previous case in that during the reflood transient, steam,

DET-04-028-1 Revision 0



instead of air, flows through the vacuum breaker. Thus, the line contains very little air and the loading imposed on the torus shell from this subsequent SRV actuation is bounded by Case C3.2.

The SRVDL water leg is assumed at its equilibrium height for all subsequent actuation SRV cases. The time after first valve actuation closure at which the equilibrium height is re-established is calculated using the LDR SRV discharge line reflood model. Fermi 2 primary system transient analyses are used to confirm that more than the minimum required time is available for the SRVDL water leg to return to the equilibrium position. For the steam-in-the-drywell conditions, a steam-water convective heat transfer coefficient of  $2 \times 10^5$  BTU/hr-ft<sup>2</sup>-°R is used. This conservative coefficient is based on the results of a literature survey on chugging and the downcomer water column rise characteristics during chugging in the Mark I Full-Scale Test Facility.

The number of SRV's predicted to actuate for each of the above conditions is maximized in performing the Fermi 2 structural evaluations documented in the

DET-04-028-1 Revision 0



remaining PUAR volumes. Section 1-4.3 indicates the other hydrodynamic loads which must be combined with SRV loads.

DET-04-028-1 Revision 0



### Table 1-4.2-1

	T	1	1
DESIGN INITIAL CONDITION, LOAD CASE	ANY ONE VALVE	ADS VALVES	MULTIPLE VALVES(1)
NOC, FIRST ACTUATION	A1.1		A3.2
SBA/IBA, FIRST ACTUATION	A1.2	A2.2	A3.2
DBA, FIRST ACTUATION <sup>(2)</sup>	A1.3		
NOC, LEAKING SRV <sup>(3)</sup>			B3.1 <sup>(4)</sup>
NOC, SUBSEQUENT ACTUATION			C3.1
SBA/IBA, SUBSEQUENT ACTUATION, AIR IN SRVDL			C3.2
SBA/IBA, SUBSEQUENT ACTUATION, STEAM IN SRVDL			C3.3

### SRV LOAD CASE/INITIAL CONDITIONS

- (1) THE NUMBER (ONE OR MORE) AND LOCATION OF VALVES ASSUMED TO ACTUATE ARE DETERMINED BY PLANT UNIQUE ANALYSIS.
- (2) THIS ACTUATION IS ASSUMED TO OCCUR COINCIDENT WITH THE POOL SWELL EVENT. ALTHOUGH SRV ACTUATION CAN OCCUR LATER IN THE DBA, THE RESULTING AIR LOADING ON THE TORUS SHELL IS NEGLI-GIBLE SINCE THE AIR AND WATER INITIALLY IN THE LINE WILL BE CLEARED AS THE DRYWELL TO WETWELL ΔP INCREASES DURING THE DBA TRANSIENT.
- (3) THIS IS APPLICABLE TO RAMSHEAD DISCHARGE ONLY.
- (4) ONLY ONE VALVE OF THE MULTIPLE GROUP IS ASSUMED TO LEAK.

#### LEGEND:

- ADS AUTOMATIC DEPRESSURIZATION SYSTEM
- NOC NORMAL OPERATING CONDITIONS
- SBA SMALL BREAK ACCIDENT
- IBA INTERMEDIATE BREAK ACCIDENT
- DBA DESIGN BASIS ACCIDENT



## 1-4.2.2 SRV Discharge Line Clearing Loads

The flow of high pressure steam into the discharge line when an SRV opens results in the development of a pressure wave at the entrance to the line. During the early portion of this transient, a substantial pressure differential exists across the pressure wave. This pressure differential, plus momentum effects from steam (or water in initially submerged pipe runs) flowing around elbows in the line, results in transient thrust loads on the SRV discharge pipe segments. These loads are considered in the design of SRV pipe restraints, the SRV penetrations in the vent lines and the T-quencher support system.

The bases, assumptions, and descriptions of the SRV discharge line clearing analytical model are presented in the LDR. The parameters affecting SRVDL clearing load development are the SRVDL geometry, plant specific initial conditions for the SRV actuation cases, and the SRV mass flow rate. Plant specific initial conditions for various actuation cases are presented in Table 1-4.2-2. Common SRVDL analysis input parameters (but case-independent) are presented in Table 1-4.2-3. All input calculation

DET-04-028-1 Revision 0



procedures for the SRVDL clearing model are consistent with the LDR.

The line clearing model is used to obtain transient values for the following parameters or loads for each SRV actuation case for each SRVDL:

- SRVDL Pressures and Temperatures
- Thrust Loads on SRVDL Pipe Segments
- T-quencher Internal Discharge Pressure and Temperature
- Water Slug Mass Flow Rate
  - Water Clearing Time, Velocity and Acceleration

The values obtained for T-quencher discharge pressure and water clearing time are used as input to evaluate the torus shell loads (Section 1-4.2.3) and SRV air bubble drag loads (Section 1-4.2.4) on submerged structures. The water slug mass flowrate and acceleration are used as input to calculations of SRV water jet loads on submerged structures (see Section 1-4.2.4).

The water clearing thrust load along the axis of the T-quencher, perpendicular to the T-quencher arms (due

DET-04-028-1 Revision 0



to a skewed air/water interface), and at the T-quencher arm/ramshead miter are calculated as specified in the LDR.

The SRV water and air clearing thrust and all other SRV water clearing loads calculation procedures, load definitions, and applications are in accordance with the LDR and Appendix A of NUREG-0661.



## Table 1-4.2-2

# PLANT UNIQUE INITIAL

# CONDITIONS FOR ACTUATION CASES

# USED FOR SRVDL CLEARING TRANSIENT LOAD DEVELOPMENT

PARAMETER	CASE Al.1	CASE Al.2	CASE C3.1	CASE C3.2
PRESSURE IN THE WETWELL (psia)	14.2	34.5	14.2	34.5
PRESSURE IN THE DRYWELL (psia)	14.2	35.9	14.2	35.9
△P VACUUM BREAKER (psig)	0.2	0.2	0.2	0.2
INITIAL PIPE WALL TEMPERATURE IN THE WETWELL AIRSPACE (°F)	115	340	350	350
INITIAL PIPE WALL TEMPERATURE IN THE SUPPRESSION POOL (°F)	95	112	95	112
PRESSURE IN THE POOL (psia)	14.0	35.7	14.0	35.7
INITIAL AIR PRESSURE IN SRVDL (psia)	14.0	35.7	14.0	35.7
INITIAL AIR DENSITY IN SRVDL (1bm/ft <sup>3</sup> )	0.0657	0.1205	0.0467	0.1
INITIAL WATER VOLUME IN SRVDL AND T-QUENCHER (ft <sup>3</sup> )	36.474	34.196	36.474	34.196





## Table 1-4.2-3

# SRVDL ANALYSIS PARAMETERS

PARAMETER	VALUE
DESIGN SRV FLOW RATE (1bm/sec)	298.89
STEAM LINE PRESSURE (psia)	1194.0
STEAM DENSITY IN THE STEAM LINE (lbm/ft <sup>3</sup> )	2.743
RATIO OF AREAS OF DISCHARGE DEVICE EXIT TO TOTAL T-QUENCHER ARM	0.3481



1-4.2.3 SRV Loads on the Torus Shell

Following SRV actuation, the air mass in the SRVDL is expelled into the suppression pool, forming many small air bubbles. These bubbles then coalesce into four larger bubbles which expand and contract as they rise and break through the pool surface. The positive and negative dynamic pressures developed within these bubbles result in an oscillatory, attenuated pressure loading on the torus shell.

The analytical model which is used to predict air bubble and torus shell boundary pressures resulting from SRV discharge is similar to that describéd in Reference 13. The analytical model in Reference 13 was modified slightly to more closely bound the magnitudes and time characteristics of pressures observed in the Monticello test. Figure 1-4.2-4 shows a comparison of the shell pressure time-history measured during the Monticello test to the shell pressure time-history computed using the revised analytical model. The comparison is shown for shell pressures at the bottom of the torus beneath the quencher, where the highest shell pressures were

DET-04-028-1 Revision 0



observed. As can be seen from Figure 1-4.2-4, the predicted shell pressures envelop those observed in the Monticello test.

The pressure time-history generated using the analytical model discussed above is used to perform a forced vibration analysis of the suppression chamber. The phenomena associated with SRV discharge into the suppression pool are characteristic of an initial value or free vibration condition rather than a forced vibration condition. Correction factors are applied to convert the forced vibration response to a free vibration response.

The correction factors are developed using simple one degree-of-freedom analogs. The factors vary with the ratio of load frequency to structural frequency and are applied to the response (displacement, velocity, and acceleration) associated with each structural mode. Figure 1-4.2-5 shows the modal correction factors which are used in the suppression chamber evaluation.

The pressure magnitudes produced by the analytical model discussed previously were calibrated to envelop

DET-04-028-1 Revision 0



the maximum local shell pressures observed in the Monticello test. This results in an overly conservative prediction of net vertical loads, as discussed in Section 3.10.2.9 of NUREG-0661. Net vertical load correction factors were developed by comparing net vertical pressure loads measured in the Monticello test with those predicted at test conditions. The factors were determined to be 0.70 for upward loads and 0.78 for downward loads. An enveloping correction factor of 0.8 is used in the analysis for both upward and downward loads. This correction factor is applied only to forces acting on the torus supports.

Table 1-4.2-4 shows a comparison of shell membrane stresses and column forces observed in the Monticello test with those values predicted using the analytical methods and correction factors described above. As can be seen from the table, predicted forces and stresses conservatively bound the measured values at all locations. A series of in-plant tests will be performed at Fermi 2 after fuel load to provide additional confirmation that the computed loadings and predicted structural response due to SRV discharge are conservative.

DET-04-028-1 Revision 0



# Table 1-4.2-4

COMPARISON OF ANALYSIS AND MONTICELLO TEST RESULTS

QUANTITY	LOCATION	ANALYSIS	TEST	ANALYSIS TEST
	MIDBAY 90° FROM BDC REACTOR SIDE	2.8	0.6	4.7
	MIDBAY 52.5° FROM BDC REACTOR SIDE	2.3	1.1	2.1
SUPPRESSION CHAMBER SHELL	MIDBAY 12.4 <sup>0</sup> FROM BDC REACTOR SIDE	2.2	1.7	1.3
MEMBRANE STRESSES	MIDBAY 12.4 <sup>0</sup> FROM BDC OPPOSITE REACTOR	2.1	1.4	1.5
	MIDBAY 52.5 <sup>0</sup> FROM BDC OPPOSITE REACTOR	2.5	1.1	2.3
	1/4 BAY 12.4° FROM BDC OPPOSITE REACTOR	2.2	1.4	1.6
TORUS COLUMN	INSIDE COLUMN	123.9	49.0	2.5
LOADS	OUTSIDE COLUMN	157.8	52.5	3.0
TORUS COLUMN DOWN LOADS	INSIDE COLUMN	152.9	64.5	2.4
	OUTSIDE COLUMN	178.2	78.5	2.3

DET-04-028-1 Revision 0









COMPARISON OF PREDICTED AND MEASURED SHELL PRESSURE TIME-HISTORIES FOR MONTICELLO TEST 801

1-4.109





MODAL CORRECTION FACTORS FOR ANALYSIS OF SRV DISCHARGE TORUS SHELL LOADS

DET-04-028-1 Revision 0

1-4.110

### 1-4.2.4 SRV Loads on Submerged Structures

This section addresses the load definition procedures for determining SRV loads on submerged structures due to T-quencher water jets and bubbles.

When an SRV is actuated, water initially contained in the submerged portion of the SRVDL is forced out of the T-quencher through holes in the arms forming orifice jets. Some distance downstream, the orifice jets merge to form column jets. Further downstream, the column jets merge to form the quencher arm jets. As soon as the water flow through the arm hole ceases, the quencher arm jet velocity decreases rapidly and the jet penetrates a limited distance into the pool. The T-quencher water jets create drag loads on nearby submerged structures which are within the jet path.

Oscillating bubbles resulting from a SRV actuation create an unsteady three-dimensional flow field and therefore induce acceleration and standard drag forces on the submerged structures in the suppression pool.

DET-04-028-1 Revision 0



### a. T-quencher Water Jet Loads

The T-quencher water jet model conservatively models the T-quencher water jet test data. The bases, justification, and assumptions for the Mark I T-quencher model are presented in Reference 1. The Fermi 2 T-quencher is similar to the Mark I T-quencher in that both have the same hole diameter, approximately the same arm lengths, and number of holes. Due to some geometric differences, a Fermi 2 T-quencher water jet model was developed. The techniques utilized in the Fermi 2 model development are the same as those used for the Mark I T-quencher model, except the Fermi 2 T-quencher geometric characteristics are used (Figure 1-4.2-6).

The SRV T-quencher water jet analytical model calculation procedure and application are in accordance with Mark I LDR techniques.

DET-04-028-1 Revision 0



b. SRV Bubble-Induced Drag Loads

The SRV bubble drag load development methodology, load definition, and application for the Fermi 2 plant unique analysis are performed utilizing the Fermi 2 T-quencher geometry (Figure 1-4.2-1) which is somewhat different from the Mark I T-quencher The techniques utilized in geometry. developing the Fermi 2 loads are the same as those used for the Mark I T-quencher, except the Fermi 2 T-quencher geometric characteristics are used. Dynamic load factors are derived from Monticello in-plant SRV test data.

A bubble pressure bounding factor based on Monticello test data is utilized for Fermi 2 SRV load development in place of the LDR value of 2.5. A value of 1.75 produces results which bound the peak positive bubble pressure and maximum bubble pressure differential from the Monticello T-quencher test data (9.9 psid and 18.1 psid, respectively).

DET-04-028-1 Revision 0



For submerged structures with sharp corners such as T-beams, I-beams, etc., the acceleration drag volumes are calculated using the methodology in Section 1-4.1.5.

The model described in Section 1-4.2.3 is used to determine drag loads on downcomers due to SRV bubble oscillation.





PLAN VIEW OF FERMI 2 T-QUENCHER ARM JET SECTIONS

1-4.115

## 1-4.3 Event Sequence

Not all of the suppression pool hydrodynamic loads discussed in this evaluation can occur at the same time. In addition, the load magnitudes and timing vary, depending on the accident scenario being considered. Therefore, it is necessary to construct a series of event combinations to describe the circumstances under which individual loads might combine.

The event combinations used in the plant unique analysis are shown in Tables 1-3.2-1 and 1-3.2-2. The combinations of load cases were determined from typical plant primary system and containment response analyses, with considerations for automatic actuation, manual actuation, and single active failures of the various systems in each event. This section describes the event sequences for the following postulated LOCA's.

- Design Basis Accident
- Intermediate Break Accident
  - Small Break Accident

DET-04-028-1 Revision 0

nute

Table 1-4.3-1 identifies the SRV and LOCA loads which potentially affect structural components and identifies the appropriate section of this report defining the loads. For SRV piping and other structures within the wetwell, the locations of the structural components are considered to determine if any of the identified conditions affect the structures.





# Table 1-4.3-1

Den.

# SRV AND LOCA STRUCTURAL LOADS

	STRUCTURES					OTHER WETWELL INTERIOR STRUCTURES			
LOADS	TORUS SHELL	TORUS SUPPORT SYSTEM	MAIN VENTS	VENT HEADER	DOWNCOMERS	SRV PIPING	ABOVE NORM WATER LEVEL	ABOVE BOTTOM OF DOWNCOMERS AND BELOW NORM WATER LEVEL	BELOW BOTTOM OF DOWNCOMERS
1-4.1.1 CONTAINMENT PRESSURE AND TEMPERATURE RESPONSE	x	x	x	x	x	x	x	x	x
1-4.1.2 VENT SYSTEM DISCHARGE LOADS			x	x	x				
1-4.2.3 POOL SWELL LOADS ON THE TORUS SHELL	x	x					-		
1-4.1.4 POOL SWELL LOADS ON ELEVATED STRUCTURES	+				-				
1-4.1.4.1 IMPACT AND DRAG LOADS ON THE VENT SYSTEM			x	x	x				
1-4.1.4.2 IMPACT AND DRAG LOADS ON OTHER STRUCTURES			x			x	x		
1-4.1.4.3 POOL SWELL FROTH IMPINGEMENT LOADS			х				x		
1-4.1.4.4 POOL FALLBACK LOADS						x	x	x	1.1
1-4.1.5 LOCA WATERJET LOADS ON SUBMERGED STRUCTURES						x			x
1-4.1.6 LOCA BUBBLE-INDUCED LOADS ON SUBMERGED STRUCTURES						x			x
1-4.1.7 CONDENSATION OSCILLATION LOADS 1-4.1.7.1 CO LOADS ON THE TORUS SHELL	x	x							
1-4.1.7.2 CO LOADS ON THE DOWNCOMERS AND VENT SYSTEM 1-4.1.7.3 CO LOADS ON SUBMERGED			x	x	x				
STRUCTURES						x		x	x
1-4.1.8 CHUGGING LOADS 1-4.1.8.1 CHUGGING LOADS ON THE TORUS SHELL	x	x							
1-4.1.8.2 CHUGGING DOWNCOMER LATERAL LOADS				x	x				
1-4.1.8.3 CHUGGING LOADS ON SUBMERGED STRUCTURES						x		x	x
1-4.2 SAFETY PELIEF VALVE DISCHARGE LOADS									
1-4.2.2 SRV DISCHARGE LINE CLEARING LOADS						X			
1-4.2.3 SRV LOADS ON THE TORUS SHELL 1-4.2.4 SRV LOADS ON SUBMERGED STRUCTURES	X	x			x	x		x	x

DET-04-028-1 Revision 0

1-4.118



0

The DBA for the Mark I containment design is the instantaneous guillotine rupture of the largest pipe in the primary system (the recirculation line). The load combinations for the DBA are presented in Figures 1-4.3-1 through 1-4.3-3. The nomenclature for these figures is presented in Table 1-4.3-2. The bar charts for the DBA show the loading condition combination for postulated breaks large enough to produce significant pool swell. The length of the bars in the figures indicates the time periods during which the loading conditions may occur. Loads are considered to act simultaneously on a structure at a specific time if the loading condition bars overlap at that time. For SRV discharge, the loads may occur at any time during the indicated time period. The assumption of combining a SRV discharge with the DBA is beyond the design basis of the Fermi 2 plant. Therefore, the DBA and SRV load combination is evaluated only to demonstrate containment structural capability. Table 1-4.3-3 shows the SRV discharge loading conditions.

DET-04-028-1 Revision 0 1-4.119

# Table 1-4.3-2

## EVENT TIMING NOMENCLATURE

TIME	DESCRIPTION
t <sub>1</sub>	THE ONSET OF CONDENSATION OSCILLATION
t2	THE BEGINNING OF CHUGGING
t <sub>3</sub>	THE END OF CHUGGING
t <sub>4</sub>	TIME OF COMPLETE REACTOR DEPRESSURIZATION
t <sub>ADS</sub>	ADS ACTUATION ON HIGH DRYWELL PRESSURE AND LOW REACTOR WATER LEVEL. THE ADS WAS ASSUMED TO BE ACTUATED BY THE OPERATOR FOR THE SBA.



## Table 1-4.3-3

# SRV DISCHARGE LOAD CASES FOR MARK I STRUCTURAL ANALYSIS

INITIAL CONDITIONS	ANY ONE VALVE	ADS VALVES	MULTIPLE VALVES (1)
FIRST ACTUATION	A 1	A 2	A 3
FIRST ACTUATION, LEAKING SRV(2)			В 3
SUBSEQUENT ACTUATION			C 3

NOTES:

- (1) THE NUMBER (ONE OR MORE) AND LOCATION OF SRV'S ASSUMED TO ACTUATE ARE DELEMINED BY PLANT UNIQUE ANALYSES.
- (2) THE LOADS FOR T-QUENCHER DISCHARGE DEVICES ARE NOT AFFECTED BY LEAKING SRV'S. NO SRV'S ARE CONSIDERED TO LEAK PRIOR TO A LOCA.







TIME AFTER LOCA (sec)

NOTE:

(1) THIS ACTUATION IS ASSUMED TO OCCUR COINCIDENT WITH THE POOL SWELL EVENT. ALTHOUGH SRV ACTUATION CAN OCCUR LATER IN THE DBA, THE RESULTING AIR LOADING ON THE TORUS SHELL IS NEGLIGIBLE SINCE THE AIR AND WATER INITIALLY IN THE LINE WILL BE CLEARED AS THE DRYWELL TO WETWELL △P INCREASES DURING THE DBA TRANSIENT.

### Figure 1-4.3-1

LOADING CONDITION COMBINATIONS FOR THE VENT HEADER, MAIN VENTS, DOWNCOMERS AND TORUS SHELL DURING A DBA

DET-04-028-1 Revision 0





NOTE:

(1) THIS ACTUATION IS ASSUMED TO OCCUR COINCIDENT WITH THE POOL SWELL EVENT. ALTHOUGH SRV ACTUATION CAN OCCUR LATER IN THE DBA, THE RESULTING AIR LOADING ON THE TORUS SHELL IS NEGLIGIBLE SINCE THE AIR AND WATER INITIALLY IN THE LINE WILL BE CLEARED AS THE DRYWELL TO WETWELL AP INCREASES DURING THE DBA TRANSIENT.

### Figure 1-4.3-2

LOADING CONDITION COMBINATIONS FOR SUBMERGED

STRUCTURES DURING A DBA

DET-04-028-1 Revision 0



Figure 1-4.3-3

LOADING CONDITION COMBINATIONS FOR SMALL STRUCTURES ABOVE SUPPRESSION POOL DURING A DBA

1-4.124

## 1-4.3.2 Intermediate Break Accident

The bar chart in Figure 1-4.3-4 shows conditions for a break size large enough such that the HPCI system cannot prevent ADS actuation on low-water level, but for break sizes smaller than that which would produce significant pool swell loads. A break size of 0.1 ft<sup>2</sup> is assumed for an IBA. Table 1-4.3-3 shows SRV discharge loading conditions. The IBA break is too small to cause significant pool swell.





NOTE:

(1) LOADING NOT COMBINED WITH OTHER SRV CASES.



LOADING CONDITION COMBINATIONS FOR THE VENT HEADER, MAIN VENTS, DOWNCOMERS, TORUS SHELL AND SUBMERGED STRUCTURES DURING AN IBA

DET-04-028-1 Revision 0

1-4.126

The bar chart (Figure 1-4.3-5) for the SBA shows conditions for a break size equal to 0.01 ft<sup>2</sup>. For a SBA, the HPCI system would be able to maintain the water level and the reactor would be depressurized by means of operator initiation of the ADS. Table 1-4.3-3 identifies the SRV discharge loading conditions. The SBA break is too small to cause significant pool swell and condensation oscillation does not occur during an SBA. The ADS is assumed to be initiated by the operator 10 minutes after the SBA begins. With the concurrence of the NRC (Reference 14), the procedures which the operator will use to perform this action are being developed as part of the Emergency Procedures Guidelines.



DET-04-028-1 Revision 0 1-4.127





LOADING CONDITION COMBINATIONS FOR VENT HEADER, MAIN VENTS, DOWNCOMERS, TORUS SHELL AND SUBMERGED STRUCTURES DURING AN SBA

DET-04-028-1 Revision 0

1-4.128

## 1-5.0 SUPPRESSION POOL TEMPERATURE MONITORING SYSTEM

This section describes the Fermi 2 suppression pool temperature response to SRV transients and the design of the Suppression Pool Temperature Monitoring System (SPTMS).




## 1-5.1 <u>Suppression Pool Temperature Response to SRV</u> <u>Transients</u>

The Enrico Fermi Atomic Power Plant Unit 2 takes advantage of the large thermal capacitance of the suppression pool during plant transients requiring safety relief valve actuation. Steam is discharged through the SRV's into the suppression pool where it is condensed, resulting in an increase in the temperature of the suppression pool water. Although stable steam condensation is expected at all pool temperatures, Reference 15 imposes a local temperature limit shown in Figure 1-5.1-1 in the vicinity of the Fermi 2 T-quencher discharge devices.

To demonstrate that the local pool temperature limit shown in Figure 1-5.1-1 is satisfied, seven limiting transients involving SRV discharges are analyzed. A summary of the transients analyzed and the corresponding pool temperature results are presented in Table 1-5.1-1. Three of the transients conservatively assume the failure of one Residual Heat Removal (RHR) loop in addition to the single equipment malfunction or operator error which

DET-04-028-1 Revision 0 1-5.2



initiated the event. This conservative assumption exceeds the current licensing basis for anticipated operational transients.

Each of the SRV discharge transients are analyzed assuming an initial pool temperature of 95°F, which is the Technical Specification pool temperature limit for normal power operation. Other initial conditions and assumptions included in these analyses are listed in the Notes to Table 1-5.1-1.

The analysis of Case 2C, normal depressurization at isolated hot shutdown, shows a maximum local pool temperature of 184°F. This demonstrates that with no system failures and in the event of a non-mechanistic scram, depressurizing the reactor pressure vessel (RPV) with SRV's at 100°F/hr results in local pool temperatures that are well below the condensation stability limit of Figure 1-5.1-1.

Case 3A, a small-break accident with one RHR loop available, results in a maximum local pool temperature of 202°F, which is below the condensation stability limit of 204.8°F. High local temperatures are predicted in this case because of reduced mixing

DET-04-028-1 Revision 0

1-5.3

when the available RHR pool cooling system is switched to the shutdown cooling mode.

The maximum local pool temperature of all other cases also remains below the condensation stability limit throughout the transient. In general, local-to-bulk temperature differences at the time of maximum temperatures are about 15°F for cases where two RHR loops are assumed available and about 30°F for cases where one RHR loop is assumed available. Thus, bulk pool circulation induced by the RHR loops leads to good thermal mixing, which effectively lowers the local pool temperatures in the vicinity of quencher devices.

DET-04-028-1 Revision 0

nute

## Table 1-5.1-1

## SUMMARY OF FERMI 2 POOL TEMPERATURE RESPONSE TO SRV TRANSIENTS

CASE NUMBER	EVENT	NUMBER OF SRV'S MANUALLY OPENED	MAXIMUM COOLDOWN RATE ( <sup>O</sup> F/hr)	MAXIMUM BULK POOL TEMPERATURE (°F)	MAXIMUM LOCAL POOL TEMPERATURE ( <sup>O</sup> F)
18	SORV <sup>(1)</sup> AT POWER, 1 RHR LOOP	1	1323(2)	154	187
18	SORV AT POWER, SPURIOUS ISOLATION, 2 RHR LOOPS	1	938	172	196
2A	RAPID DEPRESSURIZATION AT ISOLATED HOT SHUTDOWN, 1 RHR LOOP	5	1000	165	200
2В	SORV AT ISOLATED HOT SHUTDOWN, 2 RHR LOOPS	1	968	162	186
2C	NORMAL DEPRESSURIZATION AT ISOLATED HOT SHUTDOWN, 2 RHR LOOPS	5	100	168	184
3A	SBA-ACCIDENT MODE, 1 RHR LOOP	5 (ADS)	2541	171	202
3в	SBA-FAILURE OF SHUTDOWN COOLING MODE, 2 RHR LOOPS	5	100	169	185

NOTES:

(1) SORV - STUCK OPEN SAFETY RELIEF VALVE

(2) WHEN THE MAIN CONDENSER IS AVAILABLE

DET-04-028-1 Revision 0

-

1-5.5

NOTES TO TABLE 1-5.1-1

- (1) Reactor operation at 102% of rated thermal power (3435 MWt).
- (2) Minimum Technical Specification suppression pool water volume (117,450 ft<sup>3</sup>).
- (3) The suppression pool has no initial velocity.
- (4) Wetwell and drywell airspaces are at nominal operating conditions.
- (5) Normal auxiliary power is available.
- (6) In the event of a loss of off-site power in conjunction with the loss of any one emergency bus, it is assumed that the available RHR loop can be switched from the pool cooling mode to the reactor shutdown cooling mode.
- (7) Normal automatic operation of the plant auxiliary system (high pressure coolant injection (HPCI), ADS).
- (8) The core spray pumps have a manual shutoff at vessel high water level (Level 8 elevation). They are reactivated when the level drops as needed to maintain water level and may be shut off again.
- (9) Control rod drive (CRD) flow is maintained constant at 8.89 lbm/sec.
- (10) SRV (manual, automatic, ADS) capacities are at 122.5% of ASME-rated flow to conservatively calculate maximum pool temperatures.
- (11) The licensed decay-heat curve (May-Witt) for containment analysis is used.
- (12) No heat transfer is considered in the drywell or wetwell airspace.
- (13) The MSIV's close 3 seconds after a 1/2 second delay for the isolation signal.
- (14) Operator actions are based on normal operator action times and licensing basis delays during the given event.
- (15) A switchover time of 16 minutes is taken to switch from the pool cooling mode to the shutdown cooling mode.

4

5.6

#### NOTES TO TABLE 1-5.1-1 (Concluded)

(16) When both RHR loops are operating and shutdown cooling is available, one RHR loop is left aligned in the pool cooling mode while the other is diverted to shutdown cooling. This assumption is reasonable because the pool is at a high temperature, and because a single RHR loop will effectively depressurized the vessel via shutdown cooling.

- (17) Drywell fan coolers are initially available in SORV events and isolation events. However, it is assumed that the coolers will not operate to keep the drywell pressure below the high drywell pressure trip set point (2 psig) after RPV lower water level 2 is reached. Consequently, under appropriate initial conditions the RHR will automatically switch out of the pool cooling mode and line up in the low pressure coolant injection (LPCI) mode.
- (18) The ADS system is modeled by fully opening five SRV's in the ADS mode. The ADS system may be actuated manually on high suppression pool temperature (120°F).
- (19) All RHR and ECCS pumps have 100% of their horsepower rating converted to a pump heat input (Btu/sec) and added directly to the pool as an enthalpy rise over time of pump operation.
- (20) Upon isolation, the portion of feedwater in the feedwater system that is higher in temperature than the peak bulk pool temperature is assumed to continue to return to the reactor vessel. The "hot" portion is taken to be the feedwater which enters the vessel at an enthalpy greater than 150 Btu/lbm.
- (21) The service water temperature for the RHR heat exchangers is kept constant at 89°F, giving a heat transfer coefficient of 321 Btu/sec-°F per loop.
- (22) The 18-in. RHR discharge line is directed parallel to flow in the discharge bay.
- (23) The break flow mass and energy are added to flow through the quenchers for SBA cases. This approach makes the results of SBA cases more conservative because it maintains a "hot spot" around the quenchers at all times.
- (24) The analyses are terminated when the pool temperature reaches a maximum and turns around, or when the steam discharging activities of the SRV's are over.
- (25) The operator will attempt to reclose an SORV. Based on available operating plant data prior to the implementation of the requirements of IE Bulletin 80-25 (Reference 16), SORVs have been shown to reclose at an average pressure of 260 psig. The lowest reclosure pressure recorded was 50 psig, and this value is conservatively assumed for this analysis.

DET-04-028 Revision 0

1

1-5.7







LOCAL POOL TEMERATURE LIMIT FOR ENRICO FERMI UNIT 2

1-5.8

1-5.2 Suppression Pool Temperature Monitoring System Design

Fermi 2 utilizes a Suppression Pool Temperature Monitoring System to ensure that the suppression pool is within the allowable Technical Specification limits. The conservative analysis of the Fermi 2 pool temperature response to SRV transients described in Section 1-5.1 contributes to ensuring that the pool temperature is maintained within acceptable limits during SRV discharges. The following discussion describes the Fermi 2 SPTMS design and conformance to the criteria specified in Appendix A of NUREG-0661.

The Fermi 2 SPTMS design utilizes 8 dual element thermocouples which are installed in the torus at an elevation of 556'-1" to measure torus water temperatures. In addition, there are 4 more dual element thermocouples installed at an elevation of 551'-4". These thermocouples are well below the minimum operating water level. (Normal operation is at 557'-0" and low low controls are at 556'-10".) All of these thermocouples are uniformly distributed throughout the torus.

DET-04-028-1 Revision 0 1-5.9

The Fermi 2 design provides suppression pool temperature indication and recording in the main control room. Suppression pool temperatures are calculated based on temperature sensors located throughout the pool. The Fermi 2 operating procedures will provide details and necessary steps such that minimum operator action is required to determine the pool bulk temperature.

The suppression pool temperature sensors (thermocouples) are seismically qualified and are of Quality Level III. The sensors are a passive element and do not require any power supply. The sensors are mounted on seismically qualified supports and the signal cables are routed in seismically qualified and supported trays and conduits to the main control room recorders. There are three multi-pen (12 pens) Stripchart Recorders of Quality Group III in the main control room and they are powered from onsite emergency bus power supplies.

The Fermi 2 SPTMS design as described above is in accordance with Appendix A of NUREG-0661.

DET-04-028-1 Revision 0 1-5.10

### 1-6.0

#### LIST OF REFERENCES

- "Mark I Containment Program Load Definition Report," General Electric Company, NEDO-21888, Revision 2, December 1981.
- "Mark I Containment Program Structural Acceptance Criteria Plant-Unique Analysis Applications Guide," Task Number 3.1.3, Mark I Owners Group, General Electric Company, NEDO-24583, Revision 1, July 1979.
- "Mark I Containment Long-Term Program," Safety Evaluation Report, USNRC, NUREG-0661, July 1980.
- "Enrico Fermi 2 Atomic Power Plant, Unit 2, Interim Plant Unique Analysis Report," NUTECH, DET-01-074, May 1978.
- 5. "The General Electric Pressure Suppression Containment Analytical Model," General Electric Company, NEDO-10320, April, 1971; Supplement 1, May, 1971; Supplement 2, January 1973.
- 6. "Mark I Containment Program Plant Unique Load Definition," Enrico Fermi Atomic Power Plant: Unit 2, General Electric Company, NEDO-24568, Revision 1, June 1981.
- "Mark I Containment Program Quarter-Scale Plant Unique Tests, Task Number 5.5.3, Series 2," General Electric Company, NEDE-21944-P, Volumes 1-4, April 1979.
- Patton, K.T., "Tables of Hydrodynamic" Mass Factors for Translational Motion, ASME Manuscript, Chicago, November 7-11, 1965.
- Miller, R.R., "The Effects of Frequency and Amplitude of Oscillation on the Hydrodynamic Masses of Irregularly-Shaped Bodies, MS Thesis, Univerity of Rhode Island, Kingston, R.I., 1965.
- Fitzsimmons, G. W. et al., "Mark I Containment Program Full-Scale Test Program Final Report, Task Number 5.11," General Electric Company, NEDE-24539-P, April 1979.

DET-04-028-1 Revision 0 1-6.1



- 11. "Mark I Containment Program Letter Reports MI-LR-81-01 and MI-LR-81-01-P, Supplemental Full-Scale Condensation Test Results and Load Confirmation-Proprietary and Nonproprietary Information," General Electric Company, May 6, 1981.
- 12. "Mark I Containment Program Full-Scale Test Program - Evaluation of Supplemental Tests," General Electric Company, NEDO-24539, Supplement 1, July 1981.
- 13. Hsiao, W. T. and Valandani, P., "Mark I Containment Program Analytical Model for Computing Air Bubble and Boundary Pressures Resulting from an SRV Discharge Through a T-Quencher Device," General Electric Company, NEDE-21878-P, August 1979.
- Letter from T. A. Ippolito (NRC) to J. F. Quirk (GE) dated October 16, 1981.
- 15. "Suppression Pool Temperature Limits for BWR Containment," USNRC, NUREG-0783, Draft, July 1981.
- 16. "Operating Problems with Target Rock Safety-Relief Valves at BWR's," USNRC, Office of Inspection and Enforcement, IE Bulletin No. 80-25, December 19, 1980.

DET-04-028-1 Revision 0

