NRC FORM 366 (7-77) U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	M I P A L 1 2 0 0 4 0 0 - 0 0 3 4 11 11 11 6 5 B LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58
CON'T	SOURCE 60 61 DOCKET NUMBER 66 69 EVENT DATE 74 75 REPORT DATE 80
	During review of construction records associated with modifications which
0 2	
0 3	installed two 8-inch containment purge lines, it was determined that
0 4	material and testing certifications could not be located for 4 pieces of
0 5	pipe; in addition, noncertified material was used for two 1-inch test taps.
0 6	System had satisfactorily passed a hydrostatic test accordingly, no threat
0 7	to public health or safety is considered to have exis. 30.
0 8	
7 8	9 SYSTEM CAUSE CAUSE COMP. VALVE
[e] o	SIA 10 X 12 Z 13 P P E X X 14 C 15 Z 16
4	LER RO EVENT YEAR REPORT NO. CODE TYPE NO.
	(17) REPORT 8 2
	ACTION FUTURE EFFECT SHUTDOWN HOURS 22 ATTACHMENT NPRD- PRIME COMP. COMPONENT NAKEN ACTION ON PLANT METHOD HOURS 22 SUBMITTED FORMULE SUPPLIER NANUFACTURER
	X (8) A (9) 2 (2) 1 (1) (1) (2) (1) (2) (3) (4) (4) (4) (4) (4) (4) (4) (4) (4) (4
	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0	Inadequate material controls caused this deviation. All nonconforming
	material will be replaced prior to returning the 8-inch purge lines to
112	service.
1 3	
14	
7 8	9 80 FACILITY STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION (32)
1 5	C 3 O O O O Cold Shutdown D 3 Review of Construction Records
	ELEASED OF RELEASE AMOUNT OF ACT TITY 35
7 8	9 10 11 44 45
	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39
1 7 8	9 11 12 13 NA
	PERSONNEL INJURIES 13 NUMBER DESCRIPTION 41
7 8	NA NA 80
	LOSS OF OR DAMAGE TO FACILITY 43
1 9	Z (42) NA
	PUBLICITY ISSUED DESCRIPTION 45
7 8	NA NA 68 69 80