LICENSEE EVENT REPORT

CONTROL BLOCK: [] [] [] (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 N Y J A F 1 2 0 0 - 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 4 5 57 CAT 58
CON'T SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
During normal operation, containment oxygen concentration exceeded the 4 percent
[0]3 [limit of TS 3.7.A.6 for approximately six (6) hours. Peak oxygen concentration was
[0] [approximately 7 percent. Air leakage as a result of a failed breathing air filter
[0]5] [gasket is the most likely source of air (oxygen). No significant hazard existed.
06
0 7
7 8 9
SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
LER/RO EVENT YEAR SEQUENTIAL REPORT NO. 17 REPORT NUMBER 2 23 24 26 27 28 29 30 31 32
ACTION FUTURE EFFECT SHUTDOWN HOURS 22 ATTACHMENT NFRD-4 PRIME COMP. COMPONENT MANUFACTURER X 18 X 19 Z 20 Z 21 0 0 0 0 N 23 N 24 Z 25 Z 9 9 9 21 21 23 24 24 24 25 26 27 26 27 27 27 27 27
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) [1] O Personnel error was the cause. Breathing air to containment should have been isolated
[1] [by closure of a manual valve. Isolation of the breathing air and the addition of
[1] Initrogen reduced oxygen concentration to within TS limits. To prevent recurrence.
[1] [the startup check off list will be revised to require a check of the air isolation
[1]4] [valve prior to startup. Evaluation of systems to maintain valve lineup continues.]
PACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 1 5 E 28 0 4 9 29 NA A 31 Operator Observation
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36) NA NA NA NA NA NA NA NA NA
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 NA NA
7 9 PERSONNEL INJURIES 13 NUMBER DESCRIPTION 41 NA
LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION NA NA
PUBLICITY (45) B205040535 B20420 NRC USE ONLY NA S PDR
7 8 9 10 68 69 80 5