


Nebraska Public Power District
Cooper Nuclear Station

Annual Environmental Operating Report Volume II — Radiological

Environmental Radiation Monitoring Program
January 1, 1981 — December 31, 1981




USNRC Docket Number 50-298




Prepared by

**TELEDYNE
ISOTOPES**

8205070217 820310
PDR ADOCK 05000298
R PDR





Nebraska Public Power District

GENERAL OFFICE
P.O. BOX 499, COLUMBUS, NEBRASKA 68601-0499
TELEPHONE (402) 564-8561

LQA8200094

March 10, 1982

Mr. John T. Collins
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive
Suite 1000
Arlington, Texas 76011

Subject: Annual Environmental Operating Report
Volume II - Radiological
Cooper Nuclear Station
NRC Docket No. 50-298, DPR-46

Dear Mr. Collins:

In accordance with Paragraph 5.4.1.a(2) of the Cooper Nuclear Station Technical Specifications, the Nebraska Public Power District submits the Cooper Nuclear Station Annual Environmental Operating Report Volume II - Radiological for the period January 1, 1981 through December 31, 1981.

We are enclosing one signed original of the report for your use and are transmitting 18 copies to the Document Control Desk in accordance with Regulatory Guide 10.1, Revision 4.

Should you have any questions or comments regarding this report, please contact me.

Sincerely,

Jay M. Pilant
Division Manager of Licensing
and Quality Assurance

JMP:ACM:cmk
Enclosure

cc: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. John T. Collins
March 10, 1982
Page 2

STATE OF NEBRASKA)
) ss
PLATTE COUNTY)

Jay M. Pilant, being first duly sworn, deposes and says that he is an authorized representative of the Nebraska Public Power District, a public corporation and political subdivision of the State of Nebraska; that he is duly authorized to submit this information on behalf of Nebraska Public Power District; and that the statements in said application are true to the best of his knowledge and belief.

Jay M. Pilant
Jay M. Pilant

Subscribed in my presence and sworn to before me this 10th day of March, 1982.

Colleen M. Kuta
NOTARY PUBLIC




NEBRASKA PUBLIC POWER DISTRICT
COOPER NUCLEAR STATION
ANNUAL SUMMARY REPORT 1981

ENVIRONMENTAL RADIATION
MONITORING PROGRAM

PREPARED BY
TELEDYNE ISOTOPES
50 VAN BUREN AVENUE
WESTWOOD, NEW JERSEY 07675

REPORT APPROVED BY:



MANAGER
ENVIRONMENTAL ANALYSIS DEPARTMENT

TABLE OF CONTENTS

	<u>PAGE</u>
INTRODUCTION	1
LOCATION MAP	2
SAMPLING SCHEDULE AND ANALYSES	3
STATIONS AND RELATIVE POSITION TO ERP	6
REMPs TABLE - ANNUAL SUMMARY	8
DISCUSSION, IMPACT ON ENVIRONMENT AND STATISTICAL TABLES	36
A&B. AIR PARTICULATES - GROSS BETA - GROSS ALPHA	37
C. CHARCOAL FILTER, I-131	46
D. COMPOSITE OF AIR PARTICULATE FILTERS - GAMMA	51
E. EGGS	54
F. FEED AND FORAGE - BEEF PRODUCERS	57
G&H. FOOD AND GARDEN CROPS - APPLES-GARDEN VEGETABLES	61
I&J. FEED AND FORAGE - NEAREST MILK PRODUCERS-COMMERCIAL MILK PRODUCERS	66
K. FOOD AND FEED CROPS	73
L. FISH	76
M&N. MILK - COMMERCIAL PRODUCERS AND NEAREST PRODUCERS	79
O. GROUNDWATER	84
P. RIVER WATER	87
Q. RABBITS	90
R. AQUATIC VEGETATION	93
S. SOIL	97
T. THERMOLUMINESCENT DOSIMETERS	100

INTRODUCTION

This annual summary report of the radiological environmental monitoring program conducted in the environs of the Cooper Nuclear Station (CNS) for the Nebraska Public Power District (NPPD) contains summaries of the analysis of radionuclides monitored during 1981.

Samples were collected in the environs of CNS by NPPD and analyzed by Teledyne Isotopes in compliance with the Environmental Technical Specifications, Appendix B of the Cooper Nuclear Station Operating License.

The results of the analyses performed during 1981 were compared with previous studies conducted during 1973 through 1976 and in 1979 and 1980 by Teledyne Isotopes. In the years 1977 through 1978 the monitoring program was conducted by the Hazelton Environmental Science Company. From summaries of the 1981 results and comparisons with data generated previously assessments were made of the observed impact of the nuclear plant (CNS) operations on the environment.

NEBRASKA PUBLIC POWER DISTRICT
COOPER NUCLEAR STATION
SAMPLING STATION
LOCATIONS MAP




TABLE 1

Sampling schedule and analyses, 1981, Cooper Nuclear Station

WEEKLY

<u>Sample Type</u>	<u>Station Nos.</u>	<u>Analyses</u>
Airborne - Particulates	1 - 10	Gross α , β Gamma spec. on quarterly composite of each station and on samples with β levels > 300 dpm
Airborne - Iodine	1 - 10	I-131
Feed & Forage - Beef Producers (peak pasture only)	64, 65, 67, 68, 71, 76	Gamma spec. on monthly composite
Milk - Nearest Producers (peak pasture only)	61, 74	I-131 (low level) Sr-89, Sr-90 Elem. Ca Gamma spec. on monthly composite

MONTHLY

<u>Sample Type</u>	<u>Station Nos.</u>	<u>Analyses</u>
Feed & Forage - Beef Producers (except peak pasture season)	64, 65, 67, 68, 71, 76	Gamma spec.
Feed & Forage - Nearest Milk Producers (peak pasture only)	61, 74	Sr-89, Sr-90 Elem. Ca Gamma spec.
River Water	12, 13, 28	Gross α - sus & dis Gross β - sus & dis Sr-89, Sr-90 Gamma spec. and tritium on quarterly composite
Milk - Nearest Producers	61, 74	I-131 (low level) Sr-89, Sr-90 Elem. Ca Gamma spec.

(Continued)

TABLE 1

<u>QUARTERLY</u>		
<u>Sample Type</u>	<u>Station Nos.</u>	<u>Analyses</u>
Background Radiation	1 - 10, 15, 18, 22, 44, 58, 59	TLD readout
Feed & Forage - Nearest Milk Pro- ducers (except peak pasture season)	61, 74	Sr-89, Sr-90 Elem. Ca Gamma spec.
Feed & Forage - Commercial Milk Producers	42, 73, 75	Sr-89, Sr-90 Elem. Ca Gamma Spec.
Ground Water	11, 47	Gross α , β Gamma spec. Tritium
Milk - Commercial Producers	42, 73, 75	I-131 (low level) Sr-89, Sr-90 Elem. Ca Gamma spec.
Eggs	42, 51, 67, 76	Gross β Sr-89, Sr-90 Elem. Ca Gamma spec.
<u>2 TIMES/YEAR</u>		
<u>Sample Type</u>	<u>Station Nos.</u>	<u>Analyses</u>
Fish (Summer and Fall)	28, 35	Gross β Sr-89, Sr-90 Gamma spec.
Aquatic Vegetation	12, 13 28	Gross β Sr-89, Sr-90 Gamma spec.
<u>ANNUALLY</u>		
<u>Sample Type</u>	<u>Station Nos.</u>	<u>Analyses</u>
Food & Feed Crops (at harvest)	15, 18, 20, 27, 29, 38, 41	Gross β Sr-89, Sr-90 Elem. Ca Gamma spec.

(Continued)

TABLE 1

ANNUALLY (cont'd.)

<u>Sample Type</u>	<u>Station Nos.</u>	<u>Analyses</u>
Garden Crops (at harvest)	34, 56, 62	Gross β Sr-89, Sr-90 Elem. Ca Gamma spec.
Apples (at harvest)	53, 54	Gross β Sr-89, Sr-90 Elem. Ca Gamma spec.
Rabbits (fall or early winter)	28, 35	Thyroid - I-131 Femur - Sr-89, Sr-90 Muscle - Gamma spec.

ONCE EVERY THREE YEARS

<u>Sample Type</u>	<u>Station Nos.</u>	<u>Analyses</u>
Soil (Sampled in 1981)	2 - 10	Sr-90 Gamma spec.

TABLE 2

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 BROWNVILLE, NEBRASKA

DISTANCE AND DIRECTION FROM THE ELEVATED RELEASE POINT (ERP) TO THE
 SAMPLE STATION LOCATIONS

<u>STATION NUMBER</u>	<u>DISTANCE (MILES)</u>	<u>DIRECTION (DEGREES)</u>	<u>CLASSIFICATION (a)</u>
1	.1	225	IND
2	.75	225	IND
3	2.5	338	IND
4	3.0	43	IND
5	3.5	102	IND
6	3.0	165	IND
7	2.5	230	IND
8	2.5	260	IND
9	7.25	335	IND
10	10.0	160	IND
11	.15	225	IND
12	.1	360	CON
13	.25	120	IND
14	.5	140	PO
15	.51	180	IND
16	.75	202	NA
17	1.5	235	PO
18	.8	270	IND
19	1.0	300	PO
20	.96	315	IND
21	.6	46	PO
22	.7	95	IND
23	1.9	80	PO
24	3.0	97	PO
25	3.75	105	PO
26	3.0	130	PO
27	3.0	143	IND
28	1.8	150	IND
29	3.0	170	IND
30	5.0	178	PO
31	2.75	222	NA
32	3.4	268	PO
33	2.8	302	PO
34	2.5	333	IND
35	2.0	350	CON
36	3.6	335	PO
37	3.9	330	NA
38	4.0	360	IND
39	2.75	25	PO

TABLE 2

<u>STATION NUMBER</u>	<u>DISTANCE (MILES)</u>	<u>DIRECTION (DEGREES)</u>	<u>CLASSIFICATION (a)</u>
40	3.9	37	PO
41	8.4	11	IND
42	12.85	156	IND
43	11.75	217	NA
44	10.25	270	CON
45	4.0	325	NA
46	24.75	153	NA
47	25.75	154	IND
48	5.6	332	NA
49	11.4	222	NA
50	1.1	270	NA
51	4.2	125	IND
52	7.4	79	NA
53	2.0	216	IND
54	5.2	320	IND
55	1.75	270	NA
56	1.9	118	IND
57	6.6	208	NA
58	1.25	219	IND
59	1.0	189	IND
60	8.4	42	NA
61	3.5	326	IND
62	1.5	225	IND
63	5.0	56	NA
64	2.25	99	IND
65	1.1	305	IND
66	4.5	200	NA
67	4.75	325	IND
68	3.4	270	IND
69	3.5	3	NA
70	3.5	3	NA
71	4.25	71	IND
72	3.75	39	NA
73	10.0	35	IND
74	2.4	270	IND
75	9.0	180	IND
76	5.3	212	IND

(a) Classification codes: IND = indicator; CON = control; PO = pre-operational sampling site not used in 1980-81 sampling program; NA = not active as of 1 January 1980.

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- AIRBORNE
 SAMPLE - AIR PARTICULATE FILTERS
 UNITS - PCI/CU. M

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES MEAN X E-00 RANGE FRACTION	LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE FRACTION	NON- ROUTINE	REPORTING PERIOD
				STATION FRACTION	STATION DESCRIPTION			
GR-A	520	0.0020	0.0019 - 0.0022 247/510	0.0027	10	032/051 0.0010 - 0.0064 STATION 10 - 10.0 MI. 160 DEG. INC.		0 12/29/80-12/28/ 81
GR-B	520	0.0030	0.083 - 0.11 507/510	0.15	02	050/051 0.019 - 0.44 STATION 02 - 0.75 MI. 225 DEG. INC.		0 12/29/80-12/28/ 81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- AIRBORNE
 SAMPLE - CHARCOAL FILTERS
 UNITS - PCI/CC. M

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			FRACTION	RANGE	STATION FRACTION	MEAN X E-00 RANGE			
					STATION DESCRIPTION				

I-131	520	0.0300	LT	0.140					0 12/29/80-12/28/81
			LT	0.0400	-LT	0.140			
				000/510					

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- AIRBORNE
 SAMPLE - COMPOSITE AIR PARTICULATE FILTERS
 UNITS - PCI/CU. M

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION		NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION FRACTION	STATION DESCRIPTION	MEAN X E-00	RANGE		
BE-7	40	0.0500	0.0550 - 040/040	0.103 0.140	02	003/003 STATION 02 - 0.75 MI. 225 DEG. INC.	0.140 0.126 - 0.149			0 12/29/80-12/28/81
MA-54	40	0.00300	0.00141 - 008/030	0.00168 0.00233	01	001/003 STATION 01 - 0.1 MI. 225 DEG. INC.	0.00233 0.00233 - 0.00233			0 12/29/80-12/28/81
CC-60	40	0.00500	0.00332 - 002/030	0.0176 0.0319	01	001/003 STATION 01 - 0.1 MI. 225 DEG. INC.	0.0319 0.0319 - 0.0319			0 12/29/80-12/28/81
ZR-95	40	0.00500	0.0210 - 024/030	0.0433 0.0697	01	002/003 STATION 01 - 0.1 MI. 225 DEG. INC.	0.0697 0.0595 - 0.0799			0 12/29/80-12/28/81
RU-103	40	0.00300	0.0111 - 021/030	0.0176 0.0214	04	002/003 STATION 04 - 3.0 MI. 43 DEG. INC.	0.0214 0.0155 - 0.0274			0 12/29/80-12/28/81
RU-106	40	0.0300	0.0124 - 009/030	0.0181 0.0221	08	001/003 STATION 08 - 2.5 MI. 260 DEG. INC.	0.0221 0.0221 - 0.0221			0 12/29/80-12/28/81
I-131	40	0.00300 LT	LT 0.400 0.200 -LT 0.400 000/030							0 12/29/80-12/28/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- AIRBORNE
 SAMPLE - COMPOSITE AIR PARTICULATE FILTERS
 UNITS - PCI/CU. M

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00 RANGE	FRACTION	STATION FRACTION	MEAN X E-00 RANGE			
CS-137	40	0.00300	0.00158- 019/030	0.00238 0.00372	10	001/003 STATION 10 - 10.0 MI. 160 DEG. INC.	0.00372 0.00372		0 12/29/80- 12/28/81
CE-141	40	0.00300	0.00681- 020/030	0.0112 0.0174	02	002/003 STATION 02 - 0.75 MI. 225 DEG. INC.	0.0174 0.0113 - 0.0236		0 12/29/80- 12/28/81
CE-144	40	0.0100	0.0203 - 029/030	0.0239 0.0311	02	003/003 STATION 02 - 0.75 MI. 225 DEG. INC.	0.0311 0.0131 - 0.0570		0 12/29/80- 12/28/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - E G G S
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00 FRACTION	MEAN X E-00 RANGE	STATION FRACTION	STATION DESCRIPTION			
CA MG/GM	16		0.11 016/016	0.14 - 0.20	51 STATION 51 - 4.2 MI. 125 DEG. INC.	0.029 - 0.59	0.20	O	01/12/81-10/19/81
CR-B	16	0.060	1.3 016/016	1.0 - 2.0	67 STATION 67 - 4.75 MI. 325 DEG. INC.	0.75 - 2.9	2.0	C	01/12/81-10/19/81
SR-89	16	0.0060	LT 0.0060 000/016	0.0060 -LT 0.0060				O	01/12/81-10/19/81
SR-90	16	0.0060	0.0016 003/016	0.0017 - 0.0018	67 STATION 67 - 4.75 MI. 325 DEG. INC.	0.0018 - 0.0019	0.0018	O	01/12/81-10/19/81
K-4C	16	0.470	0.918 016/016	1.02 - 1.11	51 STATION 51 - 4.2 MI. 125 DEG. INC.	0.825 - 1.34	1.11	O	01/12/81-10/19/81
I-131	16	0.0310	LT 0.0100 000/016	0.0200 -LT 0.0200				O	01/12/81-10/19/81
CS-137	16	0.0310	LT 0.00700 000/016	0.00900 -LT 0.00900				C	01/12/81-10/19/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FEED & FORAGE - BEEF PRODUCERS
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	FRACTION	STATION FRACTION			
SAMPLE	4		LT	0.00000					0 05/04/81-07/27/81
	(a)		LT	0.00000-LT 000/004	0.00000				
EE-7	87	0.310		7.28					0 01/05/81-12/07/81
				4.18 - 11.6 044/086		71	010/015	0.131 - 67.8	
								STATION 71 - 4.25 MI. 71 DEG. INC.	
K-40	87	0.470		15.6					0 01/05/81-12/07/81
				9.27 - 21.2 087/087		64	015/015	2.36 - 46.5	
								STATION 64 - 2.25 MI. 99 DEG. INC.	
PN-54	87	0.0310		0.0816					0 01/05/81-12/07/81
				0.0645 - 0.0987 002/087		64	001/015	0.0987 - 0.0987	
								STATION 64 - 2.25 MI. 99 DEG. INC.	
ZR-95	87	0.0470		0.839					0 01/05/81-12/07/81
				0.643 - 0.972 021/086		67	003/014	0.566 - 1.20	
								STATION 67 - 4.75 MI. 325 DEG. INC.	
RU-103	87	0.0310		0.138					0 01/05/81-12/07/81
				0.114 - 0.172 009/087		64	002/015	0.131 - 0.214	
								STATION 64 - 2.25 MI. 99 DEG. INC.	
RU-106	87	0.310		0.893					0 01/05/81-12/07/81
				0.746 - 1.04 002/087		64	001/015	1.04 - 1.04	
								STATION 64 - 2.25 MI. 99 DEG. INC.	

(a) There was no sample from Station 65 on 05/04, 06/08 and 07/27; no QA composite could be prepared for the second quarter; therefore there are four samples not collected from Station 65. The cattle were moved to a different location.

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FEED & FORAGE - BEEF PRODUCERS
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES MEAN X E-00 RANGE FRACTION	LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE FRACTION	NON- ROUTINE	REPORTING PERIOD
				STATION FRACTION	STATION DESCRIPTION			
I-121	87	0.0310	LT 2.00 LT 0.500 -LT 2.00 000/086					C 01/05/81-12/07/81
CS-137	87	0.0470	0.107 - 0.134 026/086	0.164	64 005/015 STATION 64 - 2.25 MI. 99 DEG. IND.	0.0669 - 0.295 0.164		O 01/05/81-12/07/81
CE-141	87	0.0470	0.0885 - 0.134 005/086	0.225	64 001/015 STATION 64 - 2.25 MI. 99 DEG. INC.	0.225 - 0.225 0.225		O 01/05/81-12/07/81
CE-144	87	0.160	0.552 - 1.06 027/085	1.55	64 005/015 STATION 64 - 2.25 MI. 99 DEG. IND.	0.552 - 2.70 1.55		O 01/05/81-12/07/81
TH-228	87	0.120	0.0110 - 0.0209 002/086	0.0309	76 001/015 STATION 76 - 5.3 MI. 212 DEG. INC.	0.0309 - 0.0309 0.0309		O 01/05/81-12/07/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FOOD/GARDEN CROPS
 UNITS - PC1/GM

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION		NON- ROUTINE	REPORTING PERIOD		
			MEAN X E-00	RANGE	FRACTION	STATION FRACTION	MEAN X E-00	RANGE			FRACTION	
						STATION DESCRIPTION						
CA MG/GM	5		0.019	0.11	0.22	62	001/001	0.22	-	0.22	0	08/10/81-09/14/81
			005/005			STATION 62 - 1.5 MI. 225 DEG. IND.						
GR-E	5	0.030	2.9	3.9	5.2	62	001/001	5.2	-	5.2	0	08/10/81-09/14/81
			005/005			STATION 62 - 1.5 MI. 225 DEG. IND.						
SR-89	5	0.0030	LT	0.0020	0.0040						0	08/10/81-09/14/81
			000/005									
SR-90	5	0.0030	0.0015	0.0016	0.0017	34	001/001	0.0017	-	0.0017	0	08/10/81-09/14/81
			002/005			STATION 34 - 2.5 MI. 333 DEG. IND.						
K-40	5	0.470	1.26	1.84	2.34	62	001/001	2.34	-	2.34	0	08/10/81-09/14/81
			004/005			STATION 62 - 1.5 MI. 225 DEG. IND.						
I-131	5	0.0310	LT	0.0100	0.0200						0	08/10/81-09/14/81
			000/005									
CS-137	5	0.0310	LT	0.00900	0.0200						0	08/10/81-09/14/81
			000/005									

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FEED & FORAGE - MILK PRODUCERS
 UNITS - PCI/GM WET (NEAREST)

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN			CONTROL LOCATION		NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION FRACTION	STATION DESCRIPTION	MEAN X E-00	RANGE	FRACTION		
CA	17		2.5 017/017	2.6 - 2.7	61	005/005 STATION 61 - 3.5 MI. 326 DEG. IND.	2.7 - 10.0				0 01/12/81-10/05/81
SR-89	17	0.60	0.033 003/017	- 0.047 0.060	74	002/008 STATION 74 - 2.4 MI 270 DEG. IND.	0.037 - 0.082				0 01/12/81-10/05/81
SR-90	17	0.60	0.055 009/017	- 0.079 0.102	74	005/008 STATION 74 - 2.4 MI. 270 DEG. IND.	0.014 - 0.59				0 01/12/81-10/05/81
BE-7	17	0.310	1.97 007/017	- 2.19 2.40	61	002/009 STATION 61 - 12.85 MI. 156 DEG. IND.	2.04 - 2.74				0 01/12/81-10/05/81
K-40	17	0.470	7.10 017/017	- 10.15 13.2	61	009/009 STATION 61 - 3.5 MI. 326 DEG. IND.	2.87 - 38.4				0 01/12/81-10/05/81
IR-95	17	0.0470	0.332 005/017	- 0.418 0.503	74	001/005 STATION 74 - 2.4 MI. 270 DEG. IND.	0.503 - 0.503				0 01/12/81-10/05/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FEED AND FORAGE - MILK PRODUCERS
 UNITS - PCI/GM WET (NEAREST)

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			FRACTION	MEAN X E-00 RANGE	STATION FRACTION STATION DESCRIPTION	MEAN X E-00 RANGE			
RU-103	17	0.0310	0.0927 - 002/017	0.115 0.139	74	002/008 STATION 74 - 2.4 MI. 270 DEG. IND.	0.139 0.0360 - 0.242		0 01/12/81-10/05/81
I-131	17	0.0310	LT 0.0500 -LT 000/030	0.200 0.200					0 01/12/81-10/05/81
CS-137	17	0.0470	0.062 - 001/017	0.062 0.062	74	001/008 STATION 74 2.4 MI. 270 DEG. IND.	0.062 0.062 0.062		0 01/12/81-10/05/81
CE-141	17	0.0470	0.0998 - 002/017	0.137 0.174	74	002/008 STATION 74 - 2.4 MI. 270 DEG. IND.	0.174 0.04 0.30		0 01/12/81-10/05/81
CE-144	17	0.160	0.409 - 003/017	0.517 0.624	61	001/009 STATION 61 - 3.5 MI. 326 DEG. IND.	0.624 0.624 0.624		0 01/12/81-10/05/81
RA-226	17	0.0930	0.207 - 003/017	0.264 0.321	61	002/009 STATION 61 - 3.5 MI. 326 DEG. IND.	0.321 0.316 - 0.327		0 01/12/81-10/05/81
TH-228	17	0.120	0.0241 - 001/017	0.0241 0.0241	61	001/009 STATION 61 - 3.5 MI. 326 DEG. IND.	0.0241 0.0241 - 0.0241		0 01/12/81-10/05/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FEED & FORAGE - MILK PRODUCERS
 UNITS - PCI/GM WET (COMMERCIAL)

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-CO	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN			CONTROL LOCATION MEAN X E-CO RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION	FRACTION	MEAN X E-00			
					STATION DESCRIPTION					
CA MG/GM	13		2.0	2.6 - 3.4	42	005/005	1.3 - 9.0			0 01/12/81-10/12/81
			013/013		STATION 42 - 12.85 MI. 156 DEG. IND.					
SR-89	13	0.60	0.06	0.20 - 0.35	42	001/005	0.35 - 0.35			0 01/12/81-10/12/81
			002/013		STATION 42 - 12.85 MI. 156 DEG. IND.					
SR-90	13	0.60	0.019	0.178 - 0.13	73	003/004	0.040 - 0.13			0 01/12/81-10/12/81
			011/013		STATION 73 - 10.0 MI. 35 DEG. IND.					
Be-7	13	0.310	0.564	1.15 - 3.94	42	001/005	3.94 - 3.94			0 01/12/81-10/12/81
			005/013		STATION 42 - 12.85 MI. 145 DEG. IND.					
K-40	13	0.470	4.75	9.65 - 11.6	42	005/005	5.84 - 28.1			0 01/12/81-10/12/81
			013/013		STATION 42 - 12.85 MI. 156 DEG. IND.					
MN-54	13	0.0310	0.0652	0.0652 - 0.0652	73	001/004	0.0652 - 0.0652			0 01/12/81-10/12/81
			001/013		STATION 73 - 10.0 MI. 35 DEG. IND.					
ZR-95	13	0.0470	0.332	0.780 - 0.940	42	001/005	0.940 - 0.940			0 01/12/81-10/12/81
			002/013		STATION 42 - 12.85 MI. 156 DEG. IND.					

18

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FEED & FORAGE - MILK PRODUCERS
 UNITS - PCI/GH WET (COMMERCIAL)

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN			CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	FRACTION	STATION FRACTION	STATION DESCRIPTION			
RU-103	13	0.0310	0.093	0.093	42	001/005	0.093 - 0.093	0.093		0 01/12/81-10/12/81
			0.093 -	0.093	STATION	42 - 12.85 MI	156 DEG. IND.			
I-131	13	0.0310	LT 0.0500	0.200						0 01/12/81-10/12/81
			LT 0.0500	0.200						
CS-137	13	0.0470	0.008	0.118	42	CC1/005	0.118 - 0.118	0.118		0 01/12/81-10/12/81
			0.008 -	0.118	STATION	42 - 12.85 MI.	156 DEG. INC.			
CE-141	13	0.0470	0.114	0.114	42	001/005	0.114 - 0.114	0.114		0 01/12/81-10/12/81
			0.114 -	0.114	STATION	42 - 12.85 MI.	156 DEG. IND.			
CE-144	13	0.160	0.900	1.14	42	001/005	1.14 - 1.14	1.14		0 01/12/81-10/12/81
			0.900 -	1.14	STATION	42 - 12.85 MI.	156 DEG. IND.			
RA-226	13	0.0930	LT 1.00	1.00						0 01/12/81-10/12/81
			LT 1.00	1.00						
TH-228	13	0.120	LT 0.100	0.100						0 01/12/81-10/12/81
			LT 0.100	0.100						

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FOOD AND FEED CROPS
 UNITS - PCI/GM

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE FRACTION	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00 FRACTION	RANGE	STATION FRACTION	MEAN X E-00 RANGE STATION DESCRIPTION			
CA MG/GM	8		0.0080 008/008	0.59 - 2.2	15	001/001 STATION 15 - 0.51 MI. 180 DEG. INC.	2.2 - 2.2		0 09/21/81-09/21/81
GR-E	8	6.0	4.0 008/008	11. - 31.	15	001/001 STATION 15 - 0.51 MI. 180 DEG. INC.	31. - 31.		1 09/21/81-09/21/81
SS-89	8	0.60	LT 0.0060 000/008	0.030 -LT 0.030					0 09/21/81-09/21/81
SR-90	8	0.60	0.0071 003/008	0.012 - 0.021	38	001/001 STATION 38 - 4.0 MI. 360 DEG. INC.	0.021 - 0.021		0 09/21/81-09/21/81
BE-7	8	1.20	0.370 003/008	0.672 - 1.15	41	001/001 STATION 41 - 8.4 MI. 11 DEG. INC.	1.15 - 1.15		0 09/21/81-09/21/81
K-40	8	0.930	2.22 008/008	7.09 - 21.4	41	001/001 STATION 41 - 8.4 MI. 11 DEG. INC.	21.4 - 21.4		0 09/21/81-09/21/81
I-131	8	0.120	LT 0.0200 000/008	0.0500 -LT 0.0900					0 09/21/81-09/21/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - FOOD AND FEED CROPS
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION FRACTION	MEAN X E-00			

CS-137	8	0.160	LT	0.0300					0 09/21/81-09/21/81
			LT	0.00900-0.0300					
				000/008					

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - F I S H
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00 FRACTION	RANGE	STATION FRACTION	STATION DESCRIPTION			
GR-B	10	0.25	3.5 010/010	3.7 - 3.9	28	005/005 STATION 28 - 1.8 MI.	2.9 - 5.6 150 DEG. IND.		0 04/20/81-10/17/81
SR-89	10	0.030	LT 0.030 000/010	-LT 0.030					0 04/20/81-10/17/81
SR-90	10	0.030	0.019 008/010	0.10 - 0.20	35	004/005 STATION 35 - 2.0 MI.	0.025 - 0.76 350 DEG. CCN.		0 04/20/81-10/17/81
K-40	10	0.470	2.58 010/010	2.64 - 2.70	28	005/005 STATION 28 - 1.8 MI.	2.48 - 3.08 150 DEG. IND.		0 04/20/81-10/17/81
I-131	10	0.0310	LT 0.0200 000/010	-LT 0.0300					0 04/20/81-10/17/81
CS-137	10	0.0310	LT 0.00900 000/010	-LT 0.0200					0 04/20/81-10/17/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - MILK COMMERCIAL PRODUCER
 UNITS - PCT/LITER

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN			CONTROL LOCATION MEAN X E-00 RANGE FRACTION	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION FRACTION	STATION DESCRIPTION	MEAN X E-00			
CA MG/gm	12		1.89							0 01/19/81-12/15/81
			1.78 - 2.10	73	004/004	1.4 - 2.8				
			012/012		STATION 73 - 10.0 MI. 35 DEG. IND.					
I-131	12	0.78	LT 0.30							0 01/19/81-12/15/81
			LT 0.20 -LT 0.30							
			000/012							
LOST (a)	1		LT 0.00000							0 01/19/81-01/19/81
			LT 0.00000-LT 0.00000							
			000/002							
SR-89	12	2.0	LT 2.0							0 01/19/81-12/15/81
			LT 2.0 -LT 2.0							
			000/012							
SR-90	12	1.4	3.69							0 01/19/81-12/15/81
			3.50 - 3.78	73	004/004	2.6 - 5.4				
			012/012		STATION 73 - 10.0 MI. 35 DEG IND.					
K-40	12	140.	1200.							0 01/19/81-12/15/81
			1110. - 1250.	75	004/004	1110. - 1250.				
			012/012		STATION 75 - 9.0 MI. 180 DEG. IND.					
I-131	12	0.780	LT 60.0							0 01/19/81-12/15/81
			LT 10.0 -LT 60.0							
			000/012							

(a) January 19, Station 75 - Milk sample lost; discarded by air freight because it leaked; resampled 01/27.

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - MILK COMMERCIAL PRODUCERS
 UNITS - PCU/LITER

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES MEAN X E-00 RANGE	FRACTION	LOCATION WITH HIGHEST MEAN STATION FRACTION STATION DESCRIPTION	CONTROL LOCATION MEAN X E-00 RANGE	NON-ROUTINE	REPORTING PERIOD

CS-137	12	9.00	LT	7.00 000/012	LT	9.00 -LT	9.00	0	01/19/81-12/15/81
--------	----	------	----	-----------------	----	-------------	------	---	-------------------

TH-228	12	31.0	LT	10.0 000/012	LT	10.0 -LT	10.0	0	01/19/81-12/15/81
--------	----	------	----	-----------------	----	-------------	------	---	-------------------

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - MILK NEAREST PRODUCERS
 UNITS - PCI/LITER

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	FRACTION	STATION FRACTION			
			FRACTION		STATION DESCRIPTION		FRACTION		
CA MG/GM	27		1.75	1.90 - 2.05	74	014/014	0.98 - 2.80		0 01/19/81-12/15/81
			034/034			STATION 74 - 2.4 MI. 270 DEG. IND.			
I-131	62	0.78	LT 0.20	LT 0.50 -LT 0.50					0 01/19/81-12/15/81
			000/062						
LCST (c)	1		LT 0.00000	LT 0.00000 -LT 0.00000					0 01/19/81-01/19/81
			000/001						
SR-89	27	2.0	LT 2.0	LT 2.0 -LT 2.0					0 01/19/81-12/15/81
			000/027						
SR-90	27	1.4	1.93	2.03 - 2.13	61	012/013	0.79 - 3.9		0 01/19/81-12/15/81
			024/027			STATION 61 - 3.5 MI. 326 DEG. IND.			
K-40	27	140.	1110.	1145. - 1190.	74	014/014	1020. - 1420.		0 01/19/81-12/15/81
			027/027			STATION 74 2.4 MI. 270 DEG. IND.			
I-131	27	0.780	LT 10.0	LT 60.0 -LT 60.0					0 01/19/81-12/15/81
			000/027						

(a) January 19, Station 61 - Milk sample lost; discarded by air freight because it leaked; resampled 01/16.

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - M I L K NEAREST PRODUCERS
 UNITS - PCI/LITER

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION		NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION FRACTION	STATION DESCRIPTION	MEAN X E-00	RANGE		
CS-137	27	9.00	LT 7.00 000/027	9.00 -LT 9.00						0 01/19/81-12/15/81
Th-228	27	31.0	5.58 - 001/027	5.58 5.58	61	001/012 STATION 61 - 3.5 MI. 326 DEG. IND.	5.58 - 5.58			0 01/19/81-12/15/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- WATERBORNE
 SAMPLE - WATER - GROUND
 UNITS - PCT/LITER

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-CO	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-CO RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION FRACTION	STATION DESCRIPTION			
GR-A	8	0.80	LT 4.0 000/008	5.0 -LT 5.0					C 01/26/81-10/26/81
GR-B	8	1.4	8.3 008/008	8.8 - 9.4	11	004/004 STATION 11 - 0.15 MI. 225 DEG. IND.	7.3 - 11.0		0 01/26/81-10/26/81
I-131	8	9.00	LT 20.0 000/008	30.0 -LT 30.0					0 01/26/81-10/26/81
CS-137	8	9.00	LT 6.00 000/008	7.00 -LT 7.00					0 01/26/81-10/26/81
H-3	8	140.	110. 007/008	180. - 250.	47	004/004 STATION 47 - 25.75 MI. 154 DEG. IND.	250. - 330.		0 01/26/81-10/26/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- WATERBORNE
 SAMPLE - WATER - RIVER
 UNITS - PC/LITER

COMPILATION - ANNUAL SUMMARY
 CONTROL - STATION 12 - 0.1 MI. 360 DEG. CO

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION		NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00 FRACTION	MEAN X E-00 RANGE	STATION FRACTION	MEAN X E-00 RANGE STATION DESCRIPTION	MEAN X E-00 RANGE FRACTION			
GR-A DIS	36	0.80	2.9 002/036	2.9 - 2.9	13 002/012	1.0 - 4.9	2.9 - 4.9	LT 4.0 000/012	LT 0.70 -LT 4.0	0 01/06/81-12/08/81
GR-A SUS	36	0.80	1.5 007/036	2.7 - 4.5	28 001/012	4.5 - 4.5	4.5 - 4.5	2.2 002/012	1.6 - 2.8	0 01/06/81-12/08/81
GR-B DIS	36	1.4	9.0 033/036	9.5 - 10.	13 011/012	5.8 - 18.	10. - 18.	9.0 011/012	3.6 - 12.	0 01/06/81-12/08/81
GR-B SUS	36	1.4	3.6 033/036	3.9 - 4.3	28 011/012	1.2 - 11.	4.3 - 11.	3.7 010/012	1.3 - 8.4	0 01/06/81-12/08/81
SR-89	36	1.1	LT 1.0 000/036	LT 2.0 -LT 2.0				LT 2.0 000/012	LT 1.0 -LT 2.0	0 01/06/81-12/08/81
SR-90	36	0.93	LT 0.90 000/036	LT 1.0 -LT 1.0				LT 0.90 000/012	LT 0.60 -LT 0.90	0 01/06/81-12/08/81
I-131	12	9.00	LT 500. 000/012	LT 600. -LT 600.				LT 500. 000/004	LT 90.0 -LT 500.	0 01/06/81-12/08/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY - WATERBORNE
 SAMPLE - WATER - RIVER
 UNITS - PCl/LITER

COMPILATION - ANNUAL SUMMARY
 CONTROL - STATION 12 - 0.1 MI. 360 DEG. CO

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES MEAN X E-00 RANGE	LOCATION WITH HIGHEST MEAN MEAN X E-00 RANGE	STATION FRACTION STATION DESCRIPTION	CONTROL LOCATION MEAN X E-00 RANGE	NON-ROUTINE REPORTING PERIOD

	FRACTION				FRACTION	

CS-137	12	9.00	LT 6.00 -LT 9.00 000/012	13 STATION 13 - 0.25 MI. 120 DEG. IND.	LT 5.00 -LT 6.00 000/004	0 01/06/81-12/08/81
H-3	12	140.	270. 012/012	320. 300. 320.	270. 200. 340.	0 01/06/81-12/08/81

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- INGESTION
 SAMPLE - RABBITS - ANIMALS
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES MEAN X E-00 RANGE FRACTION	LOCATION WITH HIGHEST MEAN		CONTROL LOCATION MEAN X E-00 RANGE FRACTION	NON- ROUTINE	REPORTING PERIOD
				STATION FRACTION	STATION DESCRIPTION			
I-131	4	LT 0.30 000/004	LT 0.70 -LT 0.70	28	002/002 STATION 28 - 1.8 MI. 150 DEG. IND.	0.13 0.086 - 0.18		0 11/05/81-11/09/81
SR-29	4	LT 0.10 000/004	LT 0.20 -LT 0.20					0 11/05/81-11/09/81
SR-90	4	0.11 004/004	0.12 - 0.13	28	002/002 STATION 28 - 1.8 MI. 150 DEG. IND.	0.13 0.086 - 0.18		0 11/05/81-11/09/81
X-40	4	3.01 004/004	3.11 - 3.21	28	002/002 STATION 28 - 1.8 MI. 150 DEG. IND.	3.21 2.96 - 3.46		0 11/05/81-11/09/81
I-131	4	LT 0.0900 000/004	LT 0.100 -LT 0.100		BY Ge(Li) SPECTROMETER			0 11/05/81-11/09/81
CS-137	4	LT 0.0400 000/004	LT 0.0600 -LT 0.0600					0 11/05/81-11/09/81

30

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- AQUATIC
 SAMPLE - VEGETATION - AQUATIC
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL - STATION 12 - 0.1 MI. 360 DEG. CC

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN			CONTROL LOCATION		NON- RCLTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION	FRACTION	MEAN X E-00	RANGE	FRACTION		
			FRACTION		STATION DESCRIPTION						
GR-2	2		3.6	3.8 - 4.0	28	001/001	4.0 - 4.0	3.6	3.6 - 3.6		0 10/17/81-10/17/81
			002/002		STATION 28 - 1.8 MI. 150 DEG. IND.			001/001			
SR-27	2		LT 0.020	0.020 -LT 0.020				LT 0.020	0.020 -LT 0.020		0 10/17/81-10/17/81
			000/002					000/001			
SR-90	2		LT 0.0080	0.0080 -LT 0.010				LT 0.0080	0.0080 -LT 0.0080		0 10/17/81-10/17/81
			000/002					000/001			
K-40	2		3.87	3.87 - 3.87	28	001/001	3.87 - 3.87	LT 2.00	2.00 -LT 2.00		0 10/17/81-10/17/81
			001/002		STATION 28 - 1.8 MI. 150 DEG. IND.			000/001			
MA-54	2		0.303	0.350 - 0.398	28	001/001	0.398 - 0.398	0.303	0.303 - 0.303		0 10/17/81-10/17/81
			002/002		STATION 28 - 1.8 MI. 150 DEG. IND.			001/001			
CC-58	2		0.466	0.517 - 0.568	12	001/001	0.568 - 0.568	0.568	0.568 - 0.568		0 10/17/81-10/17/81
			002/002		STATION 12 - 0.1 MI. 360 DEG. CCN.			001/001			
CC-60	2		0.660	0.767 - 0.875	12	001/001	0.875 - 0.875	0.875	0.875 - 0.875		0 10/17/81-10/17/81
			002/002		STATION 12 - 0.1 MI. 360 DEG. CCN.			001/001			

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- AQUATIC
 SAMPLE - VEGETATION - AQUATIC
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL - STATION 12 - 0.1 MI. 360 DEG. CO

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION		NON-ROUTINE	REPORTING PERIOD
		DETECTION	MEAN X E-00	STATION FRACTION	MEAN X E-00	MEAN X E-00	RANGE		
		MEAN X E-00	RANGE	STATION FRACTION	RANGE	FRACTION			
		FRACTION		STATION DESCRIPTION		FRACTION			

I-131	2	LT 0.200	LT 0.200			LT 0.200			0 10/17/81-10/17/81
		-LT 0.200	-LT 0.200			-LT 0.200			
		000/002				000/001			
CS-137	2	LT 0.0900	LT 0.100			LT 0.100			0 10/17/81-10/17/81
		-LT 0.0900	-LT 0.100			-LT 0.100			
		000/002				000/001			

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- AIRBORNE
 SAMPLE - S O I L
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN				CONTROL LOCATION MEAN X E-00 RANGE	NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	FRACTION	STATION	FRACTION	STATION DESCRIPTION			
SR-90	11	0.020		0.16				0.20			C 09/21/81-09/21/81
			0.079	-	0.20	08	001/001	0.20	-	0.20	
			009/011			STATION 08 - 2.5 MI. 260 DEG. INC.					
BE-7	11	0.230		0.720				0.720			C 09/21/81-09/21/81
			0.720	-	0.720	07	001/001	0.720	-	0.720	
			001/011			STATION 07 - 2.5 MI. 230 DEG. INC.					
K-40	11	0.470		17.1				19.6			C 09/21/81-09/21/81
			15.2	-	19.6	04	002/002	19.2	-	20.1	
			010/011			STATION 04 - 3.0 MI. 43 DEG. INC.					
ZR-95	11	0.0780		0.131				0.131			C 09/21/81-09/21/81
			0.131	-	0.131	07	001/001	0.131	-	0.131	
			001/011			STATION 07 - 2.5 MI. 230 DEG. INC.					
I-131	11	0.0310		0.300							C 09/21/81-09/21/81
			LT	-	0.300						
			0.200	-	0.300						
			000/011								
CS-137	11	0.0310		0.397				0.652			C 09/21/81-09/21/81
			0.0937	-	0.652	05	002/002	0.587	-	0.718	
			011/011			STATION 05 - 3.5 MI. 102 DEG. INC.					
RA-226	11	0.110		1.89				2.78			C 09/21/81-09/21/81
			1.34	-	2.78	08	001/001	2.78	-	2.78	
			011/011			STATION 08 - 2.5 MI. 260 DEG. INC.					

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- AIRBORNE
 SAMPLE - S O I L
 UNITS - PCI/GM WET

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS	NO	LIMIT OF DETECTION MEAN X E-00	ALL INDICATOR SAMPLES		LOCATION WITH HIGHEST MEAN		CONTROL LOCATION		NON- ROUTINE	REPORTING PERIOD
			MEAN X E-00	RANGE	STATION FRACTION	STATION DESCRIPTION	MEAN X E-00	RANGE		

TH-228	11	0.110	0.825	1.13	1.64	08	CC1/001	1.64	-	1.64	0 09/21/81-C9/21/81
			011/011				STATION 08 - 2.5 MI. 260 DEG. IND.				

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM SUMMARY

PATHWAY- GAMMA EXPOSURE
 SAMPLE - ENVIRONMENTAL TLD
 UNITS - MR/YEAR

COMPILATION - ANNUAL SUMMARY
 CONTROL -

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION

ANALYSIS NO LIMIT OF ALL INDICATOR SAMPLES LOCATION WITH HIGHEST MEAN CONTROL LOCATION NON- REPORTING PERIOD
 DETECTION MEAN X E-00 STATION FRACTION MEAN X E-00 ROUTINE
 MEAN X E-00 RANGE STATION DESCRIPTION RANGE FRACTION
 FRACTION

01/02/81 - 01/04/82

148

81

2mR

64

TLD

Exposure/year 71 - 148 STATION 01
 064/064 01 0.1 MI. 225 DEG. IND.

DISCUSSION, IMPACT ON THE ENVIRONMENT
AND
STATISTICAL TABLES

A and B. AIR PARTICULATE SAMPLES - GROSS BETA AND GROSS ALPHA

(See Tables A-1 - A-4, B-1 - B-4

STATIONS 01 to 10

Air particulates were collected continuously on membrane filters which were changed weekly at Stations 01 through 10. The filters were shipped to Teledyne Isotopes and analyzed for gross beta and gross alpha. They were composited for each station quarterly and monitored for gamma activity (See Tables D-1 and D-2).

The gross beta activity for each quarter since July 1980 is summarized below:

1980 Third Quarter	0.029 pCi/Cu. M.
October 16 Chinese Atmospheric Nuclear Tests	
Fourth Quarter	0.053 pCi/Cu. M.
1981 First Quarter	0.130 pCi/Cu. M.
Second Quarter	0.260 pCi/Cu. M.
Third Quarter	0.053 pCi/Cu. M.
Fourth Quarter	0.033 pCi/Cu. M.

It is indicated by these averages that the level of gross beta activity rose sharply after the Chinese atmospheric nuclear tests of October 16, 1980. The activity reached a high in the second quarter of 1981 and is now tapering off to a level similar to that before the tests. This trend has been observed in many areas of the United States. It may be concluded that this increased activity was caused by fallout from the Chinese nuclear tests and not from the operations of CNS.

The gross alpha activity (Tables B-1 through B-4) continues low and close to the limits of detection. This low gross alpha activity is probably due to alpha emitters found in soil and cosmogenic radiation.

One air particulate filter for the second quarter was not included in the averages because the blue paper was not removed and no air was drawn through the filter.

<u>STATION</u>	<u>FILTER</u>	<u>COLLECTION PERIOD</u>	<u>REASON</u>
09	AP	04/20 - 04/27	No air drawn through

TABLE A-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPEP NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 AIR PARTICULATE FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 FIRST QUARTER 1981
 (JANUARY-MARCH)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 12/29/80-02/03/81	MONTHLY SUMMARY 02/03/81-03/02/81	MONTHLY SUMMARY 03/02/81-03/30/81	QUARTERLY SUMMARY 12/29/80-03/30/81
A. P. FILTERS GROSS BETA	01	1.0 ± 0.8 E-01	9.5 ± 1.2 E-02	1.6 ± 0.5 E-01	1.2 ± 0.6 E-01
	02	1.6 ± 0.7 E-01	1.3 ± 0.9 E-01	3.1 ± 1.2 E-01	2.1 ± 1.0 E-01
	03	1.3 ± 0.6 E-01	1.1 ± 0.2 E-01	1.7 ± 0.6 E-01	1.3 ± 0.5 E-01
	04	1.2 ± 0.5 E-01	1.2 ± 0.3 E-01	2.1 ± 0.8 E-01	1.5 ± 0.7 E-01
	05	8.0 ± 3.0 E-02	5.1 ± 0.8 E-02	4.5 ± 3.3 E-02	6.1 ± 3.1 E-02
	06	1.2 ± 0.6 E-01	1.3 ± 0.6 E-01	1.7 ± 0.5 E-01	1.4 ± 0.6 E-01
	07	1.2 ± 0.5 E-01	8.2 ± 1.3 E-02	7.6 ± 2.0 E-02	9.5 ± 3.7 E-02
	08	1.2 ± 1.0 E-01	1.3 ± 0.5 E-01	2.6 ± 1.0 E-01	1.8 ± 0.9 E-01
	09	9.0 ± 4.0 E-02	7.5 ± 3.2 E-02	7.5 ± 2.0 E-02	7.8 ± 3.2 E-02
	10	1.6 ± 1.7 E-01	1.2 ± 0.3 E-01	2.1 ± 0.5 E-01	1.6 ± 1.1 E-01
GROSS BETA	01-10	1.2 ± 0.8 E-01	1.0 ± 0.4 E-01	1.7 ± 1.0 E-01	1.3 ± 0.8 E-01

\bar{x} and s

Grand \bar{x} and s

TABLE A-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATH - AIRBORNE
 AIR PARTICULATE FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 SECOND QUARTER 1981
 (APRIL-JUNE)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 03/30/81-04/27/81	MONTHLY SUMMARY 04/27/81-06/01/81	MONTHLY SUMMARY 06/01/81-06/29/81	QUARTERLY SUMMARY 03/30/81-06/29/81
A.P. FILTERS GROSS BETA	01	2.5 ± 0.8 E-01	3.5 ± 0.6 E-01	2.6 ± 1.1 E-01	2.9 ± 0.9 E-01
	02	3.7 ± 0.5 E-01	3.5 ± 0.6 E-01	2.0 ± 0.6 E-01	3.1 ± 1.0 E-01
	03	2.7 ± 0.7 E-01	2.6 ± 0.7 E-01	1.2 ± 0.3 E-01	2.2 ± 0.9 E-01
	04	3.2 ± 0.7 E-01	3.4 ± 0.6 E-01	1.9 ± 0.5 E-01	2.8 ± 0.9 E-01
	05	2.7 ± 1.6 E-01	3.5 ± 0.8 E-01	1.9 ± 0.6 E-01	2.8 ± 1.2 E-01
	06	2.9 ± 0.7 E-01	3.1 ± 0.6 E-01	1.8 ± 0.4 E-01	2.6 ± 0.8 E-01
	07	1.7 ± 1.1 E-01	2.7 ± 0.6 E-01	1.3 ± 0.4 E-01	1.9 ± 0.9 E-01
	08	3.2 ± 0.6 E-01	3.0 ± 0.5 E-01	1.7 ± 0.5 E-01	2.7 ± 0.8 E-01
	09	1.4 ± 1.1 E-01 (a)	3.1 ± 0.6 E-01	1.9 ± 0.5 E-01	2.2 ± 1.0 E-01
	10	3.5 ± 0.5 E-01	2.7 ± 0.6 E-01	1.4 ± 0.4 E-01	2.6 ± 0.9 E-01
GROSS BETA	01-10	2.8 ± 1.0 E-01	3.1 ± 0.7 E-01	1.7 ± 0.6 E-01	2.6 ± 1.0 E-01
	\bar{x} and s				Grand \bar{x} and s

(a) Week of 04/20-04/27 not included in averages; no flow of air, blocked by blue paper.

TABLE A-3
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 AIR PARTICULATE FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 THIRD QUARTER 1981
 (JULY-SEPTEMBER)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 06/29/81-08/03/81	MONTHLY SUMMARY 08/03/81-08/31/81	MONTHLY SUMMARY 08/31/81-09/28/81	QUARTERLY SUMMARY 06/29/81-09/28/81
A.P. FILTERS GROSS BETA	01	8.3 ± 4.8 E-02	6.4 ± 1.5 E-02	3.6 ± 0.5 E-02	6.3 ± 3.5 E-02
	02	7.9 ± 6.1 E-02	6.2 ± 1.6 E-02	4.6 ± 0.5 E-02	6.3 ± 3.9 E-02
	03	5.5 ± 2.1 E-02	5.5 ± 1.8 E-02	2.6 ± 0.3 E-02	4.6 ± 2.1 E-02
	04	7.3 ± 4.7 E-02	4.8 ± 1.2 E-02	4.3 ± 0.2 E-02	5.6 ± 0.3 E-02
	05	6.6 ± 3.9 E-02	4.1 ± 0.9 E-02	2.9 ± 0.2 E-02	4.7 ± 2.8 E-02
	06	7.3 ± 4.5 E-02	5.2 ± 1.3 E-02	3.3 ± 1.1 E-02	5.4 ± 3.2 E-02
	07	4.1 ± 3.0 E-02	1.9 ± 0.3 E-02	9.6 ± 2.9 E-03	2.4 ± 2.2 E-02
	08	7.7 ± 4.5 E-02	4.7 ± 1.0 E-02	3.0 ± 0.3 E-02	5.3 ± 3.3 E-02
	09	7.1 ± 4.1 E-02	5.7 ± 1.3 E-02	3.7 ± 0.1 E-02	5.6 ± 2.8 E-02
	10	5.6 ± 3.1 E-02	4.4 ± 0.9 E-02	2.8 ± 0.4 E-02	4.4 ± 2.2 E-02
GROSS BETA	01-10	7.3 ± 6.0 E-02	4.9 ± 1.7 E-02	3.1 ± 1.2 E-02	5.3 ± 3.8 E-02

\bar{x} and s

Grand \bar{x} and s

TABLE A-4
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 AIR PARTICULATE FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 FOURTH QUARTER 1981
 (OCTOBER-DECEMBER)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 09/28/81-11/02/81	MONTHLY SUMMARY 11/02/81-11/30/81	MONTHLY SUMMARY 11/30/81-12/28/81	QUARTERLY SUMMARY 09/28/81-12/28/81
A.P. FILTERS GROSS BETA	01	3.4 ± 0.5 E-02	3.2 ± 0.8 E-02	2.7 ± 0.9 E-02	3.1 ± 0.7 E-02
	02	3.2 ± 0.6 E-02	3.5 ± 0.6 E-02	3.9 ± 1.4 E-02	3.5 ± 0.9 E-02
	03	2.9 ± 0.7 E-02	2.9 ± 0.5 E-02	3.3 ± 1.0 E-02	3.1 ± 0.7 E-02
	04	3.5 ± 0.8 E-02	3.6 ± 0.8 E-02	4.1 ± 1.3 E-02	3.7 ± 0.9 E-02
	05	3.3 ± 0.4 E-02	3.1 ± 0.9 E-02	2.9 ± 1.0 E-02	3.1 ± 0.7 E-02
	06	3.0 ± 0.4 E-02	3.3 ± 0.8 E-02	3.5 ± 1.3 E-02	3.3 ± 0.8 E-02
	07	3.0 ± 0.4 E-02	3.2 ± 0.6 E-02	3.6 ± 1.4 E-02	3.2 ± 0.9 E-02
	08	2.8 ± 0.3 E-02	3.2 ± 0.7 E-02	3.5 ± 0.9 E-02	3.1 ± 0.7 E-02
	09	3.2 ± 0.5 E-02	3.1 ± 0.7 E-02	3.0 ± 0.8 E-02	3.1 ± 0.6 E-02
	10	3.3 ± 0.5 E-02	3.5 ± 0.7 E-02	3.3 ± 0.9 E-02	3.3 ± 0.6 E-02
GROSS BETA	01-10	3.2 ± 0.5 E-02	3.3 ± 0.6 E-02	3.4 ± 1.1 E-02	3.3 ± 0.8 E-02
		$\bar{x} \pm s$			Grand $\bar{x} \pm s$

TABLE B-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 AIR PARTICULATE FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 FIRST QUARTER 1981
 (JANUARY-MARCH)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 12/29/80-02/03/81	MONTHLY SUMMARY 02/03/81-03/02/81	MONTHLY SUMMARY 03/02/81-03/30/81	QUARTERLY SUMMARY 12/29/80-03/30/81
A.P. FILTERS GROSS ALPHA	01	1.9 ± 0.7 E-03	1.7 ± 0.5 E-03	2.3 ± 0.5 E-03	2.0 ± 0.6 E-03
	02	2.2 ± 0.9 E-03	2.7 ± 2.1 E-03	2.7 ± 1.2 E-03	2.5 ± 1.3 E-03
	03	2.2 ± 0.8 E-03	2.0 ± 0.7 E-03	2.1 ± 0.2 E-03	2.1 ± 0.6 E-03
	04	2.2 ± 0.8 E-03	2.2 ± 0.7 E-03	2.2 ± 0.4 E-03	2.2 ± 0.6 E-03
	05	1.9 ± 0.5 E-03	1.7 ± 0.5 E-03	2.0 ± 0.0 E-03	1.8 ± 0.4 E-03
	06	2.1 ± 1.0 E-03	2.5 ± 1.3 E-03	2.8 ± 1.3 E-03	2.4 ± 1.1 E-03
	07	2.0 ± 0.6 E-03	1.9 ± 0.3 E-03	2.3 ± 0.5 E-03	2.0 ± 0.5 E-03
	08	1.9 ± 0.5 E-03	2.3 ± 0.7 E-03	3.2 ± 2.4 E-03	2.4 ± 1.4 E-03
	09	2.2 ± 1.1 E-03	1.6 ± 0.6 E-03	2.2 ± 0.3 E-03	2.0 ± 0.8 E-03
	10	3.2 ± 2.0 E-03	2.7 ± 0.9 E-03	2.3 ± 0.7 E-03	2.8 ± 1.3 E-03
GROSS ALPHA	01-10	2.2 ± 1.0 E-03	2.1 ± 0.9 E-03	2.4 ± 0.9 E-03	2.2 ± 1.0 E-03

\bar{x} and s

Grand \bar{x} and s

TABLE B-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 AIR PARTICULATE FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 SECOND QUARTER 1981
 (APRIL-JUNE)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 03/31/81-04/27/81	MONTHLY SUMMARY 04/27/81-06/01/81	MONTHLY SUMMARY 06/01/81-06/29/81	QUARTERLY SUMMARY 03/30/81-06/29-81
A.P. FILTERS GROSS ALPHA	01	2.2 ± 0.3 E-03	2.6 ± 0.7 E-03	1.7 ± 0.5 E-03	2.2 ± 0.6 E-03
	02	1.9 ± 0.6 E-03	1.5 ± 0.8 E-03	1.8 ± 0.8 E-03	1.8 ± 0.5 E-03
	03	2.7 ± 2.1 E-03	2.0 ± 0.5 E-03	1.2 ± 0.3 E-03	2.0 ± 1.2 E-03
	04	1.8 ± 0.4 E-03	1.8 ± 0.4 E-03	1.9 ± 0.2 E-03	1.8 ± 0.3 E-03
	05	2.2 ± 0.4 E-03	2.4 ± 0.4 E-03	1.3 ± 0.5 E-03	2.0 ± 0.6 E-03
	06	1.9 ± 0.6 E-03	1.6 ± 0.5 E-03	1.4 ± 0.5 E-03	1.6 ± 0.5 E-03
	07	1.7 ± 0.5 E-03	1.8 ± 0.4 E-03	1.8 ± 0.6 E-03	1.8 ± 0.5 E-03
	08	1.8 ± 0.6 E-03	1.9 ± 0.8 E-03	1.7 ± 0.5 E-03	1.8 ± 0.6 E-03
	09	1.5 ± 0.6 E-03 (a)	2.0 ± 0.1 E-03	1.6 ± 0.4 E-03	1.7 ± 0.4 E-03
	10	2.4 ± 0.4 E-03	2.9 ± 0.7 E-03	2.3 ± 1.1 E-03	2.5 ± 0.8 E-03
GROSS ALPHA	01-10	2.0 ± 0.8 E-03	2.1 ± 0.6 E-03	1.7 ± 0.6 E-03	1.9 ± 0.7 E-03
	\bar{x} and s				Grand \bar{x} and s

(a) Week of 04/20-04/27 not included in averages; no flow of air, blocked by blue paper.

TABLE B-3
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 AIR PARTICULATE FILTERS
 PCl/Cu, M.

WEEKLY COLLECTIONS
 THIRD QUARTER 1981
 (JULY-SEPTEMBER)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 06/29/81-08/05/81	MONTHLY SUMMARY 08/03/81-08/31/81	MONTHLY SUMMARY 08/31/81-09/28/81	QUARTERLY SUMMARY 06/29/81-09/28/81
AP FILTERS GROSS ALPHA	01	1.5 ± 0.5 E-03	1.8 ± 0.5 E-03	2.1 ± 0.5 E-03	1.7 ± 0.5 E-03
	02	1.4 ± 0.5 E-03	2.1 ± 0.7 E-03	2.3 ± 0.9 E-03	1.9 ± 0.8 E-03
	03	1.1 ± 0.2 E-03	2.1 ± 0.6 E-03	1.9 ± 0.7 E-03	1.7 ± 0.7 E-03
	04	1.5 ± 0.6 E-03	1.6 ± 0.5 E-03	1.9 ± 0.2 E-03	1.6 ± 0.5 E-03
	05	1.2 ± 0.2 E-03	1.7 ± 0.5 E-03	2.2 ± 0.8 E-03	1.6 ± 0.7 E-03
	06	1.6 ± 0.5 E-03	1.7 ± 0.5 E-03	2.2 ± 0.9 E-03	1.8 ± 0.7 E-03
	07	1.2 ± 0.3 E-03	1.6 ± 0.5 E-03	1.6 ± 0.5 E-03	1.4 ± 0.5 E-03
	08	2.8 ± 2.2 E-03	2.0 ± 0.0 E-03	2.1 ± 0.8 E-03	2.3 ± 1.4 E-03
	09	1.2 ± 0.3 E-03	1.9 ± 0.2 E-03	1.9 ± 0.6 E-03	1.6 ± 0.5 E-03
	10	1.6 ± 0.7 E-03	1.8 ± 0.7 E-03	1.7 ± 0.3 E-03	1.7 ± 0.6 E-03
GROSS ALPHA	01-10	1.5 ± 0.9 E-03	1.8 ± 0.5 E-03	2.0 ± 0.6 E-03	1.8 ± 0.7 E-03

\bar{x} and s

Grand \bar{x} and s

TABLE B-4
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 AIR PARTICULATE FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 FOURTH QUARTER 1981
 (OCTOBER-DECEMBER)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 09/28/81-11/02/81	MONTHLY SUMMARY 11/02/81-11/30/81	MONTHLY SUMMARY 11/30/81-12/28/81	QUARTERLY SUMMARY 09/28/81-12/28/81
A.P. FILTERS GROSS ALPHA	01	2.0 ± 0.5 E-03	1.2 ± 0.7 E-03	2.0 ± 0.2 E-03	2.0 ± 0.5 E-03
	02	1.7 ± 0.6 E-03	1.7 ± 0.5 E-03	2.2 ± 0.5 E-03	1.8 ± 0.6 E-03
	03	1.9 ± 0.6 E-03	2.3 ± 0.4 E-03	1.6 ± 0.4 E-03	1.9 ± 0.5 E-03
	04	2.0 ± 0.3 E-03	2.0 ± 0.1 E-03	2.6 ± 0.4 E-03	2.2 ± 0.4 E-03
	05	1.4 ± 0.5 E-03	2.2 ± 0.7 E-03	1.8 ± 0.6 E-03	1.8 ± 0.6 E-03
	06	1.7 ± 0.7 E-03	1.7 ± 0.5 E-03	2.3 ± 0.7 E-03	1.9 ± 0.6 E-03
	07	1.9 ± 0.6 E-03	2.3 ± 0.4 E-03	2.0 ± 0.3 E-03	2.0 ± 0.5 E-03
	08	1.8 ± 0.5 E-03	2.1 ± 0.9 E-03	2.1 ± 0.2 E-03	2.0 ± 0.6 E-03
	09	1.6 ± 0.5 E-03	1.8 ± 0.6 E-03	2.0 ± 0.3 E-03	1.8 ± 0.5 E-03
	10	2.1 ± 0.8 E-03	1.9 ± 0.6 E-03	3.0 ± 0.8 E-03	2.3 ± 0.9 E-03
GROSS ALPHA	01-10	1.8 ± 0.6 E-03	2.0 ± 0.5 E-03	2.1 ± 0.6 E-03	2.0 ± 0.6 E-03
	\bar{x} and s				Grand \bar{x} and s

C. AIR RADIOIODINE - CHARCOAL FILTERS (See Tables C-1 through C-4)

STATIONS 01 to 10

Charcoal filters used in series with air particulate filters were collected weekly during 1981 at station 01 through 10 and monitored for radioiodine.

Tables C-1 through C-4 show the average monthly and quarterly results for each station and for all 10 stations. No airborne I-131 was detected; all results were at or below the minimum level of detection.

The fact that no airborne I-131 was detected in charcoal filters during 1981 supports the fact that the increase in beta activity, summarized in Parts A and B was due to the Chinese atmospheric nuclear tests and not from any releases by CNS.

TABLE C-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 CHARCOAL FILTERS
 pCi/Cu.M.

WEEKLY COLLECTIONS
 FIRST QUARTER 1981
 (JANUARY-MARCH)

SAMPLE NUCLIDE	STATION NUMBER	MEAN		AND	STANDARD		DEVIATION		QUARTERLY SUMMARY 12/29/80-03/30/81	DET/ TOTAL	RANGE				
		MONTHLY SUMMARY 12/29/80-02/03/81			MONTHLY SUMMARY 02/05/81-03/02/81		MONTHLY SUMMARY 03/02/81-03/03/81								
Charcoal Filters I-131	01	L.T.	4.	E-02	L.T.	7.	E-02	L.T.	3.	E-02	L.T.	6.	E-02	0/13	(L.T.3.-L.T.6.)E-02
	02	L.T.	4.	E-02	L.T.	6.	E-02	L.T.	3.	E-02	L.T.	6.	E-02	0/13	(L.T.3.-L.T.6.)E-02
	03	L.T.	4.	E-02	L.T.	6.	E-02	L.T.	3.	E-02	L.T.	6.	E-02	0/13	(L.T.3.-L.T.6.)E-02
	04	L.T.	4.	E-02	L.T.	6.	E-02	L.T.	3.	E-02	L.T.	6.	E-02	0/13	(L.T.3.-L.T.6.)E-02
	05	L.T.	3.	E-02	L.T.	5.	E-02	L.T.	3.	E-02	L.T.	5.	E-02	0/13	(L.T.3.-L.T.5.)E-02
	06	L.T.	4.	E-02	L.T.	6.	E-02	L.T.	4.	E-02	L.T.	6.	E-02	0/13	(L.T.4.-L.T.6.)E-02
	07	L.T.	4.	E-02	L.T.	6.	E-02	L.T.	4.	E-02	L.T.	6.	E-02	0/13	(L.T.4.-L.T.6.)E-02
	08	L.T.	5.	E-02	L.T.	6.	E-02	L.T.	4.	E-02	L.T.	6.	E-02	0/13	(L.T.4.-L.T.6.)E-02
	09	L.T.	4.	E-02	L.T.	6.	E-02	L.T.	4.	E-02	L.T.	6.	E-02	0/13	(L.T.4.-L.T.6.)E-02
	10	L.T.	3.	E-02	L.T.	4.	E-02	L.T.	2.	E-02	L.T.	4.	E-02	0/13	(L.T.2.-L.T.4.)E-02
01-10	L.T.	5.	E-02	L.T.	6.	E-02	L.T.	4.	E-02	L.T.	6.	E-02	-	-	
DET./TOTAL	0/50			0/40			0/40			0/130			0/130	-	-
RANGE	(L.T.3.-L.T.5.)E-02			(L.T.4.-L.T.6.)E-02			(L.T.2.-L.T.4.)E-02			(L.T.4.-L.T.6.)E-02			-	-	-

TABLE C-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 CHARCOAL FILTERS
 pCi/Cu.M.

WEEKLY COLLECTIONS
 SECOND QUARTER 1981
 (APRIL-JUNE)

SAMPLE NUCLIDE	STATION NUMBER	MEAN		AND	STANDARD		DEVIATION		QUARTERLY SUMMARY 03/30/81-06/29/81	DET/ TOTAL	RANGE
		MONTHLY SUMMARY 03/30/81-04/27/81	MONTHLY SUMMARY 04/27/81-06/01/81		MONTHLY SUMMARY 06/01/81-06/29/81	MONTHLY SUMMARY 06/01/81-06/29/81					
Charcoal Filters I-131	01	L.T. 3.	E-02	L.T. 4.	E-02	L.T. 3.	E-02	L.T. 4.	E-02	0/13	(L.T.3.-L.T.4.)E-02
	02	L.T. 3.	E-02	L.T. 4.	E-02	L.T. 3.	E-02	L.T. 4.	E-02	0/13	(L.T.3.-L.T.4.)E-02
	03	L.T. 4.	E-02	L.T. 4.	E-02	L.T. 3.	E-02	L.T. 4.	E-02	0/13	(L.T.3.-L.T.4.)E-02
	04	L.T. 4.	E-02	L.T. 4.	E-02	L.T. 3.	E-02	L.T. 4.	E-02	0/13	(L.T.3.-L.T.4.)E-02
	05	L.T. 3.	E-02	L.T. 3.	E-02	L.T. 3.	E-02	L.T. 3.	E-02	0/13	-
	06	L.T. 4.	E-02	L.T. 5.	E-02	L.T. 4.	E-02	L.T. 5.	E-02	0/13	(L.T.4.-L.T.5.)E-02
	07	L.T. 4.	E-02	L.T. 4.	E-02	L.T. 4.	E-02	L.T. 4.	E-02	0/13	-
	08	L.T. 4.	E-02	L.T. 4.	E-02	L.T. 4.	E-02	L.T. 4.	E-02	0/13	-
	09	L.T. 4.	E-02	L.T. 5.	E-02	L.T. 4.	E-02	L.T. 5.	E-02	0/13	(L.T.4.-L.T.5.)E-02
	10	L.T. 2.	E-02	L.T. 3.	E-02	L.T. 2.	E-02	L.T. 3.	E-02	0/13	(L.T.2.-L.T.3.)E-02
01-10	L.T. 4.	E-02	L.T. 5.	E-02	L.T. 4.	E-02	L.T. 5.	E-02	-	-	
DET./TOTAL	0/40		0/50		0/40		0/130		0/130	-	
RANGE	(L.T.2.-L.T.4.)E-02		(L.T.3.-L.T.5.)E-02		(L.T.2.-L.T.4.)E-02		(L.T.3.-L.T.5.)E-02		-	-	

TABLE C-3
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 CHARCOAL FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 THIRD QUARTER 1981
 (JULY-SEPTEMBER)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY 06/29/81-08/03/81	MONTHLY SUMMARY 08/03/81-08/31/81	MONTHLY SUMMARY 08/31/81-09/28/81	QUARTERLY SUMMARY 06/29/81-09/28/81	DET TOTAL	RANGE
CHARCOAL FILTERS I-131	01	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	0/13	(L.T.3.-L.T.4.)E-02
	02	L.T. 3. E-02	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	0/13	(L.T.3.-L.T.4.)E-02
	03	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	0/13	(L.T.3.-L.T.4.)E-02
	04	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	0/13	(L.T.3.-L.T.4.)E-02
	05	L.T. 3. E-02	L.T. 3. E-02	L.T. 4. E-02	L.T. 4. E-02	0/13	(L.T.2.-L.T.4.)E-02
	06	L.T. 4. E-02	L.T. 4. E-02	L.T. 1.4 E-01	L.T. 1.4 E-01	0/13	(L.T.0.4-L.T.1.4)E-01
	07	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	0/13	--
	08	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	0/13	(L.T.1.-L.T.4.)E-02
	09	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	L.T. 4. E-02	0/13	--
	10	L.T. 2. E-02	L.T. 3. E-02	L.T. 3. E-02	L.T. 3. E-02	0/13	(L.T.2.-L.T.3.)E-02
01-10		L.T. 4. E-02	L.T. 4. E-02	L.T. 7. E-02	L.T. 7. E-02	--	--
DET./TOTAL		0/50	0/40	0/40	0/130	0/130	--
RANGE		(L.T.2.-L.T.4.)E-02	(L.T.3.-L.T.4.)E-02	(L.T.3.-L.T.4.)E-02	(L.T.3.-L.T.7.)E-02	--	--

TABLE C-4
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 CHARCOAL FILTERS
 pCi/Cu. M.

WEEKLY COLLECTIONS
 FOURTH QUARTER 1981
 (OCTOBER-DECEMBER)

SAMPLE NUCLIDE	STATION NUMBER	MONTHLY SUMMARY		MONTHLY SUMMARY		MONTHLY SUMMARY		QUARTERLY SUMMARY		DET	
		09/28/81-11/02/81		11/02/81-11/30/81		11/30/81-12/28/81		09/28/81-12/28/81		TOTAL RANGE	
Charcoal Filters I-131	01	L.T.	4. E-02	L.T.	5. E-02	L.T.	5. E-02	L.T.	5. E-02	0/13	(L.T.3.-L.T.5.)E-02
	02	L.T.	4. E-02	L.T.	5. E-02	L.T.	4. E-02	L.T.	5. E-02	0/13	(L.T.3.-L.T.5.)E-02
	03	L.T.	4. E-02	L.T.	5. E-02	L.T.	5. E-02	L.T.	5. E-02	0/13	(L.T.3.-L.T.5.)E-02
	04	L.T.	4. E-02	L.T.	5. E-02	L.T.	5. E-02	L.T.	5. E-02	0/13	(L.T.3.-L.T.5.)E-02
	05	L.T.	3. E-02	L.T.	4. E-02	L.T.	4. E-02	L.T.	4. E-02	0/13	(L.T.3.-L.T.4.)E-02
	06	L.T.	4. E-02	L.T.	6. E-02	L.T.	5. E-02	L.T.	6. E-02	0/13	(L.T.3.-L.T.6.)E-02
	07	L.T.	4. E-02	L.T.	7. E-02	L.T.	5. E-02	L.T.	7. E-02	0/13	(L.T.2.-L.T.7.)E-02
	08	L.T.	4. E-02	L.T.	6. E-02	L.T.	5. E-02	L.T.	6. E-02	0/13	(L.T.2.-L.T.6.)E-02
	09	L.T.	4. E-02	L.T.	6. E-02	L.T.	5. E-02	L.T.	6. E-02	0/13	(L.T.3.-L.T.6.)E-02
	10	L.T.	3. E-02	L.T.	3. E-02	L.T.	3. E-02	L.T.	3. E-02	0/13	(L.T.1.-L.T.3.)E-02
	01-10	L.T.	4. E-02	L.T.	7. E-02	L.T.	5. E-02	L.T.	7. E-02	--	--
	DET./TOTAL		0/50		0/40		0/40		0/130	0/130	--
	RANGE									--	--

D. COMPOSITE OF AIR PARTICULATE FILTERS - GAMMA

(See Tables D-1 and D-2)

STATIONS 01 to 10

Weekly Air Particulate filters were composited for each station for a quarterly gamma spectral analysis during the four quarters of 1981.

During the first two quarters there were detections of the fission product nuclides Zr-95, Ru-103, Ru-106, Cs-137, Ce-141 and Ce-144 at almost all 10 stations. These detections reached a peak in the second quarter of 1981 dropping off considerably in the third quarter and entirely in the fourth quarter. These nuclides are a continuing trend from the fourth quarter of 1980 and occurred after the Chinese atmospheric nuclear tests of October 16, 1980. This same trend was noted in other areas of the United States which lends support to the conclusion that they are due to the Chinese nuclear test.

There were two detections of Co-60 at station 01 and 02 during the second quarter and eight detections of Mn-54. Upon further testing of the composite of Station 01, it was found that the detection of Co-60 was for the period June 22 through June 29. This correlates with the period of maximum fallout from the Chinese nuclear tests. The detections of Mn-54 were low being slightly above detection level. Berillium-7, which is naturally occurring, was detected at all stations at about the same level as previously.

The average of gross beta measurements for all stations reached a maximum of 0.260 pCi/Cu.M. during the second quarter of 1981 and fell to a level of 0.033 pCi/Cu. M. by the end of 1981. The I-131 measured in charcoal filters in series with the air particulate filter remained below the limit of detection. There was no correlation between the level of activity and the stations close to the plant. This would tend to support the conclusion that the nuclides detected were from the Chinese test of October 16, 1980 and were not associated with the operations of CNS.

TABLE D-1

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 COMPOSITE OF WEEKLY AIR PARTICULATE FILTERS
 pCi/Cu. M.

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
			12/29/80-03/30/81	03/30/81-06/29/81	06/29/81-09/28/81	09/28/81-12/28/81
Be-7	01-10	Mean	7.8 ±3.2 E-02	1.3 ±0.2 E-01	1.0 ±0.4 E-01	1.1 ±0.1 E-01
		std.dev.	10/10	10/10	10/10	10/10
		det./total	(2.7-12.6)E-02	(0.97-1.6)E-01	(0.32-1.0)E-01	(0.8-1.3)E-01
Mn-54	01-10	Mean	L.T. 9. E-04	1.7 ±0.3 E-03	L.T. 8. E-04	L.T. 8. E-04
		std.dev.	0/10	8/10	0/10	0/10
		det./total	--	(1.4-2.3)E-03	--	--
Co-60	01-10	Mean	L.T. 9. E-04	1.8 ±2.0 E-02	L.T. 7. E-04	L.T. 8. E-04
		std.dev.	0/10	2/10	0/10	0/10
		det./total	--	(0.3-3.2)E-02	--	--
Zr-95	01-10	Mean	5.0±2.4 E-02	6.1 ±2.7 E-02	L.T. 2. E-03	L.T. 2. E-03
		std.dev.	10/10	10/10	0/10	0/10
		det./total	(1.4-8.0)E-02	(2.5-10.1)E-02	--	--
Ru-103	01-10	Mean	2.0 ±1.0 E-02	1.7 ±0.3 E-02	2.2 ±1.3 E-02	L.T. 2. E-03
		std.dev.	10/10	10/10	1/10	0/10
		det./total	(0.63-3.8)E-02	(1.2-2.3)E-02	--	--
Ru-106	01-10	Mean	L.T. 1. E-02	1.8 ±0.3 E-02	L.T. 7. E-03	L.T. 8. E-03
		std.dev.	0/10	9/10	0/10	0/10
		det./total	--	(1.4-2.2)E-02	--	--
Cs-137	01-10	Mean	1.1 ±0.2 E-03	3.0 ±0.6 E-03	1.2 ±0.3 E-03	L.T. 8. E-04
		std.dev.	4/10	10/10	5/10	0/10
		det./total	(0.8-1.3)E-03	(1.8-3.7)E-03	(0.86-1.6)E-03	--
Cs-141	01-10	Mean	1.4 ±0.5 E-02	8.8 ±1.8 E-03	L.T. 4. E-03	L.T. 5. E-03
		std.dev.	10/10	10/10	0/10	0/10
		det./total	(0.63-2.4)E-02	(0.6-1.1)E-02	--	--
Ce-144	01-10	Mean	1.4 ±0.5 E-02	4.8 ±0.9 E-02	8.6 ±2.2 E-03	L.T. 6. E-03
		std.dev.	10/10	10/10	5/10	0/10
		det./total	(0.7-2.3)E-02	(3.6-6.3)E-02	(6.0-11.0)E-03	--

Note: Only nuclides with 2 or more detections during any of the four quarters are listed above.

See Table D-2 for gamma emitter nuclides below the limits of detection.

TABLE D-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 COMPOSITE OF WEEKLY AIR PARTICULATE FILTERS
 PCi/Cu. M.

SAMPLE NUCLIDE	STATION NUMBER	FIRST QUARTER 12/29/80-03/30/81		SECOND QUARTER 03/30/81-06/29/81		THIRD QUARTER 06/29/81-09/28/81		FOURTH QUARTER 09/28/81-12/28/81	
		Value	Filter	Value	Filter	Value	Filter	Value	Filter
Se-7	01-10	7.8 ± 3.2	E-02(10/10)	1.3 ± 0.2	E-01(10/10)	1.0 ± 0.4	E-01(10/10)	1.1 ± 0.1	E-01(10/10)
K-40	01-10	L.T.	E-02(0/10)	L.T.	E-02(0/10)	L.T.	E-02(0/10)	L.T.	E-02(0/10)
Mn-54	01-10	L.T.	E-04(0/10)	1.7 ± 0.3	E-03(8/10)	L.T.	E-04(0/10)	L.T.	E-04(0/10)
Co-58	01-10	L.T.	E-03(0/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)
Fe-59	01-10	L.T.	E-03(0/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)
Co-60	01-10	L.T.	E-04(0/10)	1.8 ± 2.0	E-02(2/10)	L.T.	E-03(0/10)	L.T.	E-04(0/10)
Zn-65	01-10	L.T.	E-03(0/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)
Zr-95	01-10	5.0 ± 2.4	E-02(10/10)	6.1 ± 2.7	E-02(10/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)
Ru-103	01-10	2.0 ± 1.0	E-02(10/10)	1.7 ± 0.5	E-02(10/10)	2.2 ± 1.3	E-02(1/10)	L.T.	E-03(0/10)
Ru-106	01-10	L.T.	E-02(0/10)	1.8 ± 0.5	E-02(9/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)
I-131	01-10	L.T.	E-01(0/10)	L.T.	E-01(0/10)	L.T.	E-01(0/10)	L.T.	E-01(0/10)
Cs-134	01-10	L.T.	E-04(0/10)	L.T.	E-04(0/10)	L.T.	E-04(0/10)	L.T.	E-04(0/10)
Cs-137	01-10	1.1 ± 0.2	E-03(4/10)	3.0 ± 0.6	E-03(10/10)	1.2 ± 0.3	E-03(5/10)	L.T.	E-04(0/10)
Ba-140	01-10	L.T.	E-02(0/10)	L.T.	E-02(0/10)	L.T.	E-02(0/10)	L.T.	E-02(0/10)
Cs-141	01-10	1.4 ± 0.5	E-02(10/10)	8.8 ± 1.8	E-03(10/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)
Ce-144	01-10	1.4 ± 0.5	E-02(10/10)	4.8 ± 0.9	E-02(10/10)	8.6 ± 2.2	E-03(9/10)	L.T.	E-03(0/10)
Ra-226	01-10	L.T.	E-02(0/10)	L.T.	E-02(0/10)	L.T.	E-02(0/10)	L.T.	E-02(0/10)
Th-232	01-10	L.T.	E-03(0/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)	L.T.	E-03(0/10)

E. EGGS (See Tables E1, E2)

STATIONS 42, 51, 67, 76

Egg samples were collected quarterly from four locations and analyzed for elemental calcium, gross beta, Sr-89, Sr-90 and gamma emitters. The gross beta measured 1.5 pCi per gram, wet, which was accounted for largely by the naturally occurring, terrestrial isotope K-40. No other gamma emitters were measured above the minimum level of detection. There were no detections of Sr-89 and 3 detections of Sr-90 in 16 samples at a level of 0.0017 pCi per gram, wet, which is below the minimum level of detection. The level of elemental calcium in 16 samples was 0.14 mg per gram which is similar to the levels of previous years.

There is no evidence of an effect from the operation of CNS on egg samples.

TABLE E-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 EGGS - pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter 01/12/81	2nd Quarter 04/13/81	3rd Quarter 07/20/81	4th Quarter 10/19/81
Gross Beta	42,51,67,76	Mean±std.dev. det./total range	1.1 ± 0.6 E 00 4/4 (0.7-2.0)E 00	2.1 ± 0.4 E 00 4/4 (1.6-2.5)E 00	1.1 ± 0.4 E 00 4/4 (0.8-1.6)E 00	2.0 ± 0.8 E 00 4/4 (1.0-2.9)E 00
Sr-89	42,51,67,76	Mean±std.dev. det./total range	L.T. 5. E-03 0/4 -	L.T. 6. E-03 0/4 -	L.T. 6. E-03 0/4 -	L.T. 6. E-03 0/4 -
Sr-90	42,51,67,76	Mean±std.dev. det./total range	1.7 ± 0.2 E-03 2/4 (1.6-1.8)E-03	1.9 ± 1.3 E-03 1/4 -	L.T. 4. E-03 0/4 -	L.T. 3. E-03 0/4 -
Ca (elem.) mg./gm.	42,51,67,76	Mean±std.dev. det./total range	4.1 ± 1.2 E-02 4/4 (2.9-5.5)E-02	6.3 ± 2.4 E-02 4/4 (3.9-9.3)E-02	1.2 ± 0.6 E-01 4/4 (0.6-1.7)E-01	3.8 ± 0.2 E-01 4/4 (1.4-5.9)E-01
K-40	42,51,67,76	Mean±std.dev. det./total range	1.0±0.1 E 00 4/4 (0.9-1.2)E 00	8.7 ± 0.7 E-01 4/4 (8.1-9.5)E-01	1.2 ± 0.1 E 00 4/4 (1.1-1.3)E 00	1.0 ± 0.1 E 00 4/4 (0.84-1.1)E 00

Note: No gamma activity above the limits of detection was monitored in eggs except for K-40. See Table E-2 for other gamma emitter nuclides monitored below the limits of detection.

TABLE E-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 EGGS - pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER	1st quarter 01/12/81	2nd quarter 04/13/81	3rd quarter 07/20/81	4th quarter 10/19/81
Be-7	42,51,67,76	L.T. 8. E-02 (0/4)	L.T. 7. E-02 (0/4)	L.T. 6. E-02 (0/4)	L.T. 6. E-02 (0/4)
K-40	42,51,67,76	1.0 +-0.1 E 00 (4/4)	8.7 +- 0.7E-01 (4/4)	1.2 +-0.1 E 00 (4/4)	1.0 +-0.1 E 00 (4/4)
Mn-54	42,51,67,76	L.T. 8. E-03 (0/4)	L.T. 7. E-03 (0/4)	L.T. 6. E-03 (0/4)	L.T. 6. E-03 (0/4)
Co-58	42,51,67,76	L.T. 8. E-03 (0/4)	L.T. 7. E-03 (0/4)	L.T. 7. E-03 (0/4)	L.T. 6. E-03 (0/4)
Fe-59	42,51,67,76	L.T. 2. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)
Co-60	42,51,67,76	L.T. 9. E-03 (0/4)	L.T. 8. E-03 (0/4)	L.T. 7. E-03 (0/4)	L.T. 6. E-03 (0/4)
Zn-65	42,51,67,76	L.T. 2. E-02 (0/4)	L.T. 2. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)
Zr-95	42,51,67,76	L.T. 8. E-03 (0/4)	L.T. 8. E-03 (0/4)	L.T. 7. E-03 (0/4)	L.T. 7. E-03 (0/4)
Ru-103	42,51,67,76	L.T. 1. E-02 (0/4)	L.T. 8. E-03 (0/4)	L.T. 7. E-03 (0/4)	L.T. 7. E-03 (0/4)
Ru-106	42,51,67,76	L.T. 8. E-02 (0/4)	L.T. 7. E-02 (0/4)	L.T. 6. E-02 (0/4)	L.T. 6. E-02 (0/4)
I-131	42,51,67,76	L.T. 2. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 2. E-02 (0/4)
Cs-134	42,51,67,76	L.T. 1. E-02 (0/4)	L.T. 8. E-03 (0/4)	L.T. 7. E-03 (0/4)	L.T. 7. E-03 (0/4)
Cs-137	42,51,67,76	L.T. 9. E-03 (0/4)	L.T. 8. E-03 (0/4)	L.T. 7. E-03 (0/4)	L.T. 7. E-03 (0/4)
Ba-140	42,51,67,76	L.T. 1. E-02 (0/4)	L.T. 9. E-03 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)
Co-141	42,51,67,76	L.T. 2. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)
Ce-144	42,51,67,76	L.T. 8. E-02 (0/4)	L.T. 6. E-02 (0/4)	L.T. 6. E-02 (0/4)	L.T. 6. E-02 (0/4)
Ra-226	42,51,67,76	L.T. 2. E-01 (0/4)	L.T. 1. E-01 (0/4)	L.T. 2. E-01 (0/4)	L.T. 2. E-01 (0/4)
Th-228	42,51,67,76	L.T. 2. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)	L.T. 1. E-02 (0/4)

F. FEED AND FORAGE - BEEF PRODUCERS (See Tables F-1 and F-2)

STATIONS 64, 65, 67, 68, 71, 76

Feed and forage samples were collected monthly from beef producers at six stations and radioassayed for gamma emitters. During peak pasture season (June through September) a monthly composite was made of the weekly samples received and also measured for gamma activity. Beryllium-7, of cosmic origin, was detected in 44 of 79 samples and the terrestrial nuclide K-40 was detected in 87 of 87 samples at the levels encountered in the past.

There were 2 detections of the neutron activation product Mn-54; one at station 68, 3.4 miles from the plant in the June composite and one at station 64, 2.25 miles from the plant in the July composite. Both of these were slightly above the minimum detection level. Manganese-54 has been seen in air particulate filters and was probably due to the fallout of nuclear debris.

The fission product nuclides Zr-95, Ru-103, Ru-106, Cs-137, Ce-141 and Ce-144 were detected in several samples (See Table F-1). These reached a peak in the second and third quarters and tapered off to a lower level in the fourth quarter.

The incidence of these fission nuclides was not at any one particular station nor was it related to distance from the plant. These same nuclides and the same trend to peak in the second and third quarters was noted in the composite of air particulate filters (See Section D). This suggests that the probable source of these nuclides is atmospheric fallout from the Chinese nuclear tests and is not related to the operations of CNS.

TABLE F-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FEED AND FORAGE - BEEF PRODUCERS - pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
			01/05/81-03/02/81	04/06/81-06/01/81	07/06/81-09/28/81	10/05/81-12/07/81
Cs-7	64,65,67,68,71,76	Mean	1.0±1.0E 00	2.3±1.1E 00	9.96±3.8E 00	4.0±2.9E 00
		std.dev.	4/21	7/18 (a)	20/27(b)	13/21
		det./total range	(0.1-2.6)E 00	(0.7-3.9)E 00	(2.3-17.3)E 00	(0.2-8.2)E 00
K-40	64,65,67,68,71,76	Mean	1.7±1.3E 01	1.6±1.2E 01	2.0±1.7E 01	9.8±10.0E 00
		std.dev.	21/21	18/18	27/27	21/21
		det./total range	(0.2-4.1)E 01	(0.2-4.7)E 01	(0.2-7.1)E 01	(2.4-39.6)E 00
Mn-54	64,65,67,68,71,76	Mean	L.T. 9. E-02	6.5±3.4E-02	9.7±5.7E-02	L.T. 7. E-02
		std.dev.	0/21	1/18	1/27	0/21
		det./total range	--	--	--	--
Zr-95	64,65,67,68,71,76	Mean	L.T. 1. E-01	9.8±0.4E-01	8.6±4.4E-01	2.2±0.2E-01
		std.dev.	0/21	7/18	13/27	1/21
		det./total range	--	(0.4-1.4)E 00	(0.24-1.8)E 00	--
Ru-103	64,65,67,68,71,76	Mean	L.T. 1. E-01	1.2±0.5E-01	2.0±0.2E-01	L.T. 7. E-02
		std.dev.	0/21	7/18	2/27	0/21
		det./total range	--	(0.6-2.1)E-01	(1.9-2.1)E-01	--
Ru-106	64,65,67,68,71,76	Mean	L.T. 9. E-01	7.5±3.7E-01	1.0±0.6E 00	L.T. 6. E-01
		std.dev.	0/21	1/18	1/27	0/21
		det./total range	--	--	--	--

(a) No sample was available from station 65 on 05/04 or 06/08. No QA composite could be prepared; therefore there are three fewer samples in the second quarter.

(b) There was no sample available at station 65 for July (07/06-07/27); therefore there is one less sample for the third quarter (27 rather than 28 total).

TABLE F-1

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

EXPOSURE PATHWAY - INGESTION

FEED AND FORAGE - BEEF PRODUCERS - pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter		2nd Quarter	3rd Quarter	4th Quarter
			01/05/81-03/02/81		04/06/81-06/01/81	07/06/81-09/28/81	10/05/81-12/07/81
Cs-137	64,65,67,68,71,76	Meantstd.dev.	L.T.	1. E-01	8.0±4.0E-02	1.7±0.7E-01	7.0±1.4E-02
		det./total		0/21	6/18	16/27	4/21
		range	--	--	(0.2-1.3)E-01	(0.9-3.0)E-01	--
Ce-141	64,65,67,68,71,76	Meantstd.dev.	L.T.	2. E-01	1.3±0.7E-01	L.T. 3. E-01	L.T. 1. E-01
		det./total		0/21	5/18	0/27	0/21
		range	--	--	(0.5-2.3)E-01	--	--
Ce- 44	64,65,67,68,71,76	Meantstd.dev.	L.T.	7. E-01	1.1±0.5E 00	1.4±0.8E 00	4.5±1.2E-01
		det./total		0/21	7/18	17/27	4/21
		range	--	--	(0.3-1.6)E 00	(0.5-2.9)E 00	(3.1-5.5)E-01
Th-228	64,65,67,68,71,76	Meantstd.dev.		2.1±1.4E-02	L.T. 2. E-01	L.T. 2. E-01	L.T. 1. E-01
		det./total		2/21	0/18	0/27	0/21
		range		(1.1-3.1)E-02	--	--	--

TABLE F-2

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

EXPOSURE PATHWAY - INGESTION

FEED AND FORAGE - BEEF PRODUCERS - pCi/gm. wet

SAMPLE NUCLIDE	STATION NUMBER	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
		01/05/81-03/02/81	04/06/81-06/01/81	07/06/81-09/28/81	10/05/81-12/07/81
Be-7	64,65,67,68,71,76	1.0 ±1.0 E 00 (4/21)	2.3 ±1.1 E 00 (7/18)	9.96±3.8 E 00 (20/27)	4.0 ±2.9 E 00 (15/21)
K-40	64,65,67,68,71,76	1.7 ±1.3 E 01(21/24)	1.6 ±1.2 E 01 (18/18)	2.0 ±1.7 E 01 (27/27)	9.8 ±10.0 E 00 (21/21)
Mn-54	64,65,67,68,71,76	L.T. 9. E-02 (0/21)	6.5 ±3.4 E-02 (1/18)	9.9 ±5.7 E-02 (1/27)	L.T. 7. E-02 (0/21)
Co-58	64,65,67,68,71,76	L.T. 1. E-01 (0/21)	L.T. 1. E-01 (0/18)	L.T. 1. E-01 (0/27)	L.T. 7. E-02 (0/21)
Fe-59	64,65,67,68,71,76	L.T. 2. E-01 (0/21)	L.T. 3. E-01 (0/18)	L.T. 3. E-01 (0/27)	L.T. 2. E-01 (0/21)
Co-60	64,65,67,68,71,76	L.T. 1. E-01 (0/21)	L.T. 1. E-01 (0/18)	L.T. 1. E-01 (0/27)	L.T. 8. E-02 (0/21)
Zn-65	64,65,67,68,71,76	L.T. 2. E-01 (0/21)	L.T. 3. E-01 (0/18)	L.T. 2. E-01 (0/27)	L.T. 2. E-01 (0/21)
Zr-95	64,65,67,68,71,76	L.T. 1. E-01 (0/21)	9.8 ±0.4 E-01 (7/18)	8.6 ±4.4 E-01 (13/27)	2.2 ±0.2 E-01 (1/21)
Ru-103	64,65,67,68,71,76	L.T. 1. E-01 (0/21)	1.2 ±0.5 E-01 (7/18)	2.0 ±0.2 E-01 (2/27)	L.T. 7. E-02 (0/21)
Ru-106	64,65,67,68,71,76	L.T. 9. E-01 (0/21)	7.5 ±3.7 E-01 (1/18)	1.0 ±0.6 E 00 (1/27)	L.T. 6. E-01 (0/21)
I-131	64,65,67,68,71,76	L.T. 2. E-01 (0/21)	L.T. 6. E-01 (0/18)	L.T. 2. E 00 (0/27)	L.T. 1. E-01 (0/21)
Cs-134	64,65,67,68,71,76	L.T. 1. E-01 (0/21)	L.T. 1. E-01 (0/18)	L.T. 1. E-01 (0/27)	L.T. 8. E-02 (0/21)
Cs-137	64,65,67,68,71,76	L.T. 1. E-01 (0/21)	8.0 ± 4.0 E-02 (6/18)	1.7 ± 0.7 E-01 (16/27)	7.0 ± 1.4 E-02 (4/21)
Ba-140	64,65,67,68,71,76	L.T. 1. E-01 (0/21)	L.T. 2. E-01 (0/18)	L.T. 5. E-01 (0/27)	L.T. 9. E-02 (0/21)
Ce-141	64,65,67,68,71,76	L.T. 2. E-01 (0/21)	1.3 ± 0.7 E-01 (5/18)	L.T. 3. E-01 (0/27)	L.T. 1. E-01 (0/21)
Ce-144	64,65,67,68,71,76	L.T. 7. E-01 (0/21)	1.1 ± 0.5 E 00 (7/18)	1.4 ± 0.8 E 00 (17/27)	4.5 ± 1.2 E-01 (4/21)
Ra-226	64,65,67,68,71,76	L.T. 2. E 00 (0/21)	L.T. 3. E 00 (0/18)	L.T. 2. E 00 (0/27)	L.T. 1. E 00 (0/21)
Th-228	64,65,67,68,71,76	2.1 ±1.4 E-02 (2/21)	L.T. 2. E-01 (0/18)	L.T. 2. E-01 (0/27)	L.T. 1. E-01 (0/21)

FOOD AND GARDEN CROPS (SEE TABLES G-1, G-2 and H-1, H-2)

G. STATIONS 53, 54 - APPLES

H. STATIONS 34, 56, 62 - GARDEN VEGETABLES (TOMATOES AND CUCUMBERS)

Garden crops and apples were radioassayed once during the year at harvest for gross beta, Sr-89, Sr-90, elemental calcium and gamma emitters. Detectable concentrations of gross beta, elemental calcium and K-40 were monitored in each sample and are the usual elements measured in food and garden crops. The results monitored during 1981 duplicate measurements conducted during previous years.

No Sr-90 was detected in apples. Strontium-90 was detected in two of three garden vegetable samples at an average level of 0.0016 pCi/gm, wet, which is below the minimum level of detection. There were no gamma emitters above the minimum levels of detection except K-40 as cited above. It may be concluded that there was no detectable effect on food and garden crops from the operations of CNS.

TABLE G-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FOOD AND GARDEN CROPS - pCi/gm, wet
 APPLES

SAMPLE NUCLIDE	STATION NUMBER		3rd quarter 09/14/81
Gross Beta	53, 54	Mean ± std. dev. det./total range	3.2 ± 0.4 E 00 2/2 (2.9-3.4) E 00
Sr-89	53, 54	Mean ± std. dev. det./total range	L.T. 4. E-03 0/2 --
Sr-90	53, 54	Mean ± std. dev. det./total range	L.T. 1. E-03 0/2 --
Ca(mg/gm wet)	53, 54	Mean ± std. dev. det./total range	3.7 ± 2.5 E-02 2/2 (1.9-5.4) E-02
K-40	53, 54	Mean ± std. dev. det./total range	1.4 ± 0.2 E 00 2/2 (1.3-1.6) E 00

K-40 is the only gamma emitter above the limits of detection. See Table G-2 for the list of gamma emitters monitored.

TABLE G-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FOOD AND GARDEN CROPS - pCi/gm, wet
 GAMMA SCAN
 APPLES

SAMPLE NUMBER	STATION NUMBER	3rd quarter 09/14/81
Be-7	53, 54	L.T. 1. E-01 (0/2)
K-40	53, 54	1.4 +-0.2 E 00 (2/2)
Mn-54	53, 54	L.T. 1. E-02 (0/2)
Co-58	53, 54	L.T. 1. E-02 (0/2)
Fe-59	53, 54	L.T. 3. E-02 (0/2)
Co-60	53, 54	L.T. 2. E-02 (0/2)
Zn-65	53, 54	L.T. 3. E-02 (0/2)
Zr-95	53, 54	L.T. 1. E-02 (0/2)
Ru-103	53, 54	L.T. 2. E-02 (0/2)
Ru-106	53, 54	L.T. 1. E-01 (0/2)
I-131	53, 54	L.T. 2. E-02 (0/2)
Cs-134	53, 54	L.T. 2. E-02 (0/2)
Cs-137	53, 54	L.T. 2. E-02 (0/2)
Ba-140	53, 54	L.T. 2. E-02 (0/2)
Ce-141	53, 54	L.T. 2. E-02 (0/2)
Ce-144	53, 54	L.T. 1. E-01 (0/2)
Ra-226	53, 54	L.T. 3. E-01 (0/2)
Th-228	53, 54	L.T. 3. E-02 (0/2)

TABLE H-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FOOD AND GARDEN CROPS - pCi/gm, wet
 GARDEN VEGETABLES

SAMPLE NUCLIDE	STATION NUMBER		3rd Quarter 08/10/81
Gross beta	34,56,62	Mean \pm std. dev. det./total range	4.4 \pm 0.7 E 00 3/3 (3.8-5.2) E 00
Sr-89	34,56,62	Mean \pm std. dev. det./total range	L.T. 2. E-03 0/3 --
Sr-90	34,56,62	Mean \pm std. dev. det./total range	1.6 \pm 0.1 E-03 2/3 (1.5-1.7) E-03
Ca (ng/gm wet)	34,56,62	Mean \pm std. dev. det./total range	1.6 \pm 0.8 E-01 (0.8-2.2) E-01 3/3
K-40	34,56,62	Mean \pm std. dev. det./total range	2.3 \pm 0.1 E 00 2/3 (2.2-2.3) E 00

K-40 is the only gamma emitter above the limits of detection. See Table H-2 for the list of gamma emitters monitored.

TABLE H-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FOOD AND GARDEN CROPS - pCi/gm. wet
 GARDEN VEGETABLES

SAMPLE NUCLIDE	STATION NUMBER	3rd Quarter 08/10/81
Be-7	34,56,62	L.T. 9.E-02 (0/3)
K-40	34,56,62	2.3± 0.1E00 (2/3)
Mn-54	34,56,62	L.T. 1.E-02 (0/3)
Co-58	34,56,62	L.T. 1.E-02 (0/3)
Fe-59	34,56,62	L.T. 2.E-02 (0/3)
Co-60	34,56,62	L.T. 1.E-02 (0/3)
Zn-65	34,56,62	L.T. 2.E-02 (0/3)
Zr-95	34,56,62	L.T. 1.E-02 (0/3)
Ru-103	34,56,62	L.T. 1.E-02 (0/3)
Ru-106	34,56,62	L.T. 9.E-02 (0/3)
I-131	34,56,62	L.T. 2.E-02 (0/3)
Cs-134	34,56,62	L.T. 1.E-02 (0/3)
Cs-137	34,56,62	L.T. 1.E-02 (0/3)
Ba-140	34,56,62	L.T. 1.E-02 (0/3)
Ce-141	34,56,62	L.T. 2.E-02 (0/3)
Ce-144	34,56,62	L.T. 8.E-02 (0/3)
Ra-226	34,56,62	L.T. 2.E-01 (0/3)
Th-228	34,56,62	L.T. 2.E-02 (0/3)

FEED AND FORAGE (See Tables I-1, I-2 and J-1, J-2)

- I. STATIONS 61, 74 (Nearest Milk Producers)
- J. STATIONS 42, 73, 75 (Commercial Milk Producers)

Feed and forage was collected from milk producers nearest the plant quarterly from two stations and monthly during peak pasture season. Feed and forage from commercial milk producers was collected quarterly from three stations. These samples were monitored for Sr-89, Sr-90, elemental calcium and gamma emitting nuclides. Sr-90 and elemental calcium were detected in these samples at levels similar to the levels monitored in 1973 through 1980. There were several detections of Sr-89 at both the nearest stations and at the commercial stations at approximately the same level. Sr-89 was detected in air particulate filters in some areas of the United States indicating that this was the result of fallout from previous nuclear tests especially those of October 16, 1980.

The naturally occurring nuclides Be-7, K-40, Ra-226 and Th-228 were detected at the levels seen in samples in previous years. There was one detection of the activation corrosion product Mn-54 at station 73 which is 10 miles from the plant. This was slightly above the detection level and has been seen in air particulate filters also, indicating that it was probably from fallout.

The fission related products Zr-95, Ru-103, Cs-137, Ce-141 and Ce-144 occurred in several samples reaching a peak in the third quarter and tapering off to zero in the fourth quarter. These nuclides were seen in samples equally at stations farthest from the plant as well as those nearest to it. This is the same trend seen in feed and forage from beef producers and in air particulate filters. This gives further support to the conclusion that these nuclides were due to fallout from the Chinese atmospheric nuclear tests on October 16, 1980. Thus it has been established that no nuclides which are related to CNS could be ingested by cows from feed and forage and there is no dose impact to the population.

TABLE I-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FEED AND FORAGE - NEAREST MILK PRODUCERS
 pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter 01/12/81	2nd Quarter 04/13/81-06/01/81	3rd Quarter 07/06/81-09/08/81	4th Quarter 10/05/81
Sr-89	61,74	Meantstd.dev. det./total range	L.T. 3. E-02 0/3 --	3.7 ± 1.6 E-02 1/5 --	5.8 ± 3.5 E-02 2/7 (3.3-8.2) E-02	L.T. 3. E-02 0/2 --
Sr-90	61,74	Meantstd.dev. det./total range	2.0 ± 2.0 E-01 3/3 (0.8-3.9) E-01	1.9 ± 0.3 E-02 1/5 --	3.5 ± 1.7 E-02 5/7 (1.4-5.2) E-02	L.T. 1. E-03 0/2 --
Ca (mg/gm)	61,74	Meantstd.dev. det./total range	6.7 ± 2.6 E 00 3/3 (0.5-1.0) E 01	2.1 ± 1.4 E 00 5/5 (0.6-4.3) E 00	1.6 ± 1.4 E 00 7/7 (0.5-4.2) E 00	1.4 ± 0.8 E 00 2/2 (0.8-1.9) E 00
Be-7	61,74	Meantstd.dev. det./total range	4.2 ± 0.7 E 00 1/3 --	3.8 ± 1.0 E-01 1/5 --	2.0 ± 0.9 E 00 5/7 (0.6-2.8) E 00	L.T. 1. E-01 0/2 --
K-40	61,74	Meantstd.dev. det./total range	2.7 ± 1.2 E 01 3/3 (1.5-3.8) E 01	5.0 ± 1.3 E 00 5/5 (2.9-6.2) E 00	8.3 ± 5.8 E 00 7/7 (0.3-1.9) E 01	6.2 ± 0.5 E 00 2/2 (5.8-6.5) E 00

TABLE I-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FEED AND FORAGE - NEAREST MILK PRODUCERS
 pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter 01/12/81	2nd Quarter 04/13/81-06/01/81	3rd Quarter 07/06/81-09/08/81	4th Quarter 10/05/81
Zr-95	61,74	Meantstd.dev. det./total range	4.2 ± 0.8 E-01 1/3 --	2.3 ± 0.2 E-01 1/5 --	4.0 ± 1.8 E-01 3/7 (1.9-5.0) E-01	L.T. 1. E-02 0/2 --
Ru-103	61,74	Meantstd.dev. det./total range	2.4 ± 0.9 E-01 1/3 --	3.6 ± 1.1 E-02 1/5 --	L.T. 8. E-02 0/7 --	L.T. 1. E-02 0/2 --
Cs-137	61,74	Meantstd.dev. det./total range	L.T. 1. E-01 0/3 --	L.T. 2. E-02 0/5 --	6.2 ± 3.2 E-02 1/7 --	L.T. 1. E-02 0/2 --
Ce-141	61,74	Meantstd.dev. det./total range	3.1 ± 1.1 E-01 1/3 --	4.1 ± 1.4 E-02 1/5 --	L.T. 1. E-01 0/7 --	L.T. 2. E-02 0/2 --
Ce-144	61,74	Meantstd.dev.	L.T. 7. E-01 0/3 --	L.T. 7. E-02 0/5 --	4.8 ± 1.8 E-01 3/7 (2.7-6.2) E-01	L.T. 9. E-02 0/2 --

TABLE I-2

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

EXPOSURE PATHWAY - INGESTION

FEED AND FORAGE - NEAREST MILK PRODUCERS

pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER	1st Quarter 01/12/81	2nd Quarter 04/13/81-06/01/81	3rd Quarter 07/06/81-09/08/81	4th Quarter 10/05/81
Be-7	61,74	4.2 ± 0.7 E 00 (1/3)	3.8 ± 1.0 E-01 (1/5)	2.0 ± 0.9 E 00 (5/7)	L.T. 1. E-01 (0/2)
K-40	61,74	2.7 ± 1.2 E 01 (3/3)	5.0 ± 1.3 E 00 (5/5)	8.3 ± 5.8 E 00 (7/7)	6.2 ± 0.5 E 00 (2/2)
Mn-54	61,74	L.T. 9. E-02 (0/3)	L.T. 1. E-02 (0/5)	L.T. 6. E-02 (0/7)	L.T. 1. E-02 (0/2)
Co-58	61,74	L.T. 1. E-01 (0/3)	L.T. 1. E-02 (0/5)	L.T. 6. E-02 (0/7)	L.T. 1. E-02 (0/2)
Fe-59	61,74	L.T. 2. E-01 (0/3)	L.T. 2. E-02 (0/5)	L.T. 1. E-01 (0/7)	L.T. 2. E-02 (0/2)
Co-60	61,74	L.T. 1. E-01 (0/3)	L.T. 1. E-02 (0/5)	L.T. 6. E-02 (0/7)	L.T. 1. E-02 (0/2)
Zn-65	61,74	L.T. 2. E-02 (0/3)	L.T. 2. E-02 (0/5)	L.T. 1. E-01 (0/7)	L.T. 3. E-02 (0/2)
Zr-95	61,74	4.2 ± 0.8 E-01 (1/3)	2.3 ± 0.2 E-01 (1/5)	4.0 ± 1.8 E-01 (3/7)	L.T. 1. E-02 (0/2)
Ru-103	61,74	2.4 ± 0.9 E-01 (1/3)	3.6 ± 1.1 E-02 (1/5)	L.T. 8. E-02 (0/7)	L.T. 1. E-02 (0/2)
Ru-106	61,74	L.T. 9. E-01 (0/3)	L.T. 1. E-01 (0/5)	L.T. 5. E-01 (0/7)	L.T. 1. E-01 (0/2)
I-131	61,74	L.T. 2. E-01 (0/3)	L.T. 2. E-02 (0/5)	L.T. 2. E-01 (0/7)	L.T. 3. E-02 (0/2)
Cs-134	61,74	L.T. 1. E-01 (0/3)	L.T. 1. E-02 (0/5)	L.T. 6. E-02 (0/7)	L.T. 1. E-02 (0/2)
Cs-137	61,74	L.T. 1. E-01 (0/3)	L.T. 2. E-02 (0/5)	6.2 ± 3.2 E-02 (1/7)	L.T. 1. E-02 (0/2)
Ba-140	61,74	L.T. 1. E-01 (0/3)	L.T. 2. E-02 (0/5)	L.T. 1. E-01 (0/7)	L.T. 2. E-02 (0/2)
Ce-141	61,74	3.1 ± 1.1 E-01 (1/3)	4.1 ± 1.4 E-02 (1/5)	L.T. 1. E-01 (0/7)	L.T. 2. E-02 (0/2)
Ce-144	61,74	L.T. 7. E-01 (0/3)	L.T. 7. E-02 (0/5)	4.8 ± 1.8 E-01 (3/7)	L.T. 9. E-02 (0/2)
Ra-226	61,74	L.T. 2. E 00 (0/3)	2.7 ± 0.8 E-01 (2/5)	3.2 ± 1.3 E-01 (1/7)	L.T. 3. E-01 (0/2)
Th-228	61,74	L.T. 2. E-01 (0/3)	L.T. 2. E-02 (0/5)	2.4 ± 0.8 E-02 (1/7)	L.T. 2. E-02 (0/2)

TABLE J-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FEED AND FORAGE - COMMERCIAL MILK PRODUCERS
 pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter 01/12/81	2nd Quarter 04/13/81	3rd Quarter 07/13/81	4th Quarter 10/12/81
Sr-89	42,73,75	Meantstd.dev. det./total range	L.T. 3. E-02 0/3 --	L.T. 3. E-02 0/4 --	0 ± 1.9 E-01 2/3 (0.6-0.4) E-01	L.T. 3. E-02 0/3 --
Sr-90	42,73,75	Meantstd.dev. det./total range	6.0 ± 6.0 E-01 3/3 (0.1-1.3) E-01	4.8 ± 2.1 E-02 4/4 (2.9-7.7) E-02	5.7 ± 2.7 E-02 3/3 (3.2-8.6) E-02	6.3 ± 2.3 E-03 1/3 --
Ca(mg/gm)	42,73,75	Meantstd.dev. det./total range	4.1 ± 4.2 E 00 3/3 (1.6-9.0) E 00	3.1 ± 0.8 E 00 4/4 (2.3-4.2) E 00	2.7 1.5 E 00 3/3 (1.8-4.4) E 00	6.2 ± 6.1 E-01 3/3 (0.1-1.3) E 00
Be-7	42,73,75	Meantstd.dev. det./total range	1.2 ± 0.6 E-01 1/3 --	L.T. 2. E-01 0/4 --	2.5 ± 1.6 E 00 3/3 (0.8-3.9) E 00	8.2 ± 1.2 E-01 1/3 --
K-40	42,73,75	Meantstd.dev. det./total range	1.8 ± 1.3 E 01 3/3 (0.4-2.8) E 01	5.3 ± 1.2 E 00 4/4 (3.7-6.2) E 00	1.1 ± 0.4 E 01 3/3 (0.8-1.6) E 01	4.3 ± 1.5 E 00 3/3 (2.8-5.8) E 00
Mn-54	42,73,75	Meantstd.dev. det./total range	L.T. 7. E-02 0/3 --	L.T. 2. E-02 0/4 --	6.5 ± 2.7 E-02 1/3 --	L.T. 1. E-02 0/3 --

TABLE J-1

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

EXPOSURE PATHWAY - INGESTION

FEED AND FORAGE - COMMERCIAL MILK PRODUCERS

pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter 01/12/81	2nd Quarter 04/13/81	3rd Quarter 07/13/81	4th Quarter 10/12/81
Zr-95	42,73,75	Meantstd.dev. det./total range	L.T. 8. E-02 0/3 --	L.T. 2. E-02 0/4 --	7.8 ± 2.2 E-01 2/3 (6.2-9.4) E-01	L.T. 2. E-02 0/3 --
Ru-103	42,73,75	Meantstd.dev. det./total range	L.T. 7. E-02 0/3 --	L.T. 2. E-02 0/4 --	9.3 ± 4.8 E-02 1/3 --	L.T. 2. E-02 0/3 --
Cs-137	42,73,75	Meantstd.dev. det./total range	L.T. 7. E-02 0/3 --	L.T. 2. E-02 0/4 --	1.0 ± 0.3 E-01 2/3 (0.8-1.2) E-01	L.T. 2. E-02 0/3 --
Ce-141	42,73,75	Meantstd.dev. det./total range	L.T. 1. E-01 0/3 --	L.T. 4. E-02 0/4 --	1.0 ± 0.4 E-01 1/3 --	L.T. 3. E-02 0/3 --
Ce-144	42,73,75	Meantstd.dev. det./total range	L.T. 5. E-01 0/3 --	L.T. 2. E-01 0/4 --	1.0 ± 0.1 E 00 2/3 (0.9-1.1) E 00	L.T. 1. E-01 0/3 --

TABLE J-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FEED AND FORAGE - COMMERCIAL MILK PRODUCERS
 pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER	1st Quarter 01/12/81	2nd Quarter 04/13/81	3rd Quarter 07/13/81	4th Quarter 10/12/81
Be-7	42,73,75	1.2 ± 0.6 E-01 (1/3)	L.T. 2. E-01 (0/4)	2.5 ± 1.6 E 00 (3/3)	8.2 ± 1.2 E-01 (1/3)
K-40	42,73,75	1.8 ± 1.3 E 01 (3/3)	5.3 ± 1.2 E 00 (4/4)	1.1 ± 0.4 E 01 (3/3)	4.3 ± 1.5 E 00 (3/3)
Mn-54	42,73,75	L.T. 7. E-02 (0/3)	L.T. 2. E-02 (0/4)	6.5 ± 2.7 E-02 (1/3)	L.T. 1. E-02 (0/3)
Co-58	42,73,75	L.T. 7. E-02 (0/3)	L.T. 2. E-02 (0/4)	L.T. 5. E-02 (0/3)	L.T. 1. E-02 (0/3)
Fe-59	42,73,75	L.T. 2. E-01 (0/3)	L.T. 4. E-02 (0/4)	L.T. 1. E-01 (0/3)	L.T. 3. E-02 (0/3)
Co-60	42,73,75	L.T. 7. E-02 (0/3)	L.T. 2. E-02 (0/4)	L.T. 6. E-02 (0/3)	L.T. 1. E-02 (0/3)
Zn-65	42,73,75	L.T. 2. E-01 (0/3)	L.T. 4. E-02 (0/4)	L.T. 1. E-01 (0/3)	L.T. 3. E-02 (0/3)
Zr-95	42,73,75	L.T. 8. E-02 (0/3)	L.T. 2. E-02 (0/4)	7.8 ± 2.2 E-01 (0/3)	L.T. 2. E-02 (0/3)
Ru-103	42,73,75	L.T. 7. E-02 (0/3)	L.T. 2. E-02 (0/4)	9.3 ± 4.8 E-02 (1/3)	L.T. 2. E-02 (0/3)
Ru-106	42,73,75	L.T. 6. E-01 (0/3)	L.T. 2. E-01 (0/4)	L.T. 5. E-01 (0/3)	L.T. 1. E-01 (0/3)
I-131	42,73,75	L.T. 2. E-01 (0/3)	L.T. 3. E-02 (0/4)	L.T. 1. E-01 (0/3)	L.T. 4. E-02 (0/3)
Cs-134	42,73,75	L.T. 8. E-02 (0/3)	L.T. 2. E-02 (0/4)	L.T. 6. E-02 (0/3)	L.T. 1. E-02 (0/3)
Cs-137	42,73,75	L.T. 7. E-02 (0/3)	L.T. 2. E-02 (0/4)	1.0 ± 0.3 E-01 (2/3)	L.T. 2. E-02 (0/3)
Ba-140	42,73,75	L.T. 1. E-01 (0/3)	L.T. 2. E-02 (0/4)	L.T. 1. E-01 (0/3)	L.T. 3. E-02 (0/3)
Ce-141	42,73,75	L.T. 1. E-01 (0/3)	L.T. 4. E-02 (0/4)	1.0 ± 0.4 E-01 (1/3)	L.T. 3. E-02 (0/3)
Ce-144	42,73,75	L.T. 5. E-01 (0/3)	L.T. 2. E-01 (0/4)	1.0 ± 0.1 E 00 (2/3)	L.T. 1. E-01 (0/3)
Ra-226	42,73,75	L.T. 1. E 00 (0/3)	L.T. 4. E-01 (0/4)	L.T. 1. E 00 (0/3)	L.T. 3. E-01 (0/3)
Th-228	42,73,75	L.T. 1. E-01 (0/3)	L.T. 3. E-02 (0/4)	L.T. 1. E-01 (0/3)	L.T. 3. E-02 (0/3)

K. FOOD AND FEED CROPS - CORN AND SOY BEANS

(See Tables K-1 and K-2)

STATIONS 15, 18, 20, 27, 29, 38, and 41

Food and feed crops were collected once during the year at harvest time and monitored for gross beta, Sr-89, Sr-90, elemental calcium and gamma emitters. Measurements on all of these analyses were similar in activity level and range to those measured in the previous years of 1973 - 1980.

Gross beta activity measured an average of 11.0 ± 0.9 pCi per gram, wet. This was largely due to K-40, the naturally occurring, terrestrial nuclide. Strontium-90 was detected in 3 of 8 samples at an average of 0.012 pCi/gm, wet, which is below the minimum level of detection. The elemental calcium level was similar to that of other years at 0.52 mg per gram.

From this monitoring data it may be concluded that there is no effect on food and feed crops from the operations of CNS.

TABLE K-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FOOD AND FEED CROPS pCi/gm. wet

SAMPLE NUCLIDE	STATION NUMBER		3rd Quarter 09/21/81
Gross Beta	15, 18, 20, 27, 29, 38, 41	Mean ± std. dev. det./total range	1.1 ± 0.9 E 01 8/8 (0.4-3.1) E 01
Sr-89	15, 18, 20, 27, 29, 38, 41	Mean ± std. dev. det./total range	L.T. 3. E-02 0/8 --
Sr-90	15, 18, 20, 27, 29, 38, 41	Mean ± std. dev. det./total range	1.2 ± 0.7 E-02 3/8 (0.7-2.1) E-02
Ca (mg/gm)	15, 18, 20, 27, 29, 38, 41	Mean ± std. dev. det./total range	5.2 ± 8.0 E-01 8/8 (0.007-2.2) E 00
71 K-40	15, 18, 20, 27, 29, 38, 41,	Mean ± std. dev. det./total range	6.5 ± 6.8 E 00 8/8 (2.1-21.4) E 00
Be-7	15, 18, 20, 27, 29, 38, 41	Mean ± std. dev. det./total range	6.7 ± 0.4 E-01 3/8 (0.4-1.2) E 00

TABLE K-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FOOD AND FEED CROPS pCi/Gm, wet

SAMPLE NUCLIDE	STATION NUMBER	3rd Quarter 09/21/81
Be-7	15, 18, 20, 27, 29, 38, 41	6.7 ± 0.4 E-01 (3/8)
K-40	15, 18, 20, 27, 29, 38, 41	6.5 ± 6.8 E 00 (8/8)
Mn-54	15, 18, 20, 27, 29, 38, 41	L.T. 3. E-02 (0/8)
Co-58	15, 18, 20, 27, 29, 38, 41	L.T. 3. E-02 (0/8)
Fe-59	15, 18, 20, 27, 29, 38, 41	L.T. 7. E-02 (0/8)
Co-60	15, 18, 20, 27, 29, 38, 41	L.T. 3. E-02 (0/8)
Zn-65	15, 18, 20, 27, 29, 38, 41	L.T. 7. E-02 (0/8)
Zr-95	15, 18, 20, 27, 29, 38, 41	L.T. 3. E-02 (0/8)
Ru-103	15, 18, 20, 27, 29, 38, 41	L.T. 3. E-02 (0/8)
Ru-106	15, 18, 20, 27, 29, 38, 41	L.T. 3. E-01 (0/8)
I-131	15, 18, 20, 27, 49, 38, 41	L.T. 9. E-02 (0/8)
Cs-134	15, 18, 20, 27, 29, 38, 41	L.T. 3. E-02 (0/8)
Cs-137	15, 18, 20, 27, 29, 38, 41	L.T. 3. E-02 (0/8)
Ba-140	15, 18, 20, 27, 49, 38, 41	L.T. 5. E-02 (0/8)
Ce-141	15, 18, 20, 27, 29, 38, 41	L.T. 5. E-02 (0/8)
Ce-144	15, 18, 20, 27, 29, 38, 41	L.T. 2. E-01 (0/8)
Ra-226	15, 18, 20, 27, 29, 38, 41	L.T. 5. E-01 (0/8)
Th-228	15, 18, 20, 27, 29, 38, 41	L.T. 5. E-02 (0/8)

L. FISH (See Tables L-1, L-2)

STATIONS 28, 35

Fish samples were collected during the spring and fall and analyzed for gross beta, Sr-89, Sr-90 and gamma emitting isotopes. The gross beta and Sr-90 activities were similar to the levels of previous years. There were no detections of Sr-89. All of the gamma emitters were at or below the minimum level of detection except K-40, a naturally occurring isotope, which was at the same level as previous years.

There was no significant difference between the fish caught at station 28 downstream from the discharge point and that caught at station 35 upstream from discharge point. Since no change has occurred in levels of activity in the isotopes monitored since 1975 it can be concluded that the operations of CNS have had no effect on fish samples.

TABLE L-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 FISH - pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER		2nd Quarter 04/20,21/81	4th Quarter 10/17/81
Gross Beta	28,35	Mean/std.dev. det./total range	3.2 ± 0.4 E 00 5/5 (2.9-3.9) E 00	4.2 ± 0.9 E 00 5/5 (3.3-5.6) E 00
Sr-89	28,35	Mean/std.dev. det./total range	L.T. 3. E-02 0/5 --	L.T. 3. E-02 0/5 --
Sr-90	28,35	Mean/std.dev. det./total range	2.2 ± 0.6 E-02 3/5 (1.8-2.9) E-02	1.6 ± 1.3 E-02 5/5 (0.3-3.2) E-02
77 K-40 (a)	28,35	Mean/std.dev. det./total range	2.5 ± 0.3 E 00 5/5 (2.3-3.1) E 00	2.8 ± 0.4 E 00 5/5 (2.4-3.5) E 00

(a) K-40 is the only gamma emitter above the limits of detection on the Ge(Li) Spectrometer. The eighteen gamma emitters monitored are listed in Table L-2.

TELEDYNE ISOTOPES

TABLE L-2
NEBRASKA PUBLIC POWER DISTRICT
COOPER NUCLEAR STATION
EXPOSURE : THWAY - INGESTION
FISH - /gm, wet

SAMPLE NUCLIDE	STATION NUMBER	2 nd Quarter 04/20, 21/81	4th Quarter 10/17/81
Br-7	28,35	L.T. 1. E-01 (0/5)	L.T. 8. E-02 (0/5)
K-40	28,35	2.5 ± 0.3 E 00 (5/5)	2.8 ± 0.4 E 00 (5/5)
Mn-54	28,35	L.T. 1. E-02 (0/5)	L.T. 8. E-03 (0/5)
Co-58	28,35	L.T. 1. E-02 (0/5)	L.T. 9. E-03 (0/5)
Fe-59	28,35	L.T. 3. E-02 (0/5)	L.T. 2. E-02 (0/5)
Co-60	28,35	L.T. 1. E-02 (0/5)	L.T. 1. E-02 (0/5)
Zn-65	28,35	L.T. 3. E-02 (0/5)	L.T. 2. E-02 (0/5)
Zr-95	28,35	L.T. 2. E-02 (0/5)	L.T. 9. E-03 (0/5)
Ru-103	28,35	L.T. 1. E-02 (0/5)	L.T. 1. E-02 (0/5)
Ru-106	28,35	L.T. 1. E-01 (0/5)	L.T. 8. E-02 (0/5)
I-131	28,35	L.T. 3. E-02 (0/5)	L.T. 3. E-02 (0/5)
Cs-134	28,35	L.T. 1. E-02 (0/5)	L.T. 9. E-03 (0/5)
Cs-137	28,35	L.T. 2. E-02 (0/5)	L.T. 9. E-03 (0/5)
Ba-140	28,35	L.T. 2. E-02 (0/5)	L.T. 2. E-02 (0/5)
Ce-141	28,35	L.T. 3. E-02 (0/5)	L.T. 2. E-02 (0/5)
Ce-144	28,35	L.T. 1. E-01 (0/5)	L.T. 7. E-02 (0/5)
Ra-226	28,35	L.T. 3. E-01 (0/5)	L.T. 2. E-01 (0/5)
Th-228	28,35	L.T. 3. E-02 (0/5)	L.T. 2. E-02 (0/5)

MILK (See Tables M-1, M-2 and N-1, N-2)

M. STATIONS 42, 73, 75 (COMMERCIAL PRODUCERS)

N. STATIONS 61, 74 (NEAREST PRODUCERS)

Milk samples from commercial producers were collected quarterly from 3 stations and monitored for I-131, Sr-89, Sr-90, elemental calcium and gamma emitters. Milk samples from nearest producers were collected from two stations monthly and monitored for I-131, Sr-89, Sr-90, elemental calcium and gamma emitters. During peak pasture season weekly samples were collected and monitored for I-131. A monthly sample was composited and monitored for the same analytes as the monthly sample.

There were no detections of I-131 or Sr-89 in milk from either the commercial producers or the nearest producers. Sr-90 was detected in 36 of 39 samples during the four quarters at levels slightly below those of 1980. Elemental calcium levels remained approximately the same. Naturally occurring K-40 remained at the same levels as previous years. There were no other detections of gamma emitting nuclides except for one detection of naturally occurring Th-228 in the first quarter at a very low level.

Thus we conclude that the operations of CNS had no effect on the milk from commercial nor from nearest producers and thus no dose impact on the population.

TABLE M-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 MILK - pCi/liter
 COMMERCIAL PRODUCERS

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter 01/19/81-01/27/81	2nd Quarter 04/20/81-04/21/81	3rd Quarter 07/18/81	4th Quarter 10/19/81
Sr-89	42, 73, 75 (a)	Meantstd.dev. det./total range	L.T. 2. E 00 0/3 --	L.T. 2. E 00 0/3 --	L.T. 2. E 00 0/3 --	L.T. 2. E 00 0/3 --
Sr-90	42, 73, 75	Meantstd.dev. det./total range	2.9 +-1.4 E 00 3/3 (2.1-4.5) E 00	1.9 +-0.8 E 00 3/3 (1.1-2.6) E 00	3.2 +-2.8 E 00 3/3 (0.71-6.3) E 00	4.0 +-1.2 E 00 3/3 (3.1-5.4) E 00
I-131	42, 73, 75	Meantstd.dev. det./total range	L.T. 3. E-01 0/3 --	L.T. 2. E-01 0/3 --	L.T. 2. E-01 0/3 --	L.T. 2. E-01 0/3 --
Ca (mg/liter)	42, 73, 75	Meantstd.dev. det./total range	1.7 +-0.2 E 00 3/3 (1.5-1.9) E 00	2.5 +-0.3 E 00 3/3 (2.3-2.8) E 00	1.4 +-0.3 E 00 3/3 (1.1-1.7) E 00	1.9 +-0.4 E 00 3/3 (1.6-2.3) E 00
K-40	42, 73, 75	Meantstd.dev. det./total range	1.2 +-0.1 E 03 3/3 (1.1-1.2) E 03	1.1 +-0.2 E 03 3/3 (1.0-1.3) E 03	1.3 +-0.3 E 03 3/3 (1.1-1.7) E 03	1.2 +-0.1 E 03 3/3 (1.1-1.3) E 03
Cs-137	42, 73, 75	Meantstd.dev. det./total range	L.T. 7. E 00 0/3 --	L.T. 7. E 00 0/3 --	L.T. 8. E 00 0/3	L.T. 9. E 00 0/3

(a) January 19, Station 75 -- Milk sample lost; discarded by air freight because it leaked; resampled 01/27.

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 MILK - pCi/liter
 COMMERCIAL PRODUCERS

SAMPLE NUMBER	STATION NUMBER	1st Quarter 01/19/81-01/27/81	2nd Quarter 4/20/81-4/21/81	3rd Quarter 07/13/81	4th Quarter 10/19/81
Re-	42,73,75	L.T. 6. E 01 (0/3)	L.T. 5. E 01 (0/3)	L.T. 6. E 01 (0/3)	L.T. 8. E 01 (0/3)
K-40	42,73,75	1.2 +-0.1 E 03 (3/3)	1.1 +-0.2 E 03 (3/3)	1.3 +-0.3 E 03 (3/3)	1.2 +-0.1 E 03 (3/3)
Mn-54	42,73,75	L.T. 7. E 00 (0/3)	L.T. 6. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 8. E 00 (0/3)
Co-58	42,73,75	L.T. 7. E 00 (0/3)	L.T. 6. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 8. E 00 (0/3)
Fe-59	42,73,75	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 2. E 01 (0/3)
Co-60	42,73,75	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)
Zr-65	42,73,75	L.T. 2. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 2. E 01 (0/3)
Zr-95	42,73,75	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)
Ru-103	42,73,75	L.T. 7. E 00 (0/3)	L.T. 6. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 9. E 00 (0/3)
Ru-106	42,73,75	L.T. 6. E 01 (0/3)	L.T. 6. E 01 (0/3)	L.T. 6. E 01 (0/3)	L.T. 6. E 01 (0/3)
I-131	42,73,75	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 1. E 01 (0/3)
Cs-134	42,73,75	L.T. 8. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 8. E 00 (0/3)	L.T. 8. E 00 (0/3)
Cs-137	42,73,75	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 8. E 00 (0/3)	L.T. 9. E 00 (0/3)
Sr-140	42,73,75	L.T. 1. E 01 (0/3)	L.T. 7. E 00 (0/3)	L.T. 2. E 01 (0/3)	L.T. 1. E 01 (0/3)
Ce-141	42,73,75	L.T. 2. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 2. E 01 (0/3)
Ce-144	42,73,75	L.T. 6. E 01 (0/3)	L.T. 6. E 01 (0/3)	L.T. 2. E 02 (0/3)	L.T. 7. E 01 (0/3)
Ra-226	42,73,75	L.T. 2. E 02 (0/3)	L.T. 1. E 02 (0/3)	L.T. 2. E 02 (0/3)	L.T. 2. E 02 (0/3)
Th-228	42,73,75	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)

TABLE N-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 MILK - pCi/liter
 NEAREST PRODUCERS

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter 01/19/81-03/16/81	2nd Quarter 04/20/81-06/29/81	3rd Quarter 07/06/81-09/28/81	4th Quarter 10/12/81-12/14/81
Sr-89	61, 74 (a)	Meanstd.dev. det./total range	L.T. 2. E 00 0/7 --	L.T. 2. E 00 0/7 --	L.T. 2. E 00 0/6 --	L.T. 2. E 00 0/7 --
Sr-90	61, 74	Meanstd.dev. det./total range	1.6 +-0.5 E 00 7/7 (0.8-2.2) E 00	2.3 +-1.2 E 00 4/7 (1.3-3.9) E 00	2.2 +-0.7 E 00 6/6 (1.3-3.3) E 00	1.8 +-0.9 E 00 7/7 (0.8-3.2) E 00
I-131	61, 74	Meanstd.dev. det./total range	L.T. 3. E-01 0/7 --	L.T. 3. E-01 0/17 --	L.T. 5. E-01 0/31 --	L.T. 2. E-01 0/7 --
Ca (mg/liter)	61, 74	Meanstd.dev. det./total range	1.2 +-0.4 E 00 7/7 (0.6-1.7) E 00	2.5 +-0.6 E 00 7/7 (1.6-3.1) E 00	2.0 +-0.3 E 00 6/6 (1.7-2.4) E 00	1.6 +-0.3 E 00 7/7 (1.3-2.1) E 00
K-40	61,74	Meanstd.dev. det./total range	1.2 +-0.1 E 03 7/7 (1.0-1.2) E 03	1.1 +-0.1 E 03 7/7 (1.0-1.2) E 03	1.2 +-0.1 E 03 6/6 (1.1-1.4) E 03	1.2 +-0.2 E 03 7/7 (1.0-1.4) E 03

(a) January 19, Station 61 -- Milk sample lost; discarded by air freight because it leaked; resampled 01/26.

TELEDYNE ISOTOPES

TABLE N-2

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

EXPOSURE PATHWAY - INGESTION

MILK - pCi/liter

NEAREST PRODUCERS

SAMPLE NUCLIDE	STATION NUMBER	1st Quarter 01/19/81-03/16/81	2nd Quarter 04/20/81-06/29/81	3rd Quarter 07/08/81-09/28/81	4th Quarter 10/21/81-12/15/81
20-7	61,74	L.T. 6. E 01 (6/7)	L.T. 7. E 01 (0/7)	L.T. 8. E 01 (0/6)	L.T. 6. E 01 (0/7)
K-40	61,74	1.2 +-0.1 E 03 (7/7)	1.1 +-0.1 E 03 (7/7)	1.2 +-0.1 E 03 (6/6)	1.2 +-0.2 E 03 (7/7)
Mn-54	61,74	L.T. 6. E 00 (0/7)	L.T. 7. E 00 (0/7)	L.T. 7. E 00 (0/6)	L.T. 7. E 00 (0/7)
Co-58	61,74	L.T. 7. E 00 (0/7)	L.T. 7. E 00 (0/7)	L.T. 8. E 00 (0/6)	L.T. 7. E 00 (0/7)
Fe-59	61,74	L.T. 1. E 01 (0/7)	L.T. 2. E 01 (0/7)	L.T. 2. E 01 (0/6)	L.T. 1. E 01 (0/7)
Co-60	61,74	L.T. 6. E 00 (0/7)	L.T. 7. E 00 (0/7)	L.T. 7. E 00 (0/6)	L.T. 7. E 00 (0/7)
Zr-95	61,74	L.T. 2. E 01 (0/7)	L.T. 2. E 01 (0/7)	L.T. 2. E 01 (0/6)	L.T. 1. E 01 (0/7)
Ru-103	61,74	L.T. 7. E 00 (0/7)	L.T. 8. E 00 (0/7)	L.T. 9. E 00 (0/6)	L.T. 7. E 00 (0/7)
Ru-106	61,74	L.T. 7. E 00 (0/7)	L.T. 9. E 00 (0/7)	L.T. 1. E 01 (0/6)	L.T. 7. E 00 (0/7)
I-131	61,74	L.T. 6. E 01 (0/7)	L.T. 6. E 01 (0/7)	L.T. 7. E 01 (0.6)	L.T. 4. E 01 (0/7)
Cs-134	61,74	L.T. 1. E 01 (0/7)	L.T. 5. E 01 (0/7)	L.T. 6. E 01 (0/6)	L.T. 2. E 01 (0/7)
Cs-137	61,74	L.T. 7. E 00 (0/7)	L.T. 7. E 00 (0/7)	L.T. 8. E 00 (0/6)	L.T. 7. E 00 (0/7)
Pa-140	61,74	L.T. 7. E 00 (0/7)	L.T. 8. E 00 (0/7)	L.T. 8. E 00 (0/6)	L.T. 7. E 00 (0/7)
Ce-141	61,74	L.T. 9. E 00 (0/7)	L.T. 2. E 01 (0/7)	L.T. 3. E 01 (0/6)	L.T. 1. E 01 (0/7)
Ce-144	61,74	L.T. 2. E 01 (0/7)	L.T. 2. E 01 (0/7)	L.T. 2. E 01 (0/6)	L.T. 1. E 01 (0/7)
Ra-226	61,74	L.T. 6. E 01 (0/7)	L.T. 6. E 01 (0/7)	L.T. 6. E 01 (0/6)	L.T. 6. E 01 (0/7)
Th-228	61,74	L.T. 2. E 02 (0/7)	L.T. 2. E 02 (0/7)	L.T. 2. E 02 (0/6)	L.T. 2. E 02 (0/7)
		5.6 +-3.0 E 00 (1/7)	L.T. 1. E 01 (0/7)	L.T. 1. E 01 (0/6)	L.T. 1. E 01 (0/7)

D. GROUNDWATER (See Tables 0-1 and 0-2)

STATIONS 11, 47

Groundwater was collected from two stations quarterly and analyzed for gross beta and gross alpha activity, for tritium and for gamma emitting radionuclides. Station 11 is 0.15 miles from the plant and station 47 is 25.75 miles from, the plant. There was no gross alpha activity detected and no detections of gamma emitters above the minimum level of detection. The gross beta activity was statistically the same as in past years. The tritium level averaged 180 pCi/liter for the year which is the normal environmental level.

There was no difference in levels of beta activity or tritium for the station close to the plant as compared with the more distant station. It may be concluded that there is no impact from the operations of CNS on the environment as shown by measurements of radionuclides in groundwater.

TABLE 0-1

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - WATERBORNE
 GROUND WATER - pCi/liter

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter 01/26/81	2nd Quarter 04/27/81	3rd Quarter 07/26/81	4th Quarter 10/26/81
Gross Alpha	11,47	Meanstd.dev. det./total range	L.T. 4. E 00 0/2 --	L.T. 3. E 00 0/2 --	L.T. 4. E 00 0/2 --	L.T. 4. E 00 0/2 --
Gross Beta	11,47	Meanstd.dev. det./total range	6.8 ± 0.7 E 00 2/2 (6.3-7.3) E 00	1.0 ± 0.1 E 01 2/2 (0.9-1.1) E 01	9.7 ± 1.8 E 00 2/2 (0.8-1.1) E 01	9.1 ± 0.9 E 00 2/2 (8.4-9.7) E 00
H-3	11,47	Meanstd.dev. det./total range	2.3 ± 1.5 E 02 2/2 (1.2-3.3) E 02	2.0 ± 0.9 E 02 2/2 (1.3-2.6) E 02	2.3 ± 0.8 E 02 1/2 --	1.4 ± 0.6 E 02 2/2 (0.9-1.8) E 02

22

Eighteen gamma emitters were monitored on a Ge(Li) spectrometer. All were below the limits of detection and are listed on Table 0-2.

TABLE 0-2

NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATH - WATERBORNE
 GROUND WATER - pCi/liter

SAMPLE NUCLIDE	STATION NUMBER	1st Quarter 01/26/81	2nd Quarter 04/27/81	3rd Quarter 07/26/81	4th Quarter 10/26/81
Bc-7	11,47	L.T. 6. E 01 (0/2)	L.T. 7. E 01 (0/2)	L.T. 5. E 01 (0/2)	L.T. 6. E 01 (0/2)
K-40	11,47	L.T. 2. E 02 (0/2)	L.T. 2. E 02 (0/2)	L.T. 2. E 02 (0/2)	L.T. 1. E 02 (0/2)
Mn-54	11,47	L.T. 6. E 00 (0/2)	L.T. 6. E 00 (0/2)	L.T. 5. E 00 (0/2)	L.T. 6. E 00 (0/2)
Co-58	11,47	L.T. 6. E 00 (0/2)	L.T. 7. E 00 (0/2)	L.T. 5. E 00 (0/2)	L.T. 6. E 00 (0/2)
Fe-59	11,47	L.T. 1. E 01 (0/2)	L.T. 2. E 01 (0/2)	L.T. 1. E 01 (0/2)	L.T. 1. E 01 (0/2)
Co-60	11,47	L.T. 7. E 00 (0/2)	L.T. 7. E 00 (0/2)	L.T. 5. E 00 (0/2)	L.T. 6. E 00 (0/2)
Zn-65	11,47	L.T. 1. E 01 (0/2)	L.T. 1. E 01 (0/2)	L.T. 1. E 01 (0/2)	L.T. 1. E 01 (0/2)
Zr-95	11,47	L.T. 7. E 00 (0/2)	L.T. 7. E 00 (0/2)	L.T. 6. E 00 (0/2)	L.T. 7. E 00 (0/2)
Ru-103	11,47	L.T. 8. E 00 (0/2)	L.T. 9. E 00 (0/2)	L.T. 6. E 00 (0/2)	L.T. 7. E 00 (0/2)
Ru-106	11,47	L.T. 6. E 01 (0/2)	L.T. 6. E 01 (0/2)	L.T. 5. E 01 (0/2)	L.T. 5. E 01 (0/2)
I-131	11,47	L.T. 1. E 01 (0/2)	L.T. 3. E 01 (0/2)	L.T. 1. E 01 (0/2)	L.T. 2. E 01 (0/2)
Cs-134	11,47	L.T. 7. E 00 (0/2)	L.T. 8. E 00 (0/2)	L.T. 6. E 00 (0/2)	L.T. 7. E 00 (0/2)
Cs-137	11,47	L.T. 6. E 00 (0/2)	L.T. 7. E 00 (0/2)	L.T. 6. E 00 (0/2)	L.T. 6. E 00 (0/2)
Ba-140	11,47	L.T. 9. E 00 (0/2)	L.T. 1. E 01 (0/2)	L.T. 8. E 00 (0/2)	L.T. 1. E 01 (0/2)
Ce-141	11,47	L.T. 2. E 01 (0/2)	L.T. 2. E 01 (0/2)	L.T. 1. E 01 (0/2)	L.T. 1. E 01 (0/2)
Ce-144	11,47	L.T. 6. E 01 (0/2)	L.T. 6. E 01 (0/2)	L.T. 5. E 01 (0/2)	L.T. 5. E 01 (0/2)
Ra-226	11,47	L.T. 1. E 02 (0/2)	L.T. 2. E 02 (0/2)	L.T. 1. E 02 (0/2)	L.T. 1. E 02 (0/2)
Th-228	11,47	L.T. 1. E 01 (0/2)	L.T. 1. E 01 (0/2)	L.T. 1. E 01 (0/2)	L.T. 1. E 01 (0/2)

P. RIVER WATER (See Table P-1 and P-2)

STATIONS 12,13,28

River water was collected monthly and monitored for gross beta and gross alpha, suspended and dissolved, Sr-89 and Sr-90. A quarterly composite was measured for gamma emitters and tritium. All measurements during 1981 were in agreement with those of the period 1973 through 1980. There were no detections of Sr-89 or Sr-90 above the minimum level of detection. Gross beta and gross alpha readings, suspended and dissolved, were at normal environmental levels for river water. There were no detections of gamma emitters.

These measurements indicate that the river water samples monitored during 1981 contained no detectable CNS plant radionuclides. Additional verification of no detectable releases is the low range of H-3 activity which was from 200 to 520 pCi/liter.

TABLE P-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - WATERBORNE
 RIVER WATER - pCi/liter

SAMPLE NUCLIDE	STATION NUMBER		1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
			01/06/81-03/10/81	04/13/81-06/15/81	07/20/81-09/15/81	10/18/81-12/08/81
Gross alpha (dissolved)	12,13,28	Meantstd.dev. det./total range	L.T. 4. E 00 0/9 --	4.9 +-3.9 E 00 1/9 --	L.T. 4. E 00 0/9 --	L.T. 4. E 00 0/9 --
Gross alpha (suspended)	12,13,28	Meantstd.dev. det./total range	L.T. 1. E 00 0/9 --	2.4 +-1.5 E 00 6/9 (0.7-4.5) E 00	L.T. 2. E 00 0/9 --	7.2 +-4.5 E-01 1/9 --
Gross beta (dissolved)	12,13,28	Meantstd.dev. det./total range	7.1 +-2.6 E 00 9/9 (0.4-1.1) E 01	1.1 +-0.1 E 01 6/9 (0.9-1.3) E 01	1.1 +-0.3 E 01 9/9 (0.8-1.8) E 01	9.3 +-1.5 E 00 9/9 (8.0-12.0) E 00
Gross beta (suspended)	12,13,28	Meantstd.dev. det./total range	1.8 +-0.3 E 00 6/9 (1.6-2.3) E 00	5.6 +-2.8 E 00 9/9 (0.3-1.1) E 01	4.8 +-2.7 E 00 9/9 (1.2-7.3) E 00	2.9 +-0.6 E 00 9/9 (1.6-3.7) E 00
Sr-89	12,13,28	Meantstd.dev. det./total range	L.T. 1. E 00 0/9 --	L.T. 1. E 00 0/9 --	L.T. 1. E 00 0/9 --	L.T. 1. E 00 0/9 --
Sr-90	12,13,28	Meantstd.dev. det./total range	L.T. 8. E-01 0/9 --	L.T. 9. E-01 0/9 --	L.T. 1. E 00 0/9 --	L.T. 8. E-01 0/9 --
H-3 (a)	12,13,28	Meantstd.dev. det./total range	2.6 +-0.2 E 02 3/3 (2.5-2.8) E 02	3.1 +-0.3 E 02 3/3 (2.9-3.4) E 02	4.3 +-1.1 E 02 3/3 (3.0-5.2) E 02	2.1 +-0.2 E 02 3/3 (2.0-2.3) E 02

(a) Tritium analysis is performed on the quarterly composite of all stations only. See the accompanying Table P-2 for the eighteen gamma emitters monitored below the limits of detection on the quarterly composite.

TABLE 2-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - WATERBORNE
 RIVER WATER - pCi/liter

SAMPLE NUCLIDE	STATION NUMBER	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
		01/06/81-03/10/81	04/13/81-06/15/81	07/20/81-09/15/81	10/18/81-12/08/81
Be-7	12,13,28	L.T. 1. E 02 (0/3)	L.T. 1. E 02 (0/3)	L.T. 1. E 02 (0/3)	L.T. 8. E 01 (0/3)
K-40	12,13,28	L.T. 2. E 02 (0/3)	L.T. 2. E 02 (0/3)	L.T. 2. E 02 (0/3)	L.T. 2. E 02 (0/3)
Mn-54	12,13,28	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 8. E 00 (0/3)	L.T. 6. E 00 (0/3)
Co-58	12,13,28	L.T. 1. E 01 (0/3)	L.T. 9. E 00 (0/3)	L.T. 1. E 01 (0/3)	L.T. 8. E 00 (0/3)
Fe-59	12,13,28	L.T. 3. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 2. E 01 (0/3)
Co-60	12,13,28	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 5. E 00 (0/3)	L.T. 6. E 00 (0/3)
Zn-65	12,13,28	L.T. 2. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 1. E 01 (0/3)
Zr-95	12,13,28	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 9. E 00 (0/3)
Ru-103	12,13,28	L.T. 2. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 1. E 01 (0/3)
Ru-106	12,13,28	L.T. 6. E 01 (0/3)	L.T. 6. E 01 (0/3)	L.T. 8. E 01 (0/3)	L.T. 6. E 01 (0/3)
I-131	12,13,28	L.T. 6. E 02 (0/3)	L.T. 4. E 02 (0/3)	L.T. 2. E 02 (0/3)	L.T. 2. E 02 (0/3)
Cs-134	12,13,28	L.T. 8. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 8. E 00 (0/3)	L.T. 6. E 00 (0/3)
Cs-137	12,13,28	L.T. 7. E 00 (0/3)	L.T. 7. E 00 (0/3)	L.T. 9. E 00 (0/3)	L.T. 7. E 00 (0/3)
Ba-140	12,13,28	L.T. 1. E 02 (0/3)	L.T. 9. E 01 (0/3)	L.T. 6. E 01 (0/3)	L.T. 5. E 01 (0/3)
Ce-141	12,13,28	L.T. 4. E 01 (0/3)	L.T. 3. E 01 (0/3)	L.T. 3. E 01 (0/3)	L.T. 3. E 01 (0/3)
Ce-144	12,13,28	L.T. 7. E 01 (0/3)	L.T. 7. E 01 (0/3)	L.T. 7. E 01 (0/3)	L.T. 6. E 01 (0/3)
Ra-226	12,13,28	L.T. 2. E 02 (0/3)	L.T. 2. E 02 (0/3)	L.T. 2. E 02 (0/3)	L.T. 1. E 02 (0/3)
Th-232	12,13,28	L.T. 1. E 01 (0/3)	L.T. 1. E 01 (0/3)	L.T. 2. E 01 (0/3)	L.T. 1. E 01 (0/3)

Q. ANIMALS - RABBITS (See Tables Q-1 and Q-2)

STATION 28 and 35

Rabbit samples were collected from stations 28 and 35 in the fall of 1981. The femur was analyzed for Sr-89 and Sr-90, the thyroid gland for I-131 and the muscle for gamma emitters. Strontium 90 was detected in four of four samples analyzed at a level slightly lower than previous years. Iodine-131 analyses were below the minimum level of detection. There were no gamma emitters detected except for naturally occurring K-40 which was at the same level as in the previous years from 1977 through 1980. Cesium -137 was at or below the lower limit of detection.

The results of the monitoring of rabbit samples indicate that no nuclear plant effects resulting from the operations of CNS were detectable in animal life.

TABLE Q-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 RABBITS pCi/Gm WET

SAMPLE NUCLIDE	STATION NUMBER		4th Quarter 11/05-11/09
Sr-89 (femur)	28,35	Mean ± std. dev. det./total range	L.T. 2. E-01 0/4 -
Sr-90 (femur)	28,35	Mean ± std. dev. det./total range	1.3 ± 0.6 E-01 4/4 (0.6-1.8) E-01
I-131 (thyroid)	28,35	Mean ± std. dev. det./total range	L.T. 7. E-01 0/4 -
K-40 (flesh)	28,35	Mean ± std. dev. det./total range	3.1 ± 0.5 E 00 4/4 (2.5-3.5) E 00
Cs-137	28,35	Mean ± std. dev. det./total range	L.T. 6. E-02 0/4 -

TABLE Q-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 RABBITS pCi/gm WET

SAMPLE NUCLIDE	STATION NUMBER	4th Quarter 11/05-11/09		
		L.T.	S.	E-01 (0/4)
Be-7	28,35	3.1 ± 0.5	00	(4/4)
K-40	28,35	L.T.	7.	E-02 (0/4)
Mn-54	28,35	L.T.	7.	E-02 (0/4)
CO-58	28,35	L.T.	1.	E-01 (0/4)
Fe-59	28,35	L.T.	6.	E-02 (0/4)
Co-60	28,35	L.T.	1.	E-01 (0/4)
Zn-65	28,35	L.T.	7.	E-02 (0/4)
Zr-95	28,35	L.T.	7.	E-02 (0/4)
Ru-103	28,35	L.T.	5.	E-01 (0/4)
Ru-106	28,35	L.T.	2.	E-01 (0/4)
I-131	28,35	L.T.	7.	E-02 (0/4)
Cs-134	28,35	L.T.	6.	E-02 (0/4)
Cs-137	28,35	L.T.	1.	E-01 (0/4)
Ba-140	28,35	L.T.	1.	E-01 (0/4)
Ce-141	28,35	L.T.	5.	E-01 (0/4)
Ce-144	28,35	L.T.	1.	E 00 (0/4)
Ra-226	28,35	L.T.	1.	E-01 (0/4)
Th-228	28,35			

R. AQUATIC VEGETATION (See Tables R1 and R2)

STATION 12, 13, 28

Aquatic vegetation was scheduled to be collected semiannually and measured for gross beta, Sr-89, Sr-90 and gamma emitters. Samples were collected during the fall of 1981 at stations 12 and 28. No sample was available at station 13. No samples were collected during the summer of 1981 at any of the three stations because of dry conditions and lack of growth. No samples had been obtained in 1977 and 1979 for the same reasons.

The gross beta activity was slightly higher than in the past at 3.8 pCi/gm, wet. There were no detections of Sr-89 or Sr-90.

Potassium-40 was detected in one sample at the same level as in previous years. Manganese-54, Co-58 and Co-60, which are neutron activation products, were detected in both samples collected; Mn-54 at 0.35 pCi/gm, wet, Co-58 at 0.52 pCi/gm, wet, and Co-60 at 0.77 pCi/gm wet. This is slightly higher than the levels detected in 1980. Since the sampling locations are in close proximity (Station 12 is within the site boundaries and Station 28 is within three miles downstream of the discharge point), it is assumed that these nuclides originated from CNS. No other gamma emitters were detected above the minimum level of detection.

TELEDYNE ISOTOPES

TABLE R-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 VEGETATION/AQUATIC - pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER	Mean \pm std. dev. det./total range	4th Quarter 10/17/81
Gross Beta	12, 15, 28 (a)	3.8 \pm 0.3 E 00 2/2 (3.6-4.0) E 00	
Sr-89	12, 28	Mean \pm std. dev. det./total range	L.T. 2. E-02 0/2 --
Sr-90	12, 28	Mean \pm std. dev. det./total range	L.T. 1. E-02 0/2 --
K-40	12, 28	Mean \pm std. dev. det./total range	3.9 \pm 0.7 E 00 1/2 --
Mn-54	12, 28	Mean \pm std. dev. det./total range	3.5 \pm 0.7 E-01 2/2 (3.0-4.0) E-01

(a) Sample was not collected at Station 15; no sample available.

TABLE R-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 VEGETATION/AQUATIC - PCI/SM, wet

SAMPLE NUCLIDE	STATION NUMBER	Mean \pm std. dev. det./total range	4th Quarter 10/17/81
Co-58	12,28	5.2 \pm 0.7 E-01 2/2 (4.7-5.7) E-01	
Co-60	12,28	7.7 \pm 1.5 E-01 2/2 (6.6-8.8) E-01	
Cs-137	12,28	L.T. 1. E-01 0/2 --	

TABLE R-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - INGESTION
 VEGETATION/AQUATIC - pCi/gm, wet

SAMPLE NUCLIDE	STATION NUMBER	4th Quarter 10/17/81
Be-7	12,13,28	L.T. 8. E-01 (0/2) 3.9 ± 0.7 E 00 (1/2)
K-40	12,13,28	3.5 ± 0.7 E-01 (2/2)
Mn-54	12,13,28	5.2 ± 0.7 E-01 (2/2)
Co-58	12,13,28	L.T. 2. E-01 (0/2)
Fe-59	12,13,28	7.7 ± 1.5 E-01 (2/2)
Co-60	12,13,28	L.T. 2. E-01 (0/2)
Zn-65	12,13,28	L.T. 1. E-01 (0/2)
Zr-95	12,13,28	L.T. 1. E-01 (0/2)
Ru-103	12,13,28	L.T. 8. E-01 (0/2)
Ru-106	12,13,28	L.T. 2. E-01 (0/2)
I-131	12,13,28	L.T. 1. E-01 (0/2)
Cs-134	12,13,28	L.T. 1. E-01 (0/2)
Cs-137	12,13,28	L.T. 1. E-01 (0/2)
Ba-140	12,13,28	L.T. 2. E-01 (0/2)
Ce-141	12,13,28	L.T. 8. E-01 (0/2)
Ce-144	12,13,28	L.T. 2. E 00 (0/2)
Ra-226	12,13,28	L.T. 2. E-01 (0/2)
Th-228	12,13,28	

5. SOIL (See Tables S1 and S2)

STATIONS 2,3,4,5,6,7,8,9,10

Soil samples, which are collected every three years, were collected on September 10, 1981. Samples were analyzed for Sr-90 and gamma emitting isotopes. Strontium-90 was detected in 9 of 11 samples at a level of 0.16 pCi/gm, dry. This is very close to the levels detected in 1975 and 1978.

Among the gamma emitters K-40 remained at the previous level of 17.0 pCi/gm, dry. Radium-226 and Thorium-228 levels also remained constant. Trace levels of Cs-137 were detected in eleven of eleven samples and of Zr-95 in one of eleven samples. These nuclides were also detected in air particulate samples and are probably due to fallout from the Chinese nuclear atmospheric weapons tests of October 16, 1980. There is no indication of a plant effect.

TRITIUM ISOTOPES

TABLE S-1
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 SOIL - pCi/gm, dry

SAMPLE NUCLIDE	STATION NUMBER	Mean±std.dev. det./total range	3rd Quarter 09/21/81
Sr-90	2,3,4,5,6,7, 8,9,10	1.6 ± 0.5 E-01 9/11 (0.8-2.1) E-01	
K-40	2,3,4,5,6,7, 8,9,10	1.7 ± 0.2 E 01 10/11 (1.5-2.0) E 01	
Zr-95	2,3,4,5,6,7, 8,9,10	1.5 ± 0.6 E-01 1/11 --	
Cs-137	2,3,4,5,6,7, 8,9,10	4.4 ± 2.2 E-01 11/11 (0.9-7.2) E-01	
Ra-226	2,3,4,5,6,7, 8,9,10	1.9 ± 0.5 E 00 1/11 (1.5-2.8) E 00	
Th-228	2,3,4,5,6,7, 8,9,10	1.1 ± 0.2 E 00 11/11 (0.8-1.6) E 00	

TABLE S-2
 NEBRASKA PUBLIC POWER DISTRICT
 COOPER NUCLEAR STATION
 EXPOSURE PATHWAY - AIRBORNE
 SOIL - (pCi/Gm, dry)

SAMPLE NUCLIDE	STATION NUMBER	3rd Quarter 09/21/81
Be-7	2,3,4,5,6,7,8,9,10	7.2 ± 3.4 E-01 (1/11)
K-40	2,3,4,5,6,7,8,9,10	1.7 ± 0.2 E 01 (10/11)
Mn-54	2,3,4,5,6,7,8,9,10	L.T. 4. E-02 (0/11)
Co-58	2,3,4,5,6,7,8,9,10	L.T. 4. E-02 (0/11)
Fe-59	2,3,4,5,6,7,8,9,10	L.T. 1. E-01 (0/11)
Co-60	2,3,4,5,6,7,8,9,10	L.T. 3. E-02 (0/11)
Zn-65	2,3,4,5,6,7,8,9,10	L.T. 1. E-01 (0/11)
Zr-95	2,3,4,5,6,7,8,9,10	1.3 ± 0.6 E-01 (1/11)
Ru-103	2,3,4,5,6,7,8,9,10	L.T. 6. E-02 (0/11)
Ru-106	2,3,4,5,6,7,8,9,10	L.T. 4. E-01 (0/11)
I-131	2,3,4,5,6,7,8,9,10	L.T. 2. E-01 (0/11)
Cs-134	2,3,4,5,6,7,8,9,10	L.T. 4. E-02 (0/11)
Cs-137	2,3,4,5,6,7,8,9,10	4.4 ± 2.2 E-01 (11/11)
Ba-140	2,3,4,5,6,7,8,9,10	L.T. 1. E-01 (0/11)
Ce-141	2,3,4,5,6,7,8,9,10	L.T. 7. E-02 (0/11)
Ce-144	2,3,4,5,6,7,8,9,10	L.T. 2. E-01 (0/11)
Ra-226	2,3,4,5,6,7,8,9,10	1.9 ± 0.5 E 00 (11/11)
Th-228	2,3,4,5,6,7,8,9,10	1.1 ± 0.2 E 00 (11/11)

T. AMBIENT RADIATION - THERMOLUMINESCENT DOSIMETERS (TLDs - TABLE T-1)

STATIONS 01-10,15,18,22,44,58,59

Ambient radiation was monitored at 16 locations within a 10 mile radius of CNS and collected quarterly. The quarterly averages of ambient net gamma radiation ranged from 19.4+-4.4 milliRoentgen/quarter to 21.2+-5.5 milliRoentgen/quarter. The highest exposure during each of the four quarters at station 01 (0.1 mile, 225 degrees) and averaged 37.1+-5.6 mR/quarter. The lowest exposure was at station 03 (2.5 miles, 338 degrees) and averaged 17.1 mR/quarter.

These exposures were considerably below the 125 millirems per quarter specified in 10 CFR 20.105 for an unrestricted area. The relationship between milliRoentgen (mR) and millirems (mr) is approximately one for the exposure conditions encountered. No plant effect from CNS was indicated.

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

EXPOSURE PATHWAY - AMBIENT GAMMA RADIATION: TLD

milliRoentgen/Quarter

SAMPLE NUCLIDE	STATION NUMBER	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
		01/02/81-04/01/81	04/01/81-07/01/81	07/01/81-10/01/81	10/01/81-01/04/82
TLD Gamma	01	42.0 ± 0.8 (a)	30.4 ± 2.2	41.5 ± 0.8	34.6 ± 4.7
	02	18.8 ± 0.6	18.7 ± 0.3	19.5 ± 0.7	18.2 ± 0.6
	03	17.6 ± 0.5	16.9 ± 0.2	18.7 ± 1.3	15.3 ± 1.1
	04	18.2 ± 0.2	18.4 ± 0.5	18.3 ± 0.5	16.8 ± 0.2
	05	18.5 ± 0.2	19.1 ± 0.8	19.1 ± 0.5	17.6 ± 0.5
	06	18.9 ± 0.6	18.8 ± 0.4	19.2 ± 0.3	17.0 ± 0.6
	07	18.8 ± 0.2	18.8 ± 0.3	18.8 ± 0.4	17.8 ± 0.1
	08	19.6 ± 0.4	13.5 ± 0.7	19.9 ± 0.5	18.1 ± 0.3
	09	18.2 ± 0.3	18.3 ± 0.3 (a)	18.4 ± 0.4	17.7 ± 1.5
	10	18.9 ± 0.3	19.0 ± 0.6	18.8 ± 0.6	17.4 ± 0.8
	15	19.4 ± 0.4	19.5 ± 0.4	20.7 ± 1.3	16.7 ± 1.0
	18	19.8 ± 0.3	20.5 ± 0.3	20.3 ± 0.4	21.4 ± 1.8
	22	20.1 ± 0.7	21.1 ± 0.3	21.5 ± 0.8	18.4 ± 0.4
	44	21.2 ± 0.5	22.3 ± 1.0	22.3 ± 0.5	21.1 ± 0.4
	58	20.7 ± 0.3	21.0 ± 0.4	21.0 ± 0.6	19.5 ± 0.3
	59	19.8 ± 0.3	21.8 ± 0.3	21.0 ± 0.4	19.6 ± 0.2
Average/Quarter		20.7 ± 5.8 mR/89 days	19.9 ± 3.5 mR/91 days	21.1 ± 5.5 mR/92 days	19.2 ± 4.4 mR/95 days
Average/Day		0.23 ± 0.07 mR/day	0.22 ± 0.04 mR/day	0.23 ± 0.06 mR/day	0.20 ± 0.05 mR/day
Range		(17.6-42.0) mR/89 days	(13.5-30.4) mR/91 days	(18.3-41.5) mR/92 days	(15.3-34.6) mR/95 days
Det./Total		16/16	16/16	16/16	16/16

(a) Average of Areas 1, 2 and 3. Using the criterion that, if the value of one area is outside the range of 3 standard deviations from the average of the other 3 areas, then that area will be excluded from the final average determination.