

MAY 05 1982

Docket No. 50-244

Rochester Gas and Electric Corporation  
ATTN: Mr. John E. Maier  
Vice President  
Electric and Steam Production  
89 East Avenue  
Rochester, New York 14649



Gentlemen:

Subject: Inspection 50-244/82-03

This refers to your letter dated April 16, 1982, in response to our letter dated March 18, 1982.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a future inspection of your licensed program.

With regard to Violation A, we are retracting the citation based on your acceptable description of the procedural controls which remain in effect to ensure that timely corrective action will be initiated upon exceeding a predetermined administrative limit for pump bearing temperature.

Your cooperation with us in this matter is appreciated.

Sincerely,

*E. J. Brunner*

*for*

Richard W. Starostecki, Director  
Division of Project and Resident  
Programs

cc:  
Harry H. Voigt, Esquire  
Central Records (3 copies)  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
State of New York

8205100212 820505  
PDR ADOCK 05000244  
PDR

bcc:  
Region I Docket Room (w/concurrences)

IE01

OFFICE	RI: DPRP <i>JK</i>	RI: DPRP <i>JK</i>	RI: DPRP <i>JK</i>				
SURNAME	Zimmerman/cc	Kister	Brunner				<i>Sill</i>
DATE	<i>5/3/82</i>	<i>5/3/82</i>	<i>5/4</i>				