





Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 STA 3 UNIT 82 YEAR 24 NO.

PART 1 TITLE OF DEVIATION: Leak on Condensate Booster Line to Condenser OCCURRED DATE: 4/7/82 TIME: 1630

SYSTEM AFFECTED: 3400 Condensate PLANT STATUS AT TIME OF EVENT: MODE: Refuel PWR(MWT): 0 LOAD(MWE): 0 TESTING: YES NO

DESCRIPTION OF EVENT: A leak was found by Shift Foreman on 1 inch line off of condensate booster recirculation line to the main condenser.

EQUIPMENT FAILURE: 19738 WORK REQUEST NO. RESPONSIBLE SUPERVISOR: F. W. Knollhoff DATE: 4/7/82

PART 2 OPERATING ENGINEER'S COMMENTS: All leakage was contained within the turbine building floor sumps. The leak was repaired by cutting and capping the 1 inch tap prior to restart of the condensate system.

EVENT OF PUBLIC INTEREST, TECH. SPEC. VIOLATION, NON REPORTABLE OCCURRENCE, 14 DAY REPORTABLE/T.S., 30 DAY REPORTABLE/T.S. 6.6.B.2.d, ANNUAL/SPECL REPORT REQ'D, 24-HOUR NRC NOTIFICATION REQ'D, TELEPH M. Jordan (courtesy) 4/8/82 1200, TELEGM/TELECOPY REGION III, CECO CORPORATE NOTIFICATION MADE, 5-DAY WRITTEN REPORT REQ'D PER 10CFR21, TELEPH F. A. Palmer 4/12/82 1404

PRELIMINARY REPORT COMPLETED AND REVIEWED: Michael Wright OPERATING ENGINEER 4/12/82 DATE

INVESTIGATED REPORT & RESOLUTION ACCEPTED BY STATION REVIEW: Jack Brunner 5/3/82, Michael Wright 5-3-82

RESOLUTION APPROVED AND AUTHORIZED FOR DISTRIBUTION: Douglas [Signature] STATION SUPERINTENDENT 5/3/82 DATE