



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 7, 1982

NUCLEAR PRODUCTION DEPARTMENT

U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Washington, D. C. 20555

Attention: Mr. Harold R. Denton, Director

Dear Mr. Denton:

SUBJECT: Grand Gulf Nuclear Station  
Units 1 and 2  
Docket Nos. 50-416 and 50-417  
File: 0260/0651  
Ventilation Radiation Monitoring Systems  
AECM-82/205



The following information is being provided by Mississippi Power & Light Company (MP&L) in order to update the operational status of Grand Gulf Nuclear Station's (GGNS) ventilation radiation monitoring systems.

The GGNS design as described in FSAR Subsections 11.5.2.2.4, 11.5.2.2.6 thru 9 and 18.1.27.1 provides for ventilation radiation monitoring at the following release point locations; containment purge, fuel handling area, standby gas treatment (SGTS) A&B, turbine building, and off gas & radwaste building ventilation. The two types of monitoring systems utilized in this design are a General Electric (GE) constant flow (normal range) system and a microprocessor-based ventilation radiation monitoring system (NUREG 0737, 11.F.1, normal and accident range). Each of the above release point locations are serviced by both types of monitoring systems with the exception of SGTS A&B, which utilizes only the microprocessor-based monitoring system. All of the monitoring systems for the above locations are currently installed; however, due to delays in testing, the microprocessor-based monitoring systems will not be operable prior to fuel loading and during low power physics testing.

As proposed in letter AECM-82/55, dated February 15, 1982, the Turbine Building and Off Gas & Radwaste Building Ventilation Radiation Monitoring Systems are not required to be operational in order to safely conduct Phase I operations because of inconsequential fission product inventory. However, efforts are being made to ensure that the Containment Purge and Fuel Handling Area GE Constant Flow Radiation Monitoring Systems will be operable prior to fuel loading. For the same reasons noted above from AECM-82/55, the microprocessor-based ventilation radiation monitoring systems are not required for plant safety during Phase I Operations. These systems and the Turbine Building and Off Gas & Radwaste Building Ventilation GE Constant Flow Radiation Monitoring Systems will be operable prior to conducting power ascension testing (Phase II operations).

Boo!  
1/0

8205110179 820507  
PDR ADOCK 05000416  
A PDR


MISSISSIPPI POWER & LIGHT COMPANY

AECM-82/205

Page 2

With adequate ventilation radiation monitoring provisions during Phase I operations (fuel loading and low power testing), MP&L contends that interim operations is justified. If you have any questions or require further information, please contact this office.

Yours truly,



L. F. Dale  
Manager of Nuclear Services

JTB/JGC/JDR:rg

cc: Mr. N. L. Stampley  
Mr. R. B. McGehee  
Mr. T. B. Conner  
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. P. O'Reilly, Regional Administrator  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303