



Certified By

M. A. Perkins

ROCHESTER GAS AND ELECTRIC CORPORATION • 89 EAST AVENUE, ROCHESTER, N.Y. 14649

TELEPHONE
AREA CODE 716 546-2700

January 28, 1982

Mr. Ronald C. Haynes,
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, PA 19406

Subject: LER 82-004/01T, Removal of Fire Watches From Inoperable
Fire Zones

Dear Mr. Haynes:

As a result of a conversation with Mr. Roy Zimmerman and Mr. Jim Wiggins regarding the failure to notify Region I of a 24 hour notification event, the direction of the Resident Inspector was to submit this letter to provide notification of LER 82-004.

In accordance with Technical Specification 6.9.2.a.2, "Operation of the unit or affected systems when any parameter or operation subject to a limiting condition is less conservative than the least conservative aspect of the limiting condition for operation established in the technical specification", the following is submitted.

On January 25, 1982, Ginna Station experienced an event described in LER 82-003 which required site evacuation. Due to this evacuation, fire watches posted for inoperable spray/sprinkler systems were evacuated from their posts. Further information regarding this LER will be submitted with the 14 Day Written Report.

Rochester Gas & Electric Corporation regrets the delay in submitting this 24 hour notification.

Bruce A. Snow

Bruce A. Snow
Plant Superintendent

8205140233 820128
PDR ADDCK 05000244
S PDR

xc: J. E. Maier
R. P. Zimmerman, NRC Resident Inspector
CAR 1352 File

IE 29
5/0