

APPENDIX A
NOTICE OF VIOLATION

Duke Power Company
Catawba 1 and 2

Docket Nos. 50-413 & 50-414
License Nos. CPPR-116 & -117

As a result of the inspection conducted on February 23-26, 1982, and in accordance with the Interim Enforcement Policy, 45 FR 66754 (October 7, 1980), the following violations were identified.

10 CFR 50, Appendix B Criteria XVII, as implemented by Duke Power Company Topical Report Duke-1 paragraph 17.1.17, requires records shall be maintained to furnish evidence of activities affecting quality and inspection records shall as a minimum identify the inspector, the type of observation, the results and the acceptability...

Contrary to the above, on February 23-26, inspection records did not identify the inspector, type of observation, the results and acceptability of the inspection in that no inspection records were initiated for the periodic-general-storage inspections that were made of the yard area adjacent to the containment and auxiliary buildings.

This is a Severity Level VI Violation (Supplement II.F).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation.

Date: MAR 18 1982

8205140385 820416
PDR ADOCK 05000413
Q PDR