

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | 1 1 L Q A D 2 | 2 0 0 0 - 0 0 0 - 0 0 0 | 3 4 1 1 1 1 | 4 | 5
7 8 9 14 15 25 26 30 57 CAT 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 | L | 6 0 5 0 0 0 2 6 5 | 7 0 4 2 0 8 2 | 8 0 4 2 9 8 2 | 9
7 8 60 61 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing QIS-6, High Drywell Pressure Scram Calibration and Functional
0 3 | Test, pressure switch PS-2-1001-88D was found to trip at 2.2 psig which is 0.2
0 4 | psig higher than the Technical Specification limit in Table 3.1-3. This was
0 5 | of minimal consequence since the other three pressure switches in the one-out-
0 6 | of two-twice logic circuit were found to be in calibration and would have
0 7 | initiated a Reactor scram upon detecting high Drywell pressure.

0 8 | _____ | _____ | _____ | _____ | _____ | _____ | _____ | _____ | _____
7 8 9

0 9 | I A | E | E | I N S T R U | S | Z
7 8 9 10 11 12 13 14 15 16
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

17 | 8 2 | _____ | 0 0 5 | | 0 3 | L | 0
21 22 23 24 25 26 27 28 29 30 31 32
 LER NO REPORT NUMBER EVENT YEAR SHUTDOWN METHOD SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

E | Z | Z | Z | 0 0 0 0 | N | Y | N | S 3 8 2
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this occurrence was instrument setpoint drift. The pressure switch
1 1 | (Static-0-Ring, Model 12N-AA5-PP) was recalibrated and functionally tested.
1 2 | These switches do display some tendency for drifting, however, the frequency
1 3 | of occurrence is low for any one switch. Therefore, no other corrective action
1 4 | is necessary at this time.

1 5 | E | 0 9 9 | NA | B | Routine Test
7 8 9 10 11 12 13 44 45 46
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | Z | _____ | NA | NA | NA
7 8 9 10 11 44 45 46
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 0 0 | Z | NA
7 8 9 10 11 12 13
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 0 0 | _____ | NA
7 8 9 10 11 12
 PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | _____ | NA
7 8 9 10
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N | _____ | NA
7 8 9 10 11 12
 PUBLICITY ISSUED DESCRIPTION

NRC USE ONLY

8205140411 820429 PDR ADOCK 05000265 PDR
 Knospel
 PHONE 309-654-2241, ext. 187
 GPO 91 7-928