

yellow

FEB 25 1982

Virginia Electric and Power Company
ATTN: Mr. R. H. Leasburg, Vice President
Nuclear Operations
P. O. Box 26666
Richmond, VA 23261

Gentlemen:

IA

Subject: Report Nos. 50-338/82-01, 50-339/82-01

This refers to the routine safety inspection conducted by Messrs. G. A. Belisle, P. E. Fredrickson and P. H. Skinner of this office on January 18-28, 1982, of activities authorized by NRC License Nos. NPF-4 and NPF-7 for the North Anna facility. Our preliminary findings were discussed with Mr. R. H. Leasburg, Vice President, Nuclear Operations Department, at the conclusion of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

During the inspection, it was found that certain activities under your license appear to violate NRC requirements. These items and references to pertinent requirements are listed in the Notice of Violation enclosed herewith as Appendix A. Elements to be included in your response are delineated in Appendix A.

We have examined actions you have taken with regard to previously identified enforcement matters and unresolved items. The status of these items is discussed in the enclosed report.

As discussed in paragraph 6.b of the enclosed report, plant drawings have not been updated in a timely manner to include certain previous design changes. This matter was discussed by Mr. W. R. Cartwright of your staff with Mr. K. D. Landis of this office on February 12, 1982. Based on this telephone conversation, we understand that a procedure will be developed by March 1, 1982, that will require updating applicable controlled drawings to reflect future design changes within two days after the design change has been installed. In addition, controlled drawings impacted by previous design changes will be upgraded to reflect these changes by March 12, 1982.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC's Public Document Room unless you notify this office, by telephone, within ten days of the date of this letter and submit written application to withhold information contained therein within thirty days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1).

8205140425 820503
PDR ADOCK 05000338
PDR

FEB 25 1982

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

FL

F. J. Long, Acting Chief
Reactor Projects Branch 2
Division of Project and
Resident Programs

Enclosure:

- 1. Appendix A, Notice of Violation
- 2. Inspection Report Nos. 50-338/82-01,
50-339/82-01

cc w/encl:

D. G. Godwin, Director, Nuclear Security
 J. H. Ferguson, Executive Vice President
 W. R. Cartwright, Station Manager

bcc w/encl:

Document Management Branch
 Commonwealth of Virginia
 NRC Resident Inspector

RII

GAB
 GBelisle:es
 2/24/82

RII

Upright
 CUpright
 2/24/82

RII

Murphy 3/24/82
~~Jolshinksi
 2/24/82~~

RII

Kof
 KLandis
 2/25/82

RII

HD
 HDance
 2/25/82

RII

~~RC Lewis
 2/25/82~~

FAL
 Long
 2/25/82

*actual the signed
 by Long not Lewis*