

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 14 15 25 26 30 57 58 59

0 1 N J S G S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE 57 CAT 58

CON'T

7 8 60 61 68 69 74 75 80

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 1 7 0 4 1 8 8 2 8 0 5 0 5 8 2 9

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 On April 18, 1982, during routine operation, the Control Room Operator noticed that

0 3 No. 1C4 Rod Position Indicator (RPI) was more than 12 steps lower than the bank de-

0 4 mand position indicator. No. 1C4 RPI was declared inoperable at 0400 hours, and

0 5 Action Statement 3.1.3.2.1.a was entered. This constituted operation in a degraded

0 6 mode in accordance with Technical Specification 6.9.1.9.b.

0 7 (82-010, 81-121, 81-108, 81-098, 81-097)

7 8 9

0 8 \_\_\_\_\_ 80

SYSTEM CODE I D 11	CAUSE CODE B 12	CAUSE SUBCODE A 13	COMPONENT CODE I N S T R U 14	COMP. SUBCODE I 15	VALVE SUBCODE Z 16
LER RO REPORT NUMBER 17	EVENT YEAR 8 2 21 22	SEQUENTIAL REPORT NO. 0 2 6 23 24 26	OCCURRENCE CODE 0 3 27 28 29	REPORT TYPE L 30	REVISION NO. 0 31 32
ACTION TAKEN E 18	FUTURE ACTION Z 19	EFFECT ON PLANT Z 20	SHUTDOWN METHOD Z 21	HOURS 0 0 0 0 22 37 40	ATTACHMENT SUBMITTED Y 23 41
				NPRD-4 FORM SUB. N 24 42	PRIME COMP. SUPPLIER N 25 43
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27			COMPONENT MANUFACTURER B 0 4 0 26 44 47		

1 0 No. 1C4 RPI had drifted out of calibration. The RPI was properly recalibrated and

1 1 satisfactorily tested. At 1000 hours, April 18, 1982, No. 1C4 RPI was declared

1 2 operable, and Action Statement 3.1.3.2.1.a was terminated.

1 3 \_\_\_\_\_

1 4 \_\_\_\_\_ 80

FACILITY STATUS C 28	% POWER 0 4 9 29	OTHER STATUS NA 30	METHOD OF DISCOVERY A 31	DISCOVERY DESCRIPTION Operator Observation 32
ACTIVITY CONTENT Z 33	RELEASED OF RELEASE Z 34	AMOUNT OF ACTIVITY NA 35	LOCATION OF RELEASE NA 36	
PERSONNEL EXPOSURES NUMBER 0 0 0 37	TYPE Z 38	DESCRIPTION NA 39		
PERSONNEL INJURIES NUMBER 0 0 0 40	DESCRIPTION NA 41			
LOSS OF OR DAMAGE TO FACILITY TYPE Z 42	DESCRIPTION NA 43			
PUBLICITY ISSUED DESCRIPTION N 44	8205180 616		NRC USE ONLY	

NAME OF PREPARER R. Frahm PHONE: (609) 541-5900 629