

MAY 13 1982

Docket: 50-298

Nebraska Public Power District  
ATTN: J. M. Pilant, Director  
Licensing & Quality Assurance  
P. O. Box 499  
Columbus, Nebraska 68601

Gentlemen:

Subject: Response to Confirmatory Action Letter dated March 12, 1982,  
(Items 1, 2, 3, 4, and 5).

This letter is to acknowledge receipt of your letter dated March 19, 1982,  
concerning the above subject and to reflect our comments to your response.

Item 1

The licensee shall make 31 early warning system mobile siren units operable  
(installed in a vehicle or ready for immediate (5 minutes) installation), with  
parts on order for the remaining unit. Each unit shall be functionally tested  
on the vehicle for which it was intended.

Comment:

Item 1 appears adequate.

Item 4

The licensee shall develop and implement procedures or methods and provide  
necessary training to assure the following:

- a. that for each area in item 2 above, primary and alternate individuals responsible for emergency notification are identified for each route, this list is to be maintained current;
- b. that each primary or alternate individual identified in item 4.a will receive positive notification of the necessity to warn the public; and
- c. that no less than the minimum number of mobile siren units for each of the areas identified in item 2 will be continuously available for dispatch.

EPA *ook*  
CAHackney: gb  
5/3/82

RPB *A*  
TWesterman  
5/ /82

RPB *M*  
GLMadsen  
5/ /82

DDRRPEP *at/le*  
JGagliardo  
5//2/82

RA-BIV  
JTCollins  
5//1/82

8205180 675  
F

IE35  
5/11

Comment:

Item 4.a. appears to be adequate. Item 4.b. appears to be adequate, however, the positive notification and volunteer response times, time to traverse the route, and status changes will determine the adequacy of item 4.b.

Item 5

The licensee shall implement methods to assure that the 32 mobile siren units remain operable, including periodic maintenance and testing.

Comment:

Item 5 appears to be adequate, however, the training program will be a continuous program and will be given periodic inspection. The route reorganization will be reviewed upon your submittal of your findings to this office.

Item 2

The licensee shall provide an analysis of the minimum number of mobile siren units (in addition to the fixed stations) necessary for emergency notification, for each of the following areas: Peru, Brownville, Nemaha, Shubert, Rock Port, and Watson.

Item 3

The licensee shall provide revised route maps to reflect the minimum number of necessary mobile sirens identified in item 2 above.

Comment:

These items will be considered open until your reevaluation information is sent to this office for review and comment, and you receive our response.

If you have any questions, please do not hesitate to contact this office.

Sincerely,

Original signed by  
John T. Collins

John T. Collins  
Regional Administrator

bcc distrib. to RIV:  
RESIDENT INSPECTOR  
SECTION CHIEF  
KANSAS STATE DEPT. OF HEALTH  
NEBRASKA STATE DEPT. OF HEALTH  
J. COLLINS, RIV  
C. HACKNEY, RIV

cc: L. C. Lessor, Superintendent  
Cooper Nuclear Station  
P. O. Box 98  
Brownville, Nebraska 68321

bcc to DMB: (IE35)