

NEDO-24568
#1NED049
CLASS I
JUNE 1981
REVISION 1

**MARK I CONTAINMENT PROGRAM
PLANT UNIQUE LOAD
DEFINITION
ENRICO FERMI ATOMIC POWER
PLANT: UNIT 2**

B205190230 B20512
PDR ADOCK 05000341
A PDR

GENERAL  ELECTRIC

NEDO-24568

NEDO-24568
81NED049
Class 1
June 1981
Revision 1

MARK I CONTAINMENT PROGRAM
PLANT UNIQUE LOAD DEFINITION
ENRICO FERMI ATOMIC POWER PLANT: UNIT 2

This document prepared by personnel of
Nuclear Services Engineering

Approved: *A. E. Rogers*
A. E. Rogers, Manager
Reactor Performance Analysis

Approved: *J. Brandon*
J. Brandon, Manager
Nuclear Services Engineering

NUCLEAR FUEL AND SERVICES DIVISION • GENERAL ELECTRIC COMPANY
SAN JOSE, CALIFORNIA 95125

GENERAL  ELECTRIC

LEGAL NOTICE

The only undertakings of General Electric Company respecting information in this document are contained in the contract between Detroit Edison Company and General Electric Company for Mark I Containment Consulting Services, and nothing contained in this document shall be construed as changing the contract. The use of this information by anyone other than Detroit Edison Company, or for any purpose other than that for which it is intended, is not authorized; and with respect to any unauthorized use, General Electric Company makes no representation or warranty, and assumes no liability as to the completeness, accuracy, or usefulness of the information contained in this document.

CONTENTS

	<u>Page</u>
ABSTRACT	
INTRODUCTION	1
LOCA PRESSURE AND TEMPERATURE TRANSIENTS	3
DBA VENT SYSTEM THRUST LOADS, ZERO ΔP AND OPERATING ΔP	15
POOL SWELL TORUS VERTICAL LOADS	44
POOL SWELL IMPACT AND DRAG LOADS	53
VENT HEADER DEFLECTOR LOADS	62
DISTRIBUTION	70

TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
EF 4.1.1-1	Plant Conditions at Instant of DBA Pipe Break	6
EF 4.1.2-1	Plant Conditions at Instant of IBA Pipe Break	9
EF 4.1.3-1	Plant Conditions at Instant of SEA Pipe Break	12
EF 4.2-1	Nomenclature for DBA Vent System Thrust Load Section	18
EF 4.2-2	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations (Zero ΔP)	20
EF 4.2-3	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations (Operating ΔP)	33
EF 4.3.9-1	Vent Header Deflector Load	66

ILLUSTRATIONS

<u>Figure</u>	<u>Title</u>	<u>Page</u>
EF 4.1.1-1	DBA Containment Pressure Response	7
EF 4.1.1-2	DBA Containment Temperature Response	8
EF 4.1.2-1	IBA Containment Pressure Response	10
EF 4.1.2-2	IBA Containment Temperature Response	11
EF 4.1.3-1	SBA Containment Pressure Response	13
EF 4.1.3-2	SBA Containment Temperature Response	14
EF 4.2-1	Definition of Positive Thrust Loads	21
EF 4.2-2	Single Main Vent Forces (Zero ΔP)	23
EF 4.2-3	Vent Header Forces per Mitre Bend (Zero ΔP)	24
EF 4.2-4	Single Downcomer Forces (Zero ΔP)	25
EF 4.2-5	Total and Net Vertical Forces (Zero ΔP)	26
EF 4.2-6	Single Main Vent Forces (Zero ΔP)	27
EF 4.2-7	Vent Header Forces per Mitre Bend (Zero ΔP)	28
EF 4.2-8	Single Downcomer Forces (Zero ΔP)	29
EF 4.2-9	Total and Net Vertical Forces (Zero ΔP)	30
EF 4.2-10	Pressure Time Histories (Zero ΔP)	31
EF 4.2-11	Pressure Time Histories (Zero ΔP)	32
EF 4.2-12	Single Main Vent Forces (Operating ΔP)	34
EF 4.2-13	Vent Header Forces per Mitre Bend (Operating ΔP)	35
EF 4.2-14	Single Downcomer Forces (Operating ΔP)	36
EF 4.2-15	Total and Net Vertical Forces (Operating ΔP)	37
EF 4.2-16	Single Main Vent Forces (Operating ΔP)	38
EF 4.2-17	Vent Header Forces per Mitre Bend (Operating ΔP)	39
EF 4.2-18	Single Downcomer Forces (Operating ΔP)	40
EF 4.2-19	Total and Net Vertical Forces (Operating ΔP)	41

ILLUSTRATIONS (Continued)

<u>Figure</u>	<u>Title</u>	<u>Page</u>
EF 4.2-20	Pressure Time Histories (Operating ΔP)	42
EF 4.2-21	Pressure Time Histories (Operating ΔP)	43
EF 4.3.1-1	Net Torus Vertical Load (Operating ΔP)	47
EF 4.3.1-2	Net Torus Vertical Load (Zero ΔP)	48
EF 4.3.2-1	Average Submerged Pressure (Operating ΔP)	49
EF 4.3.2-2	Average Submerged Pressure (Zero ΔP)	50
EF 4.3.2-3	Torus Air Pressure (Operating ΔP)	51
EF 4.3.2-4	Torus Air Pressure (Zero ΔP)	52
EF 4.3.3-1	Pool Swell Displacement Distribution (Zero ΔP)	56
EF 4.3.3-2	Pool Swell Displacement Distribution (Operating ΔP)	57
EF 4.3.3-3	Pool Swell Velocity Distribution (Zero ΔP)	58
EF 4.3.3-4	Pool Swell Velocity Distribution (Operating ΔP)	59
EF 4.3.4-1	Longitudinal Vent Header Impact Velocity Distribution Based on EPRI Main Vent Orifice Test	60
EF 4.3.4-2	Longitudinal Time Delay Distribution Based on EPRI Main Vent Orifice Test	61
EF 4.3.9-1	Vent Header Load (Zero ΔP)	65

ABSTRACT

This document provides unique definition of specific containment loading conditions that would result from a postulated loss-of-coolant accident in the Enrico Fermi Atomic Power Plant: Unit Number 2. Transient information is provided for containment pressures and temperatures, vent system thrust, torus vertical loads, vent system pool swell impact loads and vent header deflector loads. The document has been prepared under the Mark I Containment Program to aid Detroit Edison Company in the performance of a containment structural evaluation.

.INTRODUCTION

This report provides specific transient loading information resulting from a postulated loss-of-coolant accident (LOCA) in the Enrico Fermi Atomic Power Plant: Unit Number 2. This report, in conjunction with the Mark I Containment Load Definition Report, was prepared for the Detroit Edison Company to use in the structural evaluation of the Mark I Containment system.

The following specific LOCA-related transient information is included:

- Pressure and temperature time histories for the drywell and wetwell
- Vent system thrust loads
- Net vertical pool swell loads and average submerged pressures on the wetwell
- Pool swell impact and drag loads on the vent system
- Vent header deflector loads.

Transient information is presented via a series of figures for each of the above areas. An alpha-numeric identification scheme was developed for the figures such that the alpha designation denotes the plant of interest, while the first three digits of the numeric designation denote the applicable discussion section in the Mark I Containment Program Load Definition Report (NEDO-21888).

Transient conditions presented in this report are results of plant unique testing and/or analysis for specific plant conditions that have been provided or requested by the aforementioned utility. Changes to those specific

plant conditions could result in changes to the transient information reported herein. If, after further review of this document, the responsible utility considers that such changes would be appropriate, the document can be modified accordingly.

LOCA Pressure and Temperature Transients

LOCA Pressure and Temperature Transients

This section provides the LOCA-induced pressure and temperature transients for the drywell and wetwell. The initial conditions for which the pressure and temperature responses were evaluated are also presented. Transient conditions are included for the design basis accident (DBA), intermediate break accident (IBA), and small break accident (SBA). The list of applicable figures and tables for this section is given on the following page.

The peak drywell pressure and temperature and the wetwell pressure and temperature at 30 seconds are identified on the DBA containment pressure and temperature plots (Figure 4.1.1-1 and 4.1.1-2).

The peak containment pressures, the containment temperatures at the end of RPV blowdown, and the containment pressures and temperatures at the time of ADS initiation are identified on the IBA and SBA containment pressure and temperature plots (Figures 4.1.2-1, 4.1.2-2, 4.1.3-1 and 4.1.3-2).

ENRICO FERMI 2

PLANT UNIQUE PRESSURE/TEMPERATURE RESPONSE FIGURES AND TABLES

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Table EF 4.1.1-1	Plant Conditions at Instant of DBA Pipe Break	Revision 2 ↓
Figure EF 4.1.1-1	DBA Containment Pressure Response	
Figure EF 4.1.1-2	DBA Containment Temperature Response	
Table EF 4.1.2-1	Plant Conditions at Instant of IBA Pipe Break	
Figure EF 4.1.2-1	IBA Containment Pressure Response	
Figure EF 4.1.2-2	IBA Containment Temperature Response	
Table EF 4.1.3-1	Plant Conditions at Instant of SBA Pipe Break	
Figure EF 4.1.3-1	SBA Containment Pressure Response	
Figure EF 4.1.3-2	SBA Containment Temperature Response	

Table KF 4.1.1-1

PLANT CONDITIONS AT INSTANT OF DBA PIPE BREAK

102X Licensed Power (MWt)	3358
Initial Suppression Pool Temperature (°F)	70.0
Downcomer Submergence (ft)	3.33
Airspace Volume (ft ³)	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	0.75
Wetwell	0.575

Revision 2




Figure EP 4.1.1)-1. DBA Containment Pressure Response




Figure 4.1.1-2. DBA Containment Temperature Response

Table EF 4.1.2-1
PLANT CONDITIONS AT INSTANT OF IBA PIPE BREAK

102X Licensed Power (Mwt)	3358
Initial Suppression Pool Temperature ($^{\circ}$ F)	95
Downcomer Submergence (ft)	3.33
Airspace Volume (ft ³)	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	0.75
Wetwell	0.575

Revision 2




Figure EP 4.1.2-1. IBA Containment Pressure Response




Figure EF 4.1.2-2. IBA Containment Temperature Response

Table EF 4.1.3-1

PLANT CONDITIONS AT INSTANT OF SBA PIPE BREAK

102% Licensed Power (MWt)	3358
Initial Suppression Pool Temperature (°F)	95
Downcomer Submergence (ft)	3.33
Airspace Volume (ft ³)	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	0.75
Wetwell	0.575

Revision 2




Figure EP 4.1.3-1. SBA Containment Pressure Response




Figure EP 4.1.3-2. SBA Containment Temperature Response

DBA Vent System Thrust Loads - Zero ΔP , Operating ΔP

DBA Vent System Thrust Loads - Operating and Zero ΔP

This section provides thrust loads for the main vents, vent header, and downcomers resulting from the postulated DBA for plant operation at a positive and zero drywell-wetwell pressure differential. The list of applicable figures and tables for this section is given on the following page.

Revision 2

ENFIGO FERMI 2

PLANT UNIQUE DBA VENT SYSTEM THRUST LOAD FIGURES AND TABLES - OPERATING ΔP

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Table EF 4.2-1	Nomenclature for DBA Vent System Thrust Load Section	Revision 2
Table EF 4.2-2	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations	
Figure EF 4.2-1	Definition of Positive Thrust Loads	
Figure EF 4.2-2	Single Main Vent Forces (0-5 secs)	
Figure EF 4.2-3	Vent Header Forces per Mitre Bend (0-5 secs)	
Figure EF 4.2-4	Single Downcomer Forces (0-5 secs)	
Figure EF 4.2-5	Total Vertical Forces, Net Vertical Force (0-5 secs)	
Figure EF 4.2-6	Single Main Vent Forces (0-30 secs)	
Figure EF 4.2-7	Vent Header Forces per Mitre Bend (0-30 secs)	
Figure EF 4.2-8	Single Downcomer Forces (0-30 secs)	
Figure EF 4.2-9	Total Vertical Forces, Net Vertical Force (0-30 secs)	
Figure EF 4.2-10	Pressure Time Histories (0-5 secs)	
Figure EF 4.2-11	Pressure Time Histories (0-30 secs)	

Table EF 4.2-1

NOMENCLATURE FOR DBA VENT SYSTEM THRUST LOAD SECTION

P _{DW}	Drywell pressure
P _W	Wetwell airspace pressure
P ₁	Main vent pressure
P ₂	Vent header pressure
P ₃	Downcomer pressure
F _{1V1}	Vertical force on a single main vent end cap
F _{1H1}	Horizontal force on a single main vent end cap
F _{1V2}	Vertical force on a single main vent mitre bend (applicable to Browns Ferry and Oyster Creek only)
F _{1H2}	Horizontal force on a single main vent mitre bend (applicable to Browns Ferry and Oyster Creek only)
F _{2V}	Vertical force on vent header (per mitre bend)
F _{2H}	Horizontal force on vent header (per mitre bend)
F _{3V}	Vertical force on a single downcomer mitre bend
F _{3H}	Horizontal force on a single downcomer mitre bend
F _{4V}	Vertical force on second mitre bend of a single downcomer (if applicable)
F _{4H}	Horizontal force on second mitre bend of a single downcomer (if applicable)
F _{1V1T}	Total main vent end cap vertical force - F _{1V1} x number of main vents
F _{1V2T}	Total main vent mitre bend vertical force = F _{1V2} x number of main vents
F _{2VT}	Total vent header vertical force = F _{2V} x number of vent header mitre bends
F _{3VT}	Total vertical force (first downcomer mitre bend) = F _{3V} x number of downcomers
F _{4VT}	Total vertical force (second downcomer mitre bend) = F _{4V} x number of downcomers
F _{NETV}	F _{NETV} = F _{1V1T} + F _{1V2T} + F _{2VT} + F _{3VT} + F _{4VT}
A _{VH}	Vent header flow area
A _{VP}	Total main vent flow area

Table EF 4.2-1 (Continued)


NOMENCLATURE FOR DBA VENT SYSTEM THRUST LOAD SECTION

A_{DC}	Total downcomer flow area
n_1	Number of main vents
n_2	Number of downcomers
n_3	Number of vent header mitre bends
\dot{m}_t	Total mass flow rate
v_1	Fluid velocity in main vent
v_2	Fluid velocity in vent header
v_3	Fluid velocity in downcomer
ϵ_1	Angle of main vent with horizontal
ϵ_2	Angle of first downcomer mitre bend with horizontal
ϵ_3	Angle of second downcomer mitre bend with horizontal
α	Angle of main vent mitre bend with horizontal
δ	$90^\circ - (\text{vent header mitre bend angle})$

Table EF 4.2-2

PLANT CONDITIONS AT INSTANT OF DBA PIPE BREAK FOR THRUST
LOAD CALCULATIONS - ZERO ΔP

Thermal Power (102% of licensed) (Mwt)	3358
Initial Suppression Pool Temperature ($^{\circ}F$)	70
Downcomer Submergence (ft)	3.33
Airspace Volume (ft ³)	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Operating (ΔP) DW-Ww	
Drywell	0.78
Wetwell	0.78



$F1V1$ = VERTICAL FORCE ON MAIN VENT END CAP
 $F1H1$ = HORIZONTAL FORCE ON MAIN VENT END CAP
 $F2V$ = VERTICAL FORCE ON VENT HEADER (PER MITRE BEND)
 $F2H$ = HORIZONTAL FORCE ON VENT HEADER (PER MITRE BEND)
 $F3V$ = VERTICAL FORCE ON DOWNCOMER MITRE BEND
 $F3H$ = HORIZONTAL FORCE ON DOWNCOMER MITRE BEND
 FORCES ARE SHOWN IN THEIR ASSUMED POSITIVE DIRECTION

Figure EF 4.2-1. Definition of Positive Thrust Loads

VENT SYSTEM THRUST LOADS FIGURES AND TABLES - ZERO ΔP

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Table EF 4.2-2	Plant Conditions at Instant of DBA Pipe Break for Thrust Load Calculations	Revision 2
Figure EF 4.2- 2	Single Main Vent Forces (0-5 sec)	↓
Figure EF 4.2- 3	Vent Header Forces per Mitre Bend (0-5 sec)	
Figure EF 4.2- 4	Single Downcomer Forces (0-5 sec)	
Figure EF 4.2- 5	Total Vertical Forces, Net Vertical Force (0-5 sec)	
Figure EF 4.2- 6	Single Main Vent Forces (0-30 sec)	
Figure EF 4.2- 7	Vent Header Forces per Mitre Bend (0-30 sec)	
Figure EF 4.2- 8	Single Downcomer Forces (0-30 sec)	
Figure EF 4.2- 9	Total Vertical Forces, Net Vertical Force (0-30 sec)	
Figure EF 4.2- 10	Pressure Time Histories (0-5 sec)	
Figure EF 4.2- 11	Pressure Time Histories (0-30 sec)	




Figure EF 4.2-2. Single Main Vent Forces (Zero ΔP)




Figure EP 4.2-3. Vent Header Forces Per Mitre Bend (Zero ΔP)




Figure EF 4.2-4. Single Downcomer Forces (Zero ΔP)




Figure EP 4.2-5. Total and Net Vertical Forces (Zero ΔP)




Figure EP 4.2-6. Single Main Vent Forces (Zero ΔP)




Figure EP 4.2-7. Vent Header Forces Per Mitre Bend (Zero ΔP)




Figure EP 4.2-8. Single Downcomer Forces (Zero ΔP)




Figure EF 4.2-9. Total and Net Vertical Forces (Zero ΔP)




Figure 4.2-10. Pressure Time Histories (Zero ΔP)




Figure EP 4.2-11. Pressure Time Histories (Zero ΔP)

Table EF 4.2-3

PLANT CONDITIONS AT INSTANT OF DBA PIPE BREAK FOR THRUST LOAD
CALCULATIONS - OPERATING ΔP

Thermal Power (100% of licensed) (MWt)	3358
Initial Suppression Pool Temperature ($^{\circ}F$)	70
Downcomer Submergence (ft)	3.33
Airspace Volume (ft ³)	
Drywell	163,730
Wetwell	130,900
Airspace Pressure (psig)	
Drywell	0.75
Wetwell	0.575




Figure EF 4.2-12. Single Main Vent Forces (Operating ΔP)




Figure EP 4.2-13. Vent Header Forces Per Mitre Bend (Operating ΔP)




Figure EF 4.2-14. Single Downcomer Forces (Operating ΔP)




Figure EP 4.2-15. Total and Net Vertical Forces (Operating ΔP)




Figure EP 4.2-16. Single Main Vent Forces (Operating ΔP)




Figure EP 4.2-17. Vent Header Forces Per Mitre Bend (Operating ΔP)




Figure EP 4.2-18. Single Downcomer Forces (Operating ΔP)




Figure EF 4.2-19. Total and Net Vertical Forces (Operating ΔP)




Figure EP 4.2-20. Pressure Time Histories (Operating ΔP)




Figure EP 4.2-21. Pressure Time Histories (Operating ΔP)

Pool Swell Torus Vertical Loads

Pool Swell Torus Vertical Loads

This section provides the net torus vertical load and shell pressure histories resulting from the drywell air purge to the wetwell during the postulated DBA. The list of applicable figures for this section is given on the following page.

Revision 2

ENRICO FERMI 2

POOL SWELL TORUS VERTICAL LOADS FIGURES

<u>Figure Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Figure EF 4.3.1-1	Net Torus Vertical Load (Operating ΔP)	Revision 2
Figure EF 4.3.1-2	Net Torus Vertical Load (Zero ΔP)	↓
Figure EF 4.3.2-1	Average Submerged Pressure (Operating ΔP)	
Figure EF 4.3.2.2	Average Submerged Pressure (Zero ΔP)	
Figure EF 4.3.2.3	Torus Air Pressure (Operating ΔP)	
Figure EF 4.3.2.4	Torus Air Pressure (Zero ΔP)	




Figure EP 4.3.1-1. Net Torus Vertical Load (Operating ΔP)




Figure EF 4.3.1-2. Net Torus Vertical Load (Zero ΔP)




Figure EP 4.3.2-1. Average Submerged Pressure (Operating ΔP)




Figure EF 4.3.2-2. Average Submerged Pressure (Zero ΔP)




Figure EF 4.3.2-3. Torus Air Pressure (Operating ΔP)




Figure EF 4.3.2-4. Torus Air Pressure (Zero ΔP)

Pool Swell Impact and Drag Loads

Pool Swell Impact and Drag Loads

This section provides the pool swell displacement and velocity distributions for evaluation of impact and drag loads on structures located above the pool. For the conditions specified and noted herein, the pool swell event does not produce impact or drag loading on the vent header. The list of applicable figures for this section is given on the following page.

ENRICO FERMI 2

PLANT UNIQUE POOL SWELL IMPACT AND DRAG LOAD FIGURES

<u>Figure No.</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Figure 4.3.3-1	Pool Swell Displacement Distribution (Zero ΔP)	Revision 2 ↓
Figure 4.3.3-2	Pool Swell Displacement Distribution (Operating ΔP)	
Figure 4.3.3-3	Pool Swell Velocity Distribution (Zero ΔP)	
Figure 4.3.3-4	Pool Swell Velocity Distribution (Operating ΔP)	
Figure 4.3.4-1	Longitudinal Vent Header Impact Velocity Distribution Based on EPRI Main Vent Orifice Test	
Figure 4.3.4-2	Longitudinal Time Delay Distribution Based on EPRI Main Vent Orifice Test	




Figure EP 4.3.3-1. Pool Swell Displacement Distribution (Zero ΔP)
 Radial Distance, X/R




Figure KF 4.3.3-2. Pool Swell Displacement Distribution (Operating AP)




Figure EP 4.3.3-3. Pool Swell Velocity Distribution (Zero ΔP)
 Radial Distance, X/R




Figure EF 4.3.3-4. Pool Swell Velocity Distribution (Operating ΔP)




Figure EP 4.3.4-1. Longitudinal Vent Header Impact Velocity Distribution Based on EPRI Main Vent Orifice Test




Figure EF 4.3.4-2. Longitudinal Time Delay Distribution Based on EPRI Main Vent Orifice Test

Vent Header Deflector Loads

Pool Swell Vent Header Deflector Loads

This section provides the vent header deflector loads from the pool swell resulting from the drywell air purge to the wetwell during the postulated DBA.

The loads presented are full scale running load as a function of time from LOCA break, for three values of Z/L (distance along the deflector). Z/L = 0 corresponds to the middle of the vent bay and Z/L = 1.0 corresponds to the middle of the non-vent bay.

These loads were derived from the method discussed in the Mark I Containment Program Vent Header Deflector Load Definition (WEDO-24612).

ENRICO FERMI

PLANT UNIQUE POOL SWELL VENT HEADER DEFLECTOR LOADS

<u>Figure/Table Number</u>	<u>Title</u>	<u>Applicable Revision No.</u>
Figure EF 4.3.9-1	Vent Header Deflector Load	Revision 1
Table EF 4.3.9-1	Vent Header Deflector Load	Revision 1




Figure EP 4.3.9-1. Vent Header Load (Zero ΔP)

Table EF 4.3.9-1

VENT HEADER DEFLECTOR LOAD
 ****DEFLECTOR FULL SCALE LOADS****

Fermi 2, Type 3 Deflector

Z/L=1.0		Z/L=0.5		Z/L=0.0	
Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)
380.89	.00	380.89	.00	380.89	.00
382.87	.00	382.87	.00	382.87	.00
384.86	.00	384.86	.00	384.86	.00
386.84	.00	386.84	.00	386.84	.00
388.83	.00	388.83	.00	388.83	.00
390.81	.00	390.81	.00	390.81	.00
392.79	.00	392.79	.00	392.79	.00
394.78	.00	394.78	.00	394.78	.00
396.76	.00	396.76	.00	396.76	.00
398.74	.00	398.74	.00	398.74	.00
400.73	.00	400.73	.00	400.73	.00
402.71	.00	402.71	.00	402.71	.00
404.70	.00	404.70	.00	404.70	.00
406.68	.00	406.68	.00	406.68	.00
408.66	1261.05	408.66	.00	408.66	.00
410.65	1122.33	410.65	.00	410.65	.00
412.63	951.00	412.63	.00	412.63	.00
414.62	751.16	414.62	1172.77	414.62	.00
416.60	615.05	416.60	1053.58	416.60	.00
418.58	674.44	418.58	909.58	418.58	.00
420.57	739.39	420.57	735.07	420.57	.00
422.55	811.22	422.55	571.19	422.55	.00
424.53	888.91	424.53	620.62	424.53	.00
426.52	896.69	426.52	671.97	426.52	.00
428.50	1012.00	428.50	728.09	428.50	1006.34
430.49	1135.91	430.49	789.77	430.49	905.65
432.47	1279.00	432.47	865.07	432.47	790.21
434.45	1436.56	434.45	894.76	434.45	654.78
436.44	1600.71	436.44	1008.12	436.44	495.53
438.42	1775.79	438.42	1129.52	438.42	509.99
440.40	1960.38	440.40	1262.11	440.40	550.98
442.35	2044.28	442.39	1398.44	442.39	592.20
444.37	2232.57	444.37	1537.72	444.37	636.98
446.36	2425.61	446.36	1681.50	446.36	683.98
448.34	2625.95	448.34	1831.57	448.34	678.66
450.32	2840.45	450.32	1956.66	450.32	753.68
452.31	3069.76	452.31	2127.55	452.31	835.17
454.29	3169.51	454.29	2172.83	454.29	922.05
456.28	3394.30	456.28	2338.04	456.28	1012.93
458.26	3619.44	458.26	2505.21	458.26	1108.01
460.24	3641.13	460.24	2672.29	460.24	1200.38
462.23	3487.18	462.23	2839.12	462.23	1294.70

Table EF 4.3.9-1

VENT HEADER DEFLECTOR LOAD (Continued)

****DEFLECTOR FULL SCALE LOADS****

Fermi 2, Type 3 Deflector

Z/L=1.0		Z/L=0.5		Z/L=0.0	
Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)
464.21	3300.61	464.21	3005.27	464.21	1389.82
466.19	3082.68	466.19	3169.55	466.19	1395.04
468.18	2840.85	468.18	3186.34	468.18	1483.21
470.16	2593.34	470.16	3047.60	470.16	1576.73
472.15	2340.02	472.15	2900.13	472.15	1675.66
474.13	2062.27	474.13	2732.86	474.13	1775.82
476.11	1757.78	476.11	2542.31	476.11	1875.02
478.10	1610.17	478.10	2331.82	478.10	1973.97
480.08	1611.02	480.08	2103.82	480.08	2071.83
482.06	1594.48	482.06	1850.44	482.06	2166.30
484.05	1585.19	484.05	1589.74	484.05	2261.39
486.03	1595.18	486.03	1333.23	486.03	2361.26
488.02	1603.78	488.02	1312.74	488.02	2307.45
490.00	1598.48	490.00	1309.72	490.00	2196.56
491.98	1589.90	491.98	1304.87	491.98	2076.73
493.97	1608.40	493.97	1319.34	493.97	1956.17
495.95	1611.56	495.95	1322.76	495.95	1824.83
497.94	1589.45	497.94	1306.43	497.94	1676.43
499.92	1561.66	499.92	1284.88	499.92	1517.49
501.90	1568.21	501.90	1256.03	501.90	1347.85
503.89	1563.17	503.89	1226.45	503.89	1166.11
505.87	1573.16	505.87	1239.41	505.87	985.94
507.85	1574.07	507.85	1245.76	507.85	798.88
509.84	1553.93	509.84	1237.02	509.84	706.30
511.82	1558.21	511.82	1244.75	511.82	717.56
513.81	1563.74	513.81	1253.09	513.81	728.59
515.79	1557.60	515.79	1252.90	515.79	735.84
517.77	1559.13	517.77	1257.86	517.77	744.63
519.76	1571.85	519.76	1270.63	519.76	756.31
521.74	1557.17	521.74	1263.55	521.74	759.41
523.72	1544.74	523.72	1257.77	523.72	762.52
525.71	1565.56	525.71	1275.88	525.71	775.69
527.69	1555.20	527.69	1271.24	527.69	778.71
529.68	1530.46	529.68	1255.81	529.68	776.45
531.66	1531.12	531.66	1258.76	531.66	782.13
533.64	1515.38	533.64	1249.47	533.64	781.93
535.63	1478.51	535.63	1224.31	535.63	773.89
537.61	1462.81	537.61	1214.54	537.61	772.65
539.60	1456.84	539.60	1211.83	539.60	774.50
541.58	1401.21	541.58	1171.89	541.58	758.08
543.56	1361.85	543.56	1143.75	543.56	746.83
545.55	1352.35	545.55	1137.76	545.55	746.10

Table EF 4.3.9-1

VENT HEADER DEFLECTOR LOAD (Continued)
 ****DEFLECTOR FULL SCALE LOADS****

Fermi 2, Type 3 Deflector

Z/L=1.0		Z/L=0.5		Z/L=0.0	
Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)	Time (msec)	Load (lb/ft)
547.53	1330.35	547.53	1122.25	547.53	740.47
549.51	1296.07	549.51	1097.32	549.51	729.84
551.50	1257.44	551.50	1068.86	551.50	717.10
553.48	1238.75	553.48	1055.31	553.48	711.62
555.47	1218.75	555.47	1040.65	555.47	705.38
557.45	1168.52	557.45	1002.84	557.45	687.00
559.43	1114.44	559.43	961.86	559.43	666.61
561.42	1066.82	561.42	925.57	561.42	648.29
563.40	1014.04	563.40	885.13	563.40	627.49
565.38	983.77	565.38	861.75	565.38	615.36
567.37	968.78	567.37	853.51	567.37	611.08
569.35	942.15	569.35	838.16	569.35	602.95
571.34	910.01	571.34	818.05	571.34	592.14
573.32	878.83	573.32	798.19	573.32	581.33
575.30	838.40	575.30	770.23	575.30	566.00
577.29	773.32	577.29	721.04	577.29	538.98
579.27	696.09	579.27	660.33	579.27	505.38
581.26	662.54	581.26	635.50	581.26	491.08
583.24	609.21	583.24	593.04	583.24	466.99
585.22	552.84	585.22	547.01	585.22	440.77
587.21	498.77	587.21	502.06	587.21	414.96
589.19	450.56	589.19	460.41	589.19	391.40
591.17	398.71	591.17	414.19	591.17	365.43
593.16	347.22	593.16	368.24	593.16	339.04
595.14	296.97	595.14	323.33	595.14	312.70
597.13	247.66	597.13	279.22	597.13	286.30
599.11	198.09	599.11	234.82	599.11	259.21
601.05	149.09	601.09	190.89	601.09	231.89
603.08	100.70	603.08	147.46	603.08	204.40
605.06	52.78	605.06	104.41	605.06	176.67
607.04	5.20	607.04	61.62	607.04	148.66
609.03	.00	609.03	19.24	609.03	120.46
611.01	.00	611.01	.00	611.01	92.09
613.00	.00	613.00	.00	613.00	63.55
614.98	.00	614.98	.00	614.98	34.84
616.96	.00	616.96	.00	616.96	6.00
618.95	.00	618.95	.00	618.95	.00
620.93	.00	620.93	.00	620.93	.00
622.92	.00	622.92	.00	622.92	.00
624.90	.00	624.90	.00	624.90	.00
626.88	.00	626.88	.00	626.88	.00
628.87	.00	628.87	.00	628.87	.00

Table EF 4.3.9-1

VENT HEADER DEFLECTOR LOAD (Continued)
 ****DEFLECTOR FULL SCALE LOADS****

Fermi 2, Ty 3 Deflector

Z/L=1.0		Z/L=0.5		Z/L=0.0	
<u>Time</u> <u>(msec)</u>	<u>Load</u> <u>(lb/ft)</u>	<u>Time</u> <u>(msec)</u>	<u>Load</u> <u>(lb/ft)</u>	<u>Time</u> <u>(msec)</u>	<u>Load</u> <u>(lb/ft)</u>
630.85	.00	630.85	.00	630.85	.00
632.83	.00	632.83	.00	632.83	.00
634.82	.00	634.82	.00	634.82	.00
636.80	.00	636.80	.00	636.80	.00
638.75	.00	638.79	.00	638.79	.00
640.77	.00	640.77	.00	640.77	.00
642.75	.00	642.75	.00	642.75	.00
644.74	.00	644.74	.00	644.74	.00
646.72	.00	646.72	.00	646.72	.00
648.70	.00	648.70	.00	648.70	.00
650.69	.00	650.69	.00	650.69	.00
652.67	.00	652.67	.00	652.67	.00
654.66	.00	654.66	.00	654.66	.00
656.64	.00	656.64	.00	656.64	.00
658.62	.00	658.62	.00	658.62	.00

DISTRIBUTION

INTERNAL

Name	M/C
C.W. Cullen (transmittal letter only)	602
F.P. Felini	880
D.M. Gluntz	584
T.S. Gupta (3)	126
S.A. Hucik	194
R.M. Hunt (transmittal letter only)	855
A.E. Rogers	879
P.P. Stancavage	879
B. Stevens (5 + microfiche)	126
M.E. Tanner	855
H.E. Townsend	564
P. Valandani	146
J.P. Zilinskas	843
Customer Service File	881
NEBG Library (5)	328
VNC Library (2)	V01
TIE (5)	FCH
TSS (2)	742

EXTERNAL DISTRIBUTION

Utility

Mr. D.F. Lehnert
 Detroit Edison Co. 318 ECT.
 3331 West Big Beaver Road
 Troy, MI 48084

I&SE

Mr. C.M. Johnson M/C 391
 Project Manager
 Fermi 2 Project

CC

Mr. A. Higgenbotham
 (NUTECH)



TECHNICAL INFORMATION EXCHANGE

TITLE PAGE

AUTHOR Personnel of Nuclear Services Engineering	SUBJECT	TIE NUMBER R1NED049
		DATE June 1981
TITLE Mark I Containment Program Plant Unique Load Definition Enrico Fermi Atomic Pwr Plant: Unit 2		GE CLASS I
		GOVERNMENT CLASS
REPRODUCIBLE COPY FILED AT TECHNICAL SUPPORT SERVICES, RAUO, SAN JOSE, CALIFORNIA 95125 (Mail Code 211)		NUMBER OF PAGES 78
SUMMARY This document provides unique definition of specific containment loading conditions that would result from a postulated loss-of-coolant accident in the Enrico Fermi Atomic Power Plant: Unit 2. Transient information is provided for containment pressures and temperatures, vent system thrust, torus vertical loads, vent system pool swell impact loads and vent header deflector loads. The document has been prepared under the Mark I Containment Program to aid Detroit Edison Company in the performance of a containment structural evaluation.		

By cutting out this rectangle and folding in half, the above information can be fitted into a standard card file.

DOCUMENT NUMBER WEDO-24568

INFORMATION PREPARED FOR Nuclear Fuel & Services Division

SECTION Nuclear Services Engineering

BUILDING AND ROOM NUMBER 1887/1204 MAIL CODE 889