



LER SUPPLEMENTAL INFORMATION

BFRO-50- 296 / 8210 Technical Specification Involved Table 3.2.F

Reported Under Technical Specification 6.7.2.b.(2) \* Date Due NRC 5/6/82

Event Narrative:

Units 1 and 2 were in normal operation and unit 3 was in a refueling outage. Only unit 3 was affected by this event. While performing Surveillance Instruction (SI) 4.2.F-10 (Drywell Pressure), pressure switch 3-PS-64-67 operated at 35.5 psig. Technical Specification Table 3.2.F requires the switch to operate at 35 psig. The function of 3-PS-64-67 is to initiate the alarm "Initiate Containment Spray" under accident conditions. The switch was immediately recalibrated per SI 4.2.F-10 and returned to service. There was no danger to the health or safety of the public, plant employees, or equipment at anytime because redundant drywell pressure switches at lower setpoints were available and operable. This event is considered random, and no further recurrence control is planned.

\* Previous Similar Events:

296/81054

Retention: Period - Lifetime; Responsibility - Document Control Supervisor

\*Revision: JRP