

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 A L J M F 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 33

REPORT
SOURCE

L 5 0 5 0 0 0 3 6 4 7 0 9 1 5 8 1 3 1 0 1 2 8 1 3
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

At 1710 on 9/15/81, while performing FNP-2-STP-20.0A (Penetration Room Exhaust and Air Filtration System Operability Test), the "A" Train Penetration Room Filtration System was declared inoperable when the pressure differential transmitter (PDT 3583) failed to fully open the recirculating fan damper. Tech. Spec. 3.7.8 requires the filtration system to be operable. Tech. Spec. 3.7.8 action statement requirements were met. Health/safety of the public was not affected.

SYSTEM
CODECAUSE
CODECAUSE
SUBCODECOMPONENT
CODECOMP.
SUBCODEVALVE
SUBCODE

A A 11 E 12 E 13 I N S T R U 14 T 15 Z 16
9 10 11 12 13 14 15 16 17 18 19 20

LER/RO
REPORT
NUMBEREVENT YEAR
8 1
21 22SEQUENTIAL
REPORT NO.
0 3 9
24 25 26OCCURRENCE
CODE
0 3
28 29REPORT
TYPE
L
30 31REVISION
NO.
0
32ACTION
TAKENFUTURE
ACTIONEFFECT
ON PLANTSHUTDOWN
METHOD

HOURS

ATTACHMENT
SUBMITTEDNPRD-4
FORM SUB.PRIME COMP.
SUPPLIERCOMPONENT
MANUFACTURER

E 18 Z 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 N 25 W 1 2 0
33 34 35 36 37 38 39 40 41 42 43 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

This event was due to transmitter drift. The transmitter was recalibrated and following the successful completion of FNP-2-STP-20.0A, the "A" Train Penetration Room Filtration System was returned to service at 0345 on 9/17/81. I&C will perform a calibration check after a 2 month period to verify that the transmitter calibration is still within specifications.

FACILITY
STATUS

% POWER

OTHER STATUS

METHOD OF
DISCOVERY

DISCOVERY DESCRIPTION

ACTIVITY
RELEASED OF RELEASE

AMOUNT OF ACTIVITY

LOCATION OF RELEASE

PERSONNEL EXPOSURES
NUMBER

TYPE

DESCRIPTION

PERSONNEL INJURIES
NUMBER

DESCRIPTION

LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION

8205240439 811012
PDR ADOCK 05000364
S PDR

PUBLICITY
ISSUED

DESCRIPTION

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III

PHONE: (205)8995156