

APPENDIX A

NOTICE OF VIOLATION

Duquesne Light Company
Beaver Valley Power Station, Unit 1

Docket/License: 50-334/DPR-66

During the inspection on March 20 - April 26, 1982, and in accordance with the NRC Enforcement Policy, 10CFR2 Appendix C (47FR9987, March 9, 1982), the following violation was identified:

Amendment 18 to Facility License DPR-66, issued June 6, 1979, requires implementation of an Operations Quality Assurance Plan for fire protection activities, including testing and administrative controls. The BVPS Operations Quality Assurance Plan, Appendix C, Fire Protection, Revision 1, requires that inspections and testing of the Fire Protection Systems be accomplished in accordance with documented instructions and procedures. The BVPS Operating Manual (OM) Section 1.55A, Periodic Checks and Operating Surveillance, Operating Surveillance Test (OST) 1.33.15, Fire Extinguisher Inspection, Issue 1, Revision 35, establishes monthly inspections of portable fire equipment in accordance with National Fire Protection Association Pamphlet 10. OM Section 1.55A.1, Summary Description, Issue 1, Revision 1, defines monthly test frequency as at least once per 31 days with a maximum allowable extension not to exceed 25% of the surveillance interval.

Contrary to the above, on April 15, 1982, OST 1.33.15 had not been performed since February 22, 1982, exceeding the maximum permissible interval.

This is a Severity Level V Violation (Supplement I).

Pursuant to the provisions of 10CFR2.201, Duquesne Light Company is hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) corrective steps which have been taken and the results achieved, (2) corrective steps which will be taken to avoid further violations, and (3) the date when full compliance will be achieved. Under the authority of Section 182 of the Atomic Energy Act of 1954, as amended, this response shall be submitted under oath or affirmation. Where good cause is shown, consideration will be given to extending the response time.

Date MAY 11 1982

Original Signed By:
Richard W. Starostecki, Director
Division of Project and Resident
Programs

OFFICIAL RECORD COPY

8205270335