

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION
P.O. BOX 128
SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY
STATION MANAGER

May 17, 1982

RECEIVED
MAY 21 PM 1:00
TELEPHONE
(714) 492-7700

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: R. H. Engelken, Regional Administrator

Dear Sir:


Subject: Docket No. 50-361
Licensee Event Report No. 82-16
San Onofre Nuclear Generating Station, Unit 2

In accordance with Technical Specifications Section 6.9.1.12, this letter confirms our prompt notification by telephone this date of a reportable occurrence involving San Onofre Nuclear Generating Station, Unit 2.

As reported in that telephone conversation, Limiting Condition for Operation 3.8.3.1 requires that the four 120 volt A.C. Vital Busses be energized from their associated inverters connected to specific D.C. Busses. In order to investigate the source of radio frequency interference apparently related to Vital Busses 2Y03 and 2Y04, these busses were energized from their alternate power sources for a period of approximately 15 minutes on May 16, 1982, at 6:00 p.m.

Our investigation into the occurrence is continuing. A formal Licensee Event Report and supporting information will be provided to you no later than June 1, 1982.

Sincerely,



IE22
5
1/0

Enclosure

cc: A.E. Chaffee (USNRC Resident Inspector, San Onofre, Unit 2)

8205280214 s