

GPU Nuclear
 P.O. Box 388
 Forked River, New Jersey 08731
 609-693-6000
 Writer's Direct Dial Number:

May 21, 1982

Director
 Nuclear Reactor Regulation
 U.S. Nuclear Regulatory Commission
 Washington, D.C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
 Docket No. 50-219
 Technical Specification Change Request No. 104


In accordance with 10 CFR 50.59 and 10 CFR 50.90, GPU Nuclear Corporation, operator of the Oyster Creek Nuclear Generating Station, Provisional Operating License No. DPR-16, requests a change to the license.

This Technical Specification change revises license DPR-16 to reflect that the replacement of all core spray spargers will occur during the Cycle 11 or later refueling outage vice the Cycle 10 refueling outage.

This Technical Specification Change Request has been reviewed and approved by the Director Oyster Creek Operations, the Plant Operations Review Committee, and an Independent Safety Review Group in accordance with Section 6.5 of the Oyster Creek Technical Specifications.

We have determined that the submittal is Class II per 10 CFR 107.22 and have enclosed a check for \$1,200.00 pursuant to that section. In the event that any comments or questions arise, please contact Mr. James Knubel of my staff at (201) 299-2264.

Very truly yours,



 Peter B. Fiedler
 Vice President and Director
 Oyster Creek

A001
5/11
w/check:
\$1200.00

8205280289P

General Public Utilities
Nuclear Corporation
Oyster Creek Nuclear Generating Station
Docket No. 50-219
Provisional Operating License No. DPR-16

Applicant hereby requests the Commission to change the above captioned license as follows:

1. Section to be Changed:

License No. DPR-16

2. Extent of Change:

This license modification indicates that all core spray spargers will be replaced during or after the Cycle 11 refueling outage instead of the Cycle 10 refueling outage.

3. Changes Requested:

The licensee requests that paragraph 2.C (7) of License No. DPR-16 Amendment No. 59 be changed to read as follows:

"Full inspections of the accessible surfaces and welds of both core spray spargers and repair assemblies at each refueling outage will be performed. Comparisons of any indications to previous inspection indications will be made. If additional or progressing indications are found, an evaluation of the spargers will be performed and documented by the licensee prior to resuming power operation. If the analysis of inspection results indicates that the core spray sparger performance is unacceptable, the spargers will be repaired or replaced prior to resuming power operation."


4. Discussion:

This Technical Specification Change Request confirms a presentation made by the upper management of GPU Nuclear Corporation to your staff on December 11, 1981. The meeting concerned the problems associated with our upcoming refueling outage including the requirement to replace all core spray spargers. It was established that deferring this requirement might be acceptable provided that an inspection of the existing spargers be conducted during the next refueling outage. The inspection should reveal that spray flow distribution and quantity of spray remains within specification and excessive cracking, beyond that which already exists, has not occurred.

General Public Utilities
Nuclear Corporation

Provisional Operating License
No. DPR-16
Technical Specification Change
Request No. 104
Docket No. 50-219

Applicant submits by this Technical Specification Change Request No. 104 to the Oyster Creek Nuclear Generating Station Provisional Operating License a revision to Amendment No. 59 to that license. This change modifies the time requirements for replacement of all core spray spargers.

By 
Peter B. Fiedler
Vice President and Director
Oyster Creek

Sworn to and subscribed to before me this 21 day
of May 1982.


Notary Public

MICHAEL LAGGART
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires December 31, 1985

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF)
)
GPU NUCLEAR CORP.)


DOCKET NUMBER 50-219

CERTIFICATION OF SERVICE

This is to certify that a copy of Technical Specification Change Request No. 104 for the Oyster Creek Nuclear Generating Station Technical Specification, filed with the U.S. Nuclear Regulatory Commission on May 21, 1982, has this *21th day of May* been served on the Mayor of Lacey Township, Ocean County, New Jersey, by deposit in the United States mail addressed as follows:

The Honorable Theodore Hutler
Mayor of Lacey Township
818 West Lacey Road
Forked River, N.J. 08731

By


Peter B. Fiedler
Vice President and Director
Oyster Creek

Dated: May 21, 1982



GPU Nuclear

P O Box 388
Forked River, New Jersey 08731
609-693-6000
Writer's Direct Dial Number:

May 21, 1982

The Honorable Theodore Hutler
Mayor of Lacey Township
818 West Lacey Road
Forked River, N.J. 08731

Dear Mayor Hutler:

Enclosed is one copy of Technical Specification Change Request No. 104 for the Oyster Creek Nuclear Generating Station Operating License.

This document was filed with the United States Nuclear Regulatory Commission on May 21, 1982.

Very truly yours,

A handwritten signature in cursive script, appearing to read 'P. B. Fiedler', written over a horizontal line.

Peter B. Fiedler
Vice President and Director
Oyster Creek

PBF:JK:lse
Enclosure