LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 | W I K N P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | [ ] (5)
LICENSEE CODE (9–14) LICENSE NUMBER (15–25) LICENSE TYPE (26–30) CAT (57–58)

CON'T
1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 0 5 (7) | 0 4 2 2 8 2 (8) | 0 5 2 1 8 2 (9)
SOURCE (60) DOCKET NUMBER (61–68) EVENT DATE (69–74) REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a scheduled refueling outage, surveillance testing indicated that one
0 3 RCS flow transmitter was out of calibration in excess of T.S. 2.3.a.4.A limits.
0 4 This is an LCO per Table T.S. 3.5-2 and is reportable as a reactor protection system
0 5 instrument setting less conservative than established by the Technical Specifications.
0 6 Safety limits would not have been exceeded: redundant instrumentation would have
0 7 performed as required. There was no effect on public safety or plant operation.
0 8 (7–80)

SYSTEM CODE: I A (11) | CAUSE CODE: X (12) | CAUSE SUBCODE: Z (13) | COMPONENT CODE: I N S T R U (14) | COMP SUBCODE: T (15) | VALVE SUBCODE: Z (16)

LER/RO (17) REPORT NUMBER: EVENT YEAR 8 2 (21–22) | — (23) | SEQUENTIAL REPORT NO. 0 1 0 (24–26) | / (27) | OCCURRENCE CODE 0 3 (28–29) | REPORT TYPE L (30) | — (31) | REVISION NO. 0 (32)

ACTION TAKEN: E (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 (37–40) | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: N (25) | COMPONENT MANUFACTURER: F 1 8 0 (44–47)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This transmitter was out of calibration due to normal instrument drift. The
1 1 transmitter was recalibrated and tested satisfactory. No further action is
1 2 required at this time.
1 3
1 4 (7–80)

FACILITY STATUS: H (28) | % POWER: 0 0 0 (29) | OTHER STATUS (30): NA (44) | METHOD OF DISCOVERY: B (31) | DISCOVERY DESCRIPTION (32): Surveillance Testing (46–80)

1 5

ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA (44) | LOCATION OF RELEASE (36): NA (46–80)

1 6

PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39): NA (13–80)

1 7

PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41): NA (12–80)

1 8

LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION: NA (10–80)

1 9

PUBLICITY: ISSUED N (44) | DESCRIPTION (45): NA (10–80)

2 0

8205280316

NRC USE ONLY (68–80)

NAME OF PREPARER: C. S. Smoker PHONE: (414) 388-2560 Ext. 340