

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401
1750 Chestnut Street Tower 11
ATLANTA, GEORGIA

May 4, 1982

82 MAY 7 11:31

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE
REPORT BFRO-50-296/81065 REVISION 1

The enclosed report is a supplement to my letter to you dated
November 27, 1981, concerning reactor core isolation cooling steam
supply isolation valve 3-FCV-71-3 which could not be closed electrically.
This report is submitted in accordance with Browns Ferry unit 3
Technical Specification 6.7.2.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. A. Green
H. J. Green
Director of Nuclear Power

Enclosure

cc (Enclosure):

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Records Center
Institute of Nuclear Power Operations
1820 Water Place
Atlanta, Georgia 30339

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

8206010 182.5

OFFICIAL COPY

IE 22

5/1/1