

## LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C M G S I 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 56

CONT  
01 REPORT SOURCE L 8 0 5 0 0 0 3 6 9 7 0 3 2 6 8 2 8 0 4 2 3 8 2 9  
7 8 9 DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in mode 1, EMFs 35, 36, and 37 were declared inoperable due to a loss of  
03 flow alarm received in the control room. Loss of operability of EMF-36 (unit  
04 vent Noble gas monitor) violates T.S.3.3.3.9 which is reportable per T.S.6.9.1.  
05 13(b), similar to previous R.O.s #369/81-108 and 155, and required implementa-  
06 tion of action statement #37. Because of the operability of redundant EMF  
07 monitors, along with periodic sampling and analysis of the unit vent discharge,  
08 health and safety of the public were unaffected.

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
B B 11 E 12 B 13 P U M P X X 14 H 15 Z 16  
17 LER/NO REPORT NUMBER 8 2 21 22 SEQUENTIAL REPORT NO. 0 2 6 27 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
A 18 X 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 L 25 G 0 6 3 26  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The air pump which supplies sample flow to the 3 monitors seized due to worn  
11 pump vanes. The graphite vane's failure resulted from normal wear. Due to a  
12 work backlog the preventative maintenance program (PMP) had not been completed  
13 for the EMFs. New vanes were installed and the pump returned to service. A  
14 program to insure that PMPs which are essential for equipment availability are  
15 completed on schedule is being developed.

15 FACILITY STATUS 0 5 0 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY A 31 LOSS OF flow alarm 32  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
1 8 Z 33 Z 34 N/A 44 N/A 45 46 47 48 49 50

PERSONNEL EXPOSURES  
NUMBER TYPE DESCRIPTION 39  
1 7 0 0 0 37 2 38 N/A 40  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PERSONNEL INJURIES  
NUMBER DESCRIPTION 41  
1 8 0 0 0 40 N/A 41  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

LOSS OF OR DAMAGE TO FACILITY  
TYPE DESCRIPTION 43  
1 9 Z 42 N/A 43  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

PUBLICITY  
ISSUED DESCRIPTION 45  
2 0 N 44 N/A 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NRC USE ONLY

NAME OF PREPARER Phillip B. Nardoci

PHONE: 704-373-7432