

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NCBEP2 200-00000-003411114 5
7 8 9 14 15 25 26 30 57 CAT 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

01 L6050-0324703218280419829
7 8 60 61 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During plant operation while performing the No. 3 Diesel Generator Monthly Load Test,
03 PT-12.2C, the diesel tripped and locked out due to jacket water temperature
04 exceeding the trip setpoint of 200°F. The diesel was still available to perform
05 its design function. This event did not affect the health and safety of the
06 public. A similar event involving No. 2 diesel generator occurred on 7-14-82 and
07 was reported in LER 2-81-66.

08 Technical Specifications 3.8.1.1, 6.9.1.9b 80

09 EE11 A12 X13 VALVEX14 B15 D16
7 8 9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
17 82 — 064 / 03 L — 0
21 22 23 24 26 27 28 29 30 31 32
 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
X18 X19 Z20 Z21 0000 N23 Y24 N25 G08026
33 34 35 36 37 40 41 42 43 44 47
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 The temperature lockout occurred because the diesel jacket water heat exchanger inlet
11 valve, DJW-V206, was closed. The valve was reopened, the diesel was started, and the
12 PT was satisfactorily completed. Following the completion of an ongoing investigation
13 to determine the reason for the closed valve, a supplement outlining the results of
14 the investigation and corrective action will be submitted.

15 E28 05029 NA B31 Periodic Test 32
7 8 9 10 12 13 44 45 46 80
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
16 Z33 Z34 NA NA NA 36
7 8 9 10 11 44 45 80
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
17 00037 Z38 NA 39
7 8 9 11 12 13 80
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
18 00040 NA 41
7 8 9 11 12 80
 PERSONNEL INJURIES NUMBER DESCRIPTION
19 Z42 NA 43
7 8 9 10 80
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
20 N44 NA 45
7 8 9 10 80
 PUBLICITY ISSUED DESCRIPTION
 8206010673
 NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521
68 69 80
 NRC USE ONLY