

MAY 24 1982

Docket Nos. 50-352; 50-353

Philadelphia Electric Company
ATTN: Mr. John S. Kemper
Vice President
Engineering and Research
2301 Market Street
Philadelphia, Pennsylvania 19101

Gentlemen:

Subject: Combined Inspection 50-352/82-05; 50-353/82-04

This refers to your May 6, 1982 reply to our April 6, 1982 letter.

Thank you for informing us of your corrective and preventive actions. Those actions will be examined during future inspections.

In regard to Violation A.2 for flange edge softeners not being installed, we believe that you agree that deviations from design requirements may be accomplished only through the prescribed change method and that installations may not be modified just because craftsmen and inspectors decide that specific design features are not required. Should our estimate of your position be incorrect, please notify us in writing within seven days.

Your cooperation is appreciated.

Sincerely,
Original Signed By:

R. P. Keimig for
Richard W. Starostecki, Director
Division of Project and Resident
Programs

cc:

V. S. Boyer, Senior Vice President, Nuclear Power
Troy B. Conner, Jr., Esquire (w/cy of Licensee's Reply)
Eugene J. Bradley, Esquire (w/cy of Licensee's Reply)
Public Document Room (PDR) (w/cy of Licensee's Reply)
Local Public Document Room (LPDR) (w/cy of Licensee's Reply)
Nuclear Safety Information Center (NSIC) (w/cy of Licensee's Reply)
NRC Resident Inspector (w/cy of Licensee's Reply)
Commonwealth of Pennsylvania (w/cy of Licensee's Reply)

bcc:

Region I Docket Room (with concurrences) (w/cy of Licensee's Reply)

8206030153 820524
PDR ADOCK 05000352
Q PDR

OFFICE	RI:DPRP	RI:DPRP	RI:DPRP	RI:DPRP			
SURNAME	Durr/meo	McCabe	Keimig	Starostecki			
DATE	5/20/82	5/21	5-21-82	5-21-82			

OFFICIAL RECORD COPY

USGPO: 1981-335-900

LEO