

MAY 27 1982

DISTRIBUTION:

Docket No. 50-328

Mr. H. G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street, Tower II  
Chattanooga, Tennessee 37401

Docket No. 50-328  
LB #4 r/f  
NRC PDR  
Local PDR  
TERA  
NSIC  
RTedesco  
EAdensam  
CStahle  
MDuncan  
OELD  
I&E  
ACRS (16)



Dear Mr. Parris:

Subject: Hydrostatic Test Requirements for a By-Pass  
Line on the Main Steam Line

In response to your letter of May 27, 1982, your request to waive the hydrostatic test requirements of Article IWC-5000 of ASME Section XI, following the repair of the by-pass line on the main steam line, is granted. Our Safety Evaluation Report is enclosed.

The 2-inch line and the new socket welds are to be tested at operating temperature and pressure prior to Sequoyah Unit 2 returning to service. The replacement weld areas shall be examined in accordance with Region II requirements.

Your request has been discussed with the NRC Sequoyah resident inspectors and they have no objections to deleting the hydrostatic test requirements for this particular repair.

Sincerely,

Robert L. Tedesco, Assistant Director  
for Licensing  
Division of Licensing

Enclosure:  
As stated

cc: See next page

8206030309 820527  
PDR ADOCK 05000328  
Q PDR

\*NOTE: SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	DL:LB.#4	LA:DL:LB.#4	MEB.#4	MEB.#4	DL:LB.#4	LA:DL:LB.#4
SURNAME	CStahle/hmc	MDuncan	*JBrammer	*RBosnak	EAdensam	RTedesco
DATE	5/24/82	5/27/82	5/27/82	5/27/82	5/27/82	5/27/82

Docket No. 50-328

Mr. W. G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street, Tower II  
Chattanooga, Tennessee 37401

Dear Mr. Parris:

Subject: Hydrostatic Test Requirements for a By-Pass  
Line on the Main Steam Line

In response to your letter of May 27, 1982, your request to waive the pressure test requirements of Article IWA-4400 of ASME Section XI, following the repair of the by-pass line on the main steam line, is granted.

The 2-inch line and the new socket welds are to be tested at operating temperature and pressure prior to Sequoyah Unit 2 returning to service.

Your request has been discussed with the NRC Sequoyah resident inspectors and they have no objections to deleting the hydrostatic test requirements for this particular repair.

Sincerely,

Robert L. Tedesco, Assistant Director  
for Licensing  
Division of Licensing

\*NOTE SEE PREVIOUS WHITE FOR CONCURRENCE

OFFICE	DL:LB #4	LA:DL:LB#4	MEB <i>7/25</i>	MEB <i>8</i>	DL:LB #4	AD:L:DL	
SURNAME	*CStahle	MDuncan	*JBrammer	RBosnak	EAdensam	RTedesco	
DATE	5/24/82	5/1/82	5/27/82	5/27/82	5/1/82	5/1/82	

Docket No: 50-328

Mr. H. G. Parris  
Manager of Power  
Tennessee Valley Authority  
500A Chestnut Street, Tower II  
Chattanooga, Tennessee 37401

Dear Mr. Parris:

Subject: Hydrostatic Test Requirements for a By-Pass  
Line on the Main Steam Line

In response to your letter of May 27, 1982, your request to waive the ASME Section XI requirements for hydrostatic testing of the welds and line in question is granted.

The 2-inch line and the new socket welds are to be tested at operating temperature and pressure prior to Sequoyah Unit 2 returning to service.

Your request has been discussed with the NRC Sequoyah resident inspectors and they have no objections to deleting the hydrostatic test requirements for this particular repair.

Sincerely,

Robert L. Tedesco, Assistant Director  
for Licensing  
Division of Licensing

DISTRIBUTION:

Docket No. 50-328

LB #4 r/f

NRC PDR

Local PDR

TERA

NSIC

MDuncan

CStahle

EAdensam

RTedesco

Attorney, OELD

I&E

ACRS (16)

JBrammer

RBosnak

OFFICE	DL:LB #4	LA:DL:LB #4	MEB <i>2/12</i>	MEB	DL:LB #4	AD:L:DL	
SURNAME	CStahle/hmc	MDuncan	JBrammer	RBosnak	EAdensam	RTedesco	
DATE	5/1/82	5/1/82	5/27/82	5/1/82	5/1/82	5/1/82	