PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-82-57

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by IE staff on this date.

Licensee Emergency Classification: FACILITY: Duke Power Company Notification of Unusual Event Oconee Unit 1 Alert Docket No. 50-259 Site Area Emergency Seneca, South Carolina General Emergency Not Applicable

SUBJECT: MAINTENANCE OUTAGE IN EXCESS OF TWO DAYS

On May 21, at 10:10 p.m. (EDT), the reactor tripped on high reactor coolant system (RCS) pressure. Operators were conducting a periodic test of control rod drive (CRD) movement. Operators manually reduced power to 55 percent after one rod dropped. A main feedwater flow mismatch caused high RCS pressure. The RCS pressure did not reach the power operated relief valve (PORV) set point during the transient.

The licensee plans to keep the reactor out of service for two weeks to repair a leaking CRD housing, a leaking pressurizer code safety valve, and to inspect steam generator shield wall tendons.

Media interest is expected. The licensee plans to issue a news release. The NRC will respond to media inquiries.

The State of South Carolina has been informed.

The NRC received notification of this occurrence by telephone to the headquarters duty officer at 10:41 p.m. (EDT) on May 21.

This information is current as of 10:30 a.m. (EDT) on May 24.

Contact: A. J. Ignatonis, RII 242-5588; J. C. Bryant, RII 242-5537

DISTRIBUTION:

Phillips Willste MAIL: H. Street MNBB E/W NMSS ADM: DMB Chairman Palladino EDO NRR/2:36 RES DOT: Trans Only Comm. Gilinsky OIA PA Comm. Ahearne MPA AEOD Applicable State ELD Comm. Roberts INPO SECY Air Rights NSAC ACRS CA PDR Regions: Licensee: 12'49 (Reactor Licensees) Applicable Resident Site 12:40

8206040106 820524 PDR I&E PNO-II-82-057 PDR

(IE-34):/0