



GPU Nuclear
100 Interpace Parkway
Parsippany, New Jersey 07054
201 263-6500
TELEX 136-482
Writer's Direct Dial Number:

May 28, 1982

Director
Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
Technical Specification Change Request No. 106

In accordance with 10 CFR 50.59 and 10 CFR 50.90, GPU Nuclear Corporation operator of the Oyster Creek Nuclear Generating Station, Provisional Operating License No. DPR-16 request a change to Appendix A of the Oyster Creek Technical Specifications.


Technical Specification Change Request No. 106 requests a one time only annotation to the definition of Refueling Outage (Section 1.12). Prior to the cycle 10 refueling outage only, the definition shall be annotated to extend the time between successive tests or surveillances from not exceeding 20 months to not exceeding 30 months.

It is our intention that this change request does not affect the interpretation of section 1.24 "Surveillance Requirements" which grants "A maximum allowable extension not to exceed 25% of the surveillance interval."

The Technical Specification Change Request has been reviewed and approved by the Director, Station Operations, the Plant Operations Review Committee, and an Independent Safety Review Group in accordance with Section 6.5 of the Oyster Creek Technical Specifications.

We have determined that this submittal is Class III per 10 CFR 107.22 and will enclose a check for \$4000 pursuant to that section by separate letter. If additional information is required, please contact Jim Knubel, Manager, BWR Licensing, at (201) 299-2264.

Very truly yours,


P. B. Fiedler
Vice President and
Director - Oyster Creek

lr 8206040413 820528
PDR ADOCK 05000219
P PDR

Enclosures