

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: [] [] [] [] [] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

[0] [1] N C B E P 1 [2] [0] [0] - [0] [0] [0] [0] [0] - [0] [0] [3] [4] [1] [1] [1] [1] [4] [] [] [5]

8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CONT

[0] [1] REPORT SOURCE [L] [6] [0] [5] [0] - [0] [3] [2] [5] [7] [0] [5] [0] [5] [8] [2] [8] [0] [5] [2] [6] [8] [2] [9]

61 68 DOCKET NUMBER 69 74 EVENT DATE 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While making preparations for a reactor startup, performance of Rod Sequence Control

0 3 System operability test, PT-1.6.1, revealed that fully inserted control rod 30-19 had

0 4 intermittent "full-in" RTGB position indication. This event did not affect the health

0 5 and safety of the public.

0 6

0 7 Technical Specifications 3.1.3.7, 6.9.1.9b

0 8

09		SYSTEM CODE I B (11)		CAUSE CODE E (12)	CAUSE SUBCODE A (13)						COMPONENT CODE Z Z Z Z Z Z (14)						COMP. SUBCODE Z (15)	VALVE SUBCODE Z (16)
17		EVENT YEAR 8 2		SEQUENTIAL REPORT NO. 0 5 1		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0								
ACTION TAKEN X (18)		FUTURE ACTION X (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22)		ATTACHMENT SUBMITTED N (23)		NPRD-4 FORM SUB. Y (24)		PRIME COMP. SUPPLIER N (25)		COMPONENT MANUFACTURER G 0 8 0 (26)		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The intermittent "full-in" indication is believed to be the result of a defective
1 1 rod position reed switch. This problem will be investigated and resolved during
1 2 the upcoming 1982 scheduled refueling outage. As this type failure does not constitute
1 3 a safety hazard and does occur occasionally, it is felt no additional action regarding
1 4 this event is required.

FACILITY STATUS		POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
1	5	G	28	0	0	0	29	NA	B	31	Periodic Test	32
7	8	9	10	11	12	13	14	45	46	47	48	
ACTIVITY		CONTENT			AMOUNT OF ACTIVITY		LOCATION OF RELEASE					
1	6	Z	33	Z	34	NA	44	NA	45	36		
7	8	9	10	11	12	13	14	45	46	47	48	
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION						
1	7	0	0	0	37	Z	38	NA	45	46	47	
7	8	9	10	11	12	13	14	45	46	47	48	
PERSONNEL INJURIES		NUMBER		DESCRIPTION								
1	8	0	0	0	40	NA	44	NA	45	46	47	
7	8	9	10	11	12	13	14	45	46	47	48	
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION								
1	9	Z	42	NA	44	NA	45	NA	46	47	48	
7	8	9	10	11	12	13	14	45	46	47	48	
PUBLICITY		ISSUED		DESCRIPTION								
2	0	N	44	8206070078	820526	PDR	ADOCK 05000325	S	PDR	NRC USE ONLY		
7	8	9	10	11	12	13	14	45	46	47	48	

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521