

Do Not Disclose

January 28, 1982

(File this copy)

MEMORANDUM FOR: Region III Files - LaSalle

FROM: Robert F. Warnick, Director, Enforcement and Investigation Staff

SUBJECT: TELEPHONE CALL FROM DOUG LONGENIE OF CHANEL 5 TV ALLEGATIONS AT LA SALLE

Doug Longenie called on January 26, 1982 at about 2 p.m. regarding information he had been given while pursuing other news stories. Doug indicated the source of his information was formerly a foreman for Foley Electric and now a Commonwealth Edison maintenance worker. Longenie indicated he would contact on January 27, 1982, and pave the way for us to contact to get specific details of the following allegations:

1. claimed that when they were putting in conduit, the grounding wasn't adequate. They did not do a good job of grinding off the zinc.
2. knows where two radiation monitors were supposed to be installed in the off gas building but were not actually installed.
3. All of the required heating pads in the off gas building were not installed.
4. The ceiling (in the off gas building, I think) was supposed to be 12 inches thick. When they were drilling 8 inch anchor bolts, they penetrated the ceiling and could see sky.
5. The fire alarm system in reactor building No. 1 does not meet specifications. A CAR was issued but it has been written off without the work being done. This problem was also mentioned by a second individual but the second person will not talk to us about it.

8206070242 820511
PDR FOIA
KODNER82-168 PDR

OFFICE	RIII	RIII					
SURNAME	Foley	Warnick					
DATE	1/28/82						