



**Commonwealth Edison**

One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690

June 1, 1982

Mr. A. Schwencer, Chief  
Licensing Branch #2  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Subject: LaSalle County Station Unit 1  
Proposed Amendment to NPF-11  
Appendix "A" Technical  
Specifications  
NRC Docket Nos. 50-373

Dear Mr. Schwencer:

The purpose of this letter is to request the following  
immediate change in Technical Specification's for LaSalle County  
Station Unit 1:

Change Request NPF-11/82-3

Revise the special test exception for the Confirmatory Flow  
Induced Vibration Test to allow performance of the test with the "B"  
LPCI loop isolated. This is one (1) Class III amendment.

This proposed change was discussed with Dr. Bournia, et al,  
and is addressed in the attachment. This change has received  
on-site review and approval.

Pursuant to 10 CFR 170, a fee remittance in the amount of  
\$4,000.00 is enclosed.

Please contact this office if there are any questions in  
this matter.

Three (3) signed originals and thirty-seven (37) copies of  
this transmittal and attachments are provided for your use.

Very truly yours,

*C. W. Schroeder* 6/1/82

C. W. Schroeder  
Nuclear Licensing Administrator

8206070456 820601  
PDR ADGCK 05000373  
P PDR

1m  
Attachments  
cc: NRC Resident Inspector - LSCS

SUBSCRIBED AND SWORN to  
before me this 1st day  
of June, 1982.

*Rosalie A. Presta*  
Notary Public

*Accd w/check  
\$4,000*

LASALLE COUNTY STATION UNIT 1

TECH SPEC CHANGE REQUEST NPF-11/82-3

Subject: Allow performance of the Confirmatory Flow Induced Vibration Test with the LPCI "B" loop isolated.

Background:

The Confirmatory Flow Induced Vibration Test is performed prior to initial reactor critical. Fuel is loaded into the vessel, the reactor internals and head are installed, and the reactor is heated up with pump heat. A nitrogen bubble is induced in the top of the reactor vessel and heatup continues into Condition 3 (Hot Shutdown). There is no decay heat (since the core has never been critical). Since the reactor is changing from Condition 4 (Cold Shutdown) to Condition 3 (Hot Shutdown) due to the reactor water temperature being in excess of 200°F, all systems required operable in Condition 3 must be operable prior to entering Condition 3.

Discussion:

During testing at LaSalle, the station has been unable to obtain a leak rate test on valve 1E12-F041B that falls within the 1GPM limit imposed by Specification 3.4.3.2.d. The station is pursuing repair of this valve with the vendor.

The station proposes that the manual isolation valve inside the drywell be closed. This, in combination with the normally closed injection valve provides the two closed valve protection required by action statement C of Specification 3.4.3.2. The closure of the manual isolation valve in the drywell will cause a control room alarm and indication that LPCI "B" loop is inoperable. The station's startup checklists require that all ECCS systems are verified operable prior to startup.

Closing this manual isolation valve causes LPCI "B" to be considered inoperable. Thus, in order to perform the Confirmatory Flow Induced Vibration Test, an exemption is required to allow:

- a) "B" LPCI loop to be inoperable, and
- b) 1E12-F041B valve leakage to exceed 1 gpm.

The requested changes (as shown on the attached marked up page 3/4 10-7) result in allowing the "B" LPCI system to be inoperable during this test. The HPCS, LPCS, LPCI "A" and LPCI "C" systems remain operable. During plant operation, operation would be allowed to continue for 7 days per Specification 3.5.1 Action a.1.