LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M I D C C 1 (2) | 0 0 0 0 0 0 0 0 0 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 1 5 (7) | 0 5 0 3 8 2 (8) | 0 5 2 7 8 2 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | DURING A SURVEILLANCE TEST, THE LOW PRESSURE ALARM (XPA-152) FOR THE EMERGENCY AIR
03 | SUPPLY TO NRV-152 WAS FOUND TO BE ACTUATING AT LESS THAN 900 PSIG. THIS CONDITION IS
04 | NON-CONSERVATIVE IN RESPECT TO TECHNICAL SPECIFICATION 4.4.9.3.1.d.2.a.
05
06
07
08

09 | SYSTEM CODE C J (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE S (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 2 9 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION G (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER M 2 3 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | THE LOW PRESSURE ALARM XPA-152 WAS FOUND TO BE ACTUATING AT 753 PSIG. XPA-152, MANU-
11 | FACTURED BY MERCOID CORP., MODEL DS-7241-153 WAS RECALIBRATED AND VERIFIED TO BE
12 | ACTUATING AT 952 PSIG. THE SETPOINT WAS REEVALUATED AND INCREASED TO GREATER THAN 950
13 | PSIG (MORE CONSERVATIVE). THIS CHANGE ALLOWS FOR INSTRUMENT ACCURACY AND IS TO PRE-
14 | VENT EXCEEDING LCO.

15 | FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) SURVEILLANCE TEST

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

8206070818 820527
PDR ADOCK 05000315
S PDR

almer PHONE 616-465-5901

GPO 917-928