

18

EQDP-ESE-16


Rev. 4 4/82

EQUIPMENT QUALIFICATION DATA PACKAGE

This document contains information, relative to the qualification of the equipment identified below in accordance with the methodology of WCAP-8587. The Specification section (Part I) defines the assumed limits for the equipment qualification and constitute interface requirements to the user.

Solid State Protection System (SSPS)
Two Train (Three and Four Bay) & Safeguard Test Cabinet

APPROVED:



E. P. Rahe

Manager, Nuclear Safety

WESTINGHOUSE ELECTRIC CORPORATION
NUCLEAR ENERGY SYSTEMS
P.O. BOX 355
PITTSBURGH, PENNSYLVANIA 15230

8206070855 820519
PDR TOPRP EMVWEST
C PDR

PART 1 - SPECIFICATIONS

1.0 PERFORMANCE SPECIFICATIONS

1.1 Electrical Requirements

1.1.1 Voltage: 120 VAC $\pm 10\%$ Single Phase, 105 - 140 VDC

1.1.2 Frequency: 60 or 50 Hz $\pm 5\%$

1.1.3 Load: Steady state - 10 amp; In Rush - 35 amp

1.1.4 Electromagnetic Interference: None

1.1.5 Other: The electrical requirements are described in detail
in WCAP-7488L (Reference 14)

1.2 Installation Requirements: Westinghouse Drawing 7245D75 Revision 10

1.3 Auxiliary Devices: None

1.4 Preventative Maintenance Schedule: As a result of the completion of the Westinghouse Aging Evaluation Program (Phase 1, Short Term Aging) described in WCAP-8587 and discussed in WCAP-8687 Supplement 2, Appendix A1 (Component Aging) Reference 15 and Appendix A2 (Materials Aging) Reference 16 (Proprietary), no maintenance beyond that defined in the equipment instruction manual is required to support the qualified life defined in Section 1.9.

1.5 Design Life: 40 years

1.6 Operating Cycles (Expected number of cycles during design life, including test): Continuous duty. Refer to Appendix A1, Reference 15, for mechanical cycling of relays.

1.7 Performance Requirements for Function^(b):

Parameter	Containment			DBE Conditions(a)			Post DBE Conditions(a)		
	Normal Conditions	Abnormal Conditions	Test Conditions	FLB/SLB	LOCA	Seismic	FLB/SLB	LOCA	Seismic
1.7.1 Time requirement	Continuous	12 hours	N/A	N/A	N/A	Event duration	N/A	N/A	Continuous
1.7.2 Performance requirement	Note d	As normal				As normal			As normal

1.8 Environmental conditions for Same Function^(b)

1.8.1 Temperature (°F)	60 - 80	Note c				Ambient			Ambient
1.8.2 Pressure (psig)	0	0				0			0
1.8.3 Humidity (% RH)	30 - 50	Note c				Ambient			Ambient
1.8.4 Radiation (R)	< 400	None				None			None
1.8.5 Chemicals	None	None				None			None
1.8.6 Vibration	None	None				None			None
1.8.7 Acceleration(g)	None	None				See Sec. 2.10.3.2			

Notes: a. DBE is the Design Basis Event.

b. Margin is not included in the parameters of this section.

c. Figure 1, envelope 3,. However, since operation at low humidity, based on Westinghouse experience, is not an operating concern, the abnormal extreme for humidity shall be 88 percent RH. Also, for plants having a Class 1E HVAC for the area in which the SSPS is located, the abnormal extremes are the same as the normal specified above.

d. Initiate reactor trip or safeguards actuation on demand.

WESTINGHOUSE CLASS 3

1.9 Qualified Life: The currently demonstrated qualified life (Phase 1 Short Term Aging), 5 years based on the actual test conditions identified in Table 1. Westinghouse is planning an extension (Phase II Long Term Aging) of Subprogram C of the Aging Evaluation Program (Appendix B to WCAP-8587) to increase the demonstrated qualified life.

3

1.10 Remarks: None

WESTINGHOUSE CLASS 3

PART 2 - QUALIFICATION BY TEST

2.0 TEST PLAN

3 The environmental qualification of the SSPS was performed at Westinghouse NICD (Normal) Hunt Valley, Maryland and Westinghouse DESC (Abnormal), Baltimore, Maryland.

4 2.1 Equipment Description: Three Bay configuration of the Two Train Solid State Protection System including the single-bay Safeguards Test Cabinet (see Section 2.10.2). The SSPS performs both a reactor trip function and a safeguards actuation function. The Safeguards Test Cabinet is used to perform on-line testing of the safeguards actuation feature of the SSPS. The system and electrical requirements are defined in more detail in WCAP-7488L (Reference 14).

4 The Four Bay configuration including the two-bay Safeguards Test Cabinet is made up of component parts, subassemblies, power supplies and printed circuit boards which are identical to those employed in the Three Bay configuration, in so far as part number, function and circuit configuration. Since the Four Bay configuration can be shown to have almost identical response characteristics to the Three Bay configuration (EQDP-Part 4), the Three Bay tests automatically qualify the Four Bay configuration.

2.2 Number Tested: Type test on one (1) representative train

4 2.3 Mounting: Westinghouse Drawing 7245D75 Revision 10 (four bay SSPS, two bay STC)
Westinghouse Drawing 5656D86 Revision 8 (three bay SSPS)
Westinghouse Drawing 6065D41 Revision D (one bay STC)

2.4 Connections: Terminal blocks (Power & Output); connector (input)

2.5 Aging Simulation Procedure:

As described in Subprogram C of Appendix B to WCAP-8587 and reported in Reference 15.

		<u>Normal</u>	<u>Abnormal</u>	<u>Cont.</u> <u>Test</u>	<u>Seismic</u>	<u>HELB</u>	<u>Post-HELB</u>
2.6.1	Temp. (^o F)	Ambient	Figure 2	N/A	Ambient	N/A	N/A
2.6.2	Pressure (psig)	0	0		0		
2.6.3	Humidity (% RH)	Ambient	Figure 2		Ambient		
2.6.4	Radiation (R)	None	None		None		
2.6.5	Chemicals	None	None		None		
2.6.6.	Vibration	None	None		None		
2.6.7	Acceleration (g)	None	None		See 2.10.3		

2.7 Measured Variables

This section identifies the parameters required to be measured during the test sequence(s).

2.7.1	Category I - Environment	<u>Required</u>	<u>Not Required</u>
2.7.1.1	Temperature	B	A
2.7.1.2	Pressure		A,B
2.7.1.3	Moisture	B	A
2.7.1.4	Gas Composition		A,B
2.7.1.5	Seismic Acceleration	A	B
2.7.1.6	Time	A,B	
2.7.2	Category II - Input Electrical Characteristics		
2.7.2.1	Voltage	A,B	
2.7.2.2	Current	B	A
2.7.2.3	Frequency	A,B	
2.7.2.4	Power		A,B
2.7.2.5	Other		A,B
2.7.3	Category III - Fluid Characteristics		
2.7.3.1	Chemical Composition		A,B
2.7.3.2	Flow Rate		A,B
2.7.3.3	Spray		A,B
2.7.3.4	Temperature		A,B
2.7.4	Category IV - Radiological Features		
2.7.4.1	Energy Type		A,B
2.7.4.2	Energy Level		A,B
2.7.4.3	Dose Rate		A,B
2.7.4.4	Integrated Dose		A,B

WESTINGHOUSE CLASS 3

	<u>Required</u>	<u>Not Required</u>
2.7.5 Category V - Electrical Characteristics		
2.7.5.1 Insulation Resistance		A,B
2.7.5.2 Output Voltage		A,B
2.7.5.3 Output Current		A,B
2.7.5.4 Output Power		A,B
2.7.5.5 Response Time		A,B
2.7.5.6 Frequency Characteristics		A,B
2.7.5.7 Simulated Load		A,B
2.7.6 Category VI - Mechanical Characteristics		
2.7.6.1 Thrust		A,B
2.7.6.2 Torque		A,B
2.7.6.3 Time		A,B
2.7.6.4 Load Profile		A,B
2.7.7 Category VII - Auxiliary Equipment		
None		

A: Seismic Test

B: Operational Test, Abnormal Conditions

2.8 Test Sequence Preferred

This section identifies the preferred test sequences as specified in IEEE-323-74

WESTINGHOUSE CLASS 3

- 2.8.1 Inspection of Test Item
- 2.8.2 Operation (Normal Condition)
- 2.8.3 Operation (Performance Specifications Extremes, Section 1)
- 2.8.4 Simulated Aging
- 2.8.5 Vibration
- 2.8.6 Operation (Simulated High Energy Line Break Conditions)
- 2.8.7 Operation (Simulated Post HELB Conditions)
- 2.8.8 Disassembly and Inspection

2.9 Test Sequence Actual

This section identifies the actual test sequence(s) which, in total, constitutes the overall qualification program for this equipment. The separate subsections indicate the separate test sequences completed on differing, but essentially identical, equipment and/or components. The justification for employing anything other than the preferred sequence is as follows;

4

2.9.1 Three Bay SSPS Including the Single Bay Safeguards Test Cabinet Actual Test Sequence

4

3

The DBE is simulated by the Seismic Test sequence of Section 2.9.1. The HELB Tests (Section 2.8.6 and 2.8.7) have been excluded since the SSPS is not exposed to the HELB environment due to its location. The abnormal extremes test of Section 2.9.1.2 was performed on similar equipment as permitted by IEEE-323-74 Section 6.3.2(3). An exact definition of the equipment tested in the abnormal extremes test is provided in Section 2.0 of Reference 1. The aging test employs the preferred test sequence (Section 2.8 excluding HELB and abnormal extremes Sections 2.8.6, 2.8.7, and 2.8.3) on a representative sample of components from the SSPS. The aging tests demonstrate that during the qualified life there are no in-service aging mechanisms capable of reducing the capability of the SSPS to perform during or after a seismic event. As a consequence, the seismic testing on the un-aged SSPS is not prejudiced by any in-service aging mechanisms.

WESTINGHOUSE CLASS 3

<u>Step</u>	<u>Notes</u>
2.9.1.1	Seismic Test Sequence
2.8.1	Seismic (DBE) test sequence
2.8.2	(Three Bay SSPS and the single bay Safeguards Test Cabinet only)
2.8.5	
2.8.8	

2.9.1.2	Environmental Test Sequence
2.8.1	Environmental test sequence
2.8.2	on similar piece of equipment
2.8.3	as permitted by IEEE-323
2.8.8	1974 Section 6.3.2(3)

2.9.1.3	Aging Test Sequence
2.8.1	Aging is addressed by separate testing
2.8.2	as described in Subprogram C of Appendix B
2.8.4	to WCAP-8587 and reported in References 15 and 16.
2.8.5	
2.8.8	

2.9.2	Two Bay Safeguards Test Cabinet Actual Test Sequence
-------	--

The DBE is simulated by the Environmental and Seismic Test Sequence of Section 2.9.2.2. The HELB Tests (Sections 2.8.6 and 2.8.7) have been excluded since the Safeguards Test Cabinet is not exposed to the HELB environment due to its location. The aging test employs the preferred sequence test (Section 2.8 excluding HELB and Abnormal Extremes Sections 2.8.6, 2.8.7, and 2.8.3) on a representative sample of components from the Safeguards Test Cabinet. The aging tests demonstrate that during the qualified life there are no in-service aging mechanisms capable of reducing the capability of the Safeguards

WESTINGHOUSE CLASS 3

Test Cabinet to perform during or after a seismic event. As a consequence, the seismic testing on the unaged Safe-guards Test Cabinet is not prejudiced by any in-service aging mechanisms.

2.9.2.1 Production Test Sequence

2.8.1

2.8.2 System test performed on

2.8.8 all production units

2.9.2.2 Environmental and Seismic Test Sequence

2.8.1

2.8.3 Abnormal environment and seismic

2.8.5 simulation

2.8.8

2.9.2.3 Aging Test Sequence

2.8.1

2.8.2 Aging is addressed by separate

2.8.4 testing as described in Subprogram C

2.8.5 of Appendix B to WCAP-8587 and reported

2.8.8 in References 15 and 16

2.10 Type Test Data

2.10.1 Objective

The objective of this test program is to determine, employing the recommended practices of Reg. Guide 1.89 (IEEE-323-1974) and Reg. Guide 1.100 (IEEE-344-1975), the capability of the Three Bay Two Train Solid State

WESTINGHOUSE CLASS 3

Protection System and single bay and two bay Safeguards Test Cabinet to complete the safety related functions described in EQDP Section 1.7 while exposed to the applicable environment defined in EQDP Section 1.8.

2.10.2 Equipment Tested

2.10.2.1 Three Bay SSPS

2.10.2.1.1 Three Bay SSPS Seismic Tests are reported in References 3, 4, 5, 6, and 7.

2.10.2.1.2 Environmental Test reported in Reference 1.

2.10.2.1.3 Aging Evaluation Program

A representative sample of critical components from the SSPS is included in Subprogram C of the Aging Evaluation Program described in Appendix B to WCAP 8587 and reported in Reference 15.

2.10.2.2 Safeguards Test Cabinet

2.10.2.2.1.1 Seismic Tests for the two bay cabinet are reported in Reference 2.

2.10.2.2.1.2 Seismic Tests for the single bay cabinet are reported in References 11, 12 and 18.

2.10.2.2.2 Environmental Tests for both the single bay and two bay cabinets are reported in Reference 1.

WESTINGHOUSE CLASS 3

2.10.2.2.3 Aging Evaluation Program

A representative sample of critical components from the Safeguards Test Cabinet is included in Subprogram C of the Aging Evaluation Program described in Appendix B to WCAP-8587 and reported in Reference 15.

2.10.3 Test Summary

Voltage and frequency tests were performed before, during and after the seismic and environmental testing to confirm that the equipment had not degraded substantially as the result of the test. These tests confirmed satisfactory operation.

2.10.3.1 SSPS

2.10.3.1.1 Seismic Tests (Three Bay SSPS only)

Westinghouse requires that the Three Bay Two Train Solid State Protection System be located such that it does not experience a consequent adverse environment when required to operate following a high energy line break either inside or outside containment. The single design basis event capable of producing an adverse environment at the equipment location is a seismic event. The previously completed seismic testing reported in Reference 3, 4, 5, 6, and 7 was completed on new equipment at differing seismic levels

employing single axis sine-beat testing in accordance with IEEE-344-1971. This original testing, together with the demonstration requested by the NRC employing multi-axis multi-frequency inputs as reported in References 8, 9, and 10, demonstrate the capability of the Three Bay SSPS to perform its prespecified safety-related functions, during and after seismic events up to and including those required for plants in areas of high seismic activity, (Reference 7) in accordance with Reg. Guide 1.100 (IEEE344-1975). The seismic testing which has been performed and demonstrates the transition from IEEE-344-71 testing to IEEE-344-75 requirements is reported in Reference 19. The generic seismic test levels contain significant margin with respect to any single plant application referencing this program.⁽¹⁾

2.10.3.1.2 Environmental Test

Westinghouse requires that the SSPS be located such that it does not experience a consequent adverse environment when required to operate following a high energy line break either inside or outside containment. Therefore the only testing required is to demonstrate equipment capabilities under normal and abnormal service conditions (temperature, humidity and A.C. power voltage and frequency).

Reference 13 summarizes the results of available radiation testing of organic and inorganic materials and justifies that, for radiation doses less than 10^4 rads, no deterioration in material structural properties is detectable. As a consequence, a radiation simulation is not required on this equipment, since estimated in-service radiation doses will not prejudice the capability of the equipment to perform under design basis event (i.e. seismic event) conditions.

The environmental testing reported in Reference 1 was designed to demonstrate the capability of the (Two Train) SSPS and Safeguards Test Cabinet to meet the safety-related performance requirements specified in EQDP Section 1.7 when exposed to the variations in temperature humidity, voltage, and frequency specified by EQDP Figure 2. The test successfully demonstrated the specified safety related requirements. However, the specified maximum humidity of 95% was not maintained. During the high temperature test a humidity of 88% RH was maintained, which justifies equipment acceptability up to and including 88% RH.

Additional margin was included in this test by submitting the equipment to a double cycle of electrical and environmental extremes as described by EQDP Figure 2. This test is considered to satisfactorily demonstrate the SSPS

WESTINGHOUSE CLASS 3

capability to meet its safety-related functional requirements when exposed to specified normal and simulated abnormal environments (EQDP Section 1.7) and permitted range of frequency and voltage variations (EQDP Section 1.1) in accordance with IEEE-323-1974 Section 6.3.2.(2) and (3).

2.10.3.1.3 Aging Evaluation

Subprogram C of the Westinghouse Aging Evaluation Program (Appendix B, WCAP8587) has incorporated a representative sample of components from the Solid State Protection System. This program is completed and reported in WCAP-8687 Supplement 2 Appendix A1 (Proprietary). The objective of Subprogram C is to demonstrate that during the qualified life there are no in-service aging mechanisms capable of reducing the capability of the SSPS to perform its safety-related function during or after a seismic event. As a consequence, the seismic testing on the full Solid State Protection System described above, is not prejudiced by any in-service aging mechanism.

3

2.10.3.2 Safeguards Test Cabinet

2.10.3.2.1 Seismic Tests (Single Bay Cabinet)

Westinghouse requires that the Single Bay Safeguards Test Cabinet be located such that it does not experience a

4

consequent adverse environment when required to operate following a high energy line break either inside or outside containment. The single design basis event capable of producing an adverse environment at the equipment location is a seismic event. The previously completed seismic testing reported in Reference 11, 12 and 18 was completed on new equipment at differing seismic levels employing single axis sine-beat testing in accordance with IEEE-344-1971. This original testing, together with the demonstration requested by the NRC employing multi-axis multi-frequency inputs as reported in References 8, 9, and 10, demonstrate the capability of the Single Bay Safeguards Test Cabinet to perform its prespecified safety-related functions, during and after seismic events up to and including those required for plants in areas of high seismic activity, (Reference 7) in accordance with Reg. Guide 1.100 (IEEE344-1975). The seismic testing which has been performed and demonstrates the transition from IEEE-344-1971 testing to IEEE-344-1975 requirements is reported in Reference 19. The generic seismic test levels contain significant margin with respect to any single plant application referencing this program.⁽¹⁾

WESTINGHOUSE CLASS 3

2.10.3.2.2 Seismic Tests (Two-Bay Cabinet)

The single design basis event capable of producing an adverse environment at the equipment location is a seismic event. The seismic testing reported in Reference 2 was completed on new equipment employing multi-axis multifrequency inputs in accordance with Reg. Guide 1.100 (IEEE-344-1975). The generic required response spectrum (Figure 3) contains significant margin with respect to any single plant application referencing this program.⁽¹⁾

2.10.3.2.2 Environmental Test

Westinghouse requires that the Safeguards Test Cabinet be located such that it does not experience a consequent adverse environment when required to operate following a high energy line break either inside or outside containment. Therefore the only testing required, is to demonstrate equipment capability under normal and abnormal environmental service conditions (temperature, humidity and A.C. power voltage and frequency).

Reference 13 summarizes the results of available radiation testing of organic and inorganic materials and justifies that, for radiation doses less than

10^4 rads, no deterioration in material structural properties is detectable. As a consequence, a radiation simulation is not required on this equipment, since estimated in-service radiation doses will not prejudice the capability of the equipment to perform under design basis event (i.e. seismic event) conditions.

The environmental testing reported in Reference 1 is designed to demonstrate the capability of the Safeguards Test Cabinet to meet the safety-related performance requirements specified in EQDP Section 1.7 when exposed to the variations in temperature, humidity, voltage and frequency specified by Figure 2. The testing successfully demonstrated the specified safety related requirements. Additional margin, was, furthermore, included in this test by submitting the equipment to a double cycle of electrical and environmental extremes as described by Figure 2. This test is considered to satisfactorily demonstrate the Safeguards Test Cabinets capability to meet its safety related functional requirements when exposed to the specified abnormal environments (EQDP Section 1.7) and the permitted range of frequency and voltage variations (EQDP Section 1.1) in accordance with IEEE 323-1974 Section 6.3.2(2) and (3).

WESTINGHOUSE CLASS 3

2.10.3.2.3 Aging Evaluation

Subprogram C of the Westinghouse Aging Evaluation Program (Appendix B, WCAP8587) has incorporated a representative sample of components from the Safeguards Test Cabinet. This program is completed and reported in WCAP-8687 Supplement 2, Appendix A1 (Proprietary). The objective of Subprogram C is to demonstrate that during the qualified life there are no in-service aging mechanisms capable of reducing the capability of the Safeguards Test Cabinet to perform during or after a seismic event. As a consequence the seismic testing on the full Safeguards Test Cabinet described above, is not prejudiced by an in-service aging mechanism.

2.10.4 Conclusion

The SSPS was actuated and monitored both during and following the seismic testing. The seismic test demonstrated that the SSPS is capable of initiating reactor trip or safeguards actuation on demand during or following a seismic event.

The currently demonstrated qualified life of the SSPS and Safeguards Test Cabinet is 5 years. Westinghouse is planning an extension of Subprogram C of the Aging Evaluation Program to increase the qualified life. The results of the aging program, the seismic and environmental testing described herein, together with the

WESTINGHOUSE CLASS 3

seismic analysis of Section 4, demonstrate: the qualification of the Three Bay and Four Bay SSPS and Safe-guards Test Cabinet employing the practices recommended by Reg. Guide 1.89 and 1.100.

2.11 Section 2 Notes

- (1) The generic tests proposed by Westinghouse employ parameters designed to envelope a number of plant applications. Margin is a plant specific parameter and will be established by the applicant.

WESTINGHOUSE CLASS 3

2.12 References

1. Potochnik, L. M., "Environmental Qualification of the Two Train Solid State Protection System" WCAP-8587, Supplement 2 ESF-16A (Proprietary).
2. Tang, D., E. L. Vogeding, "Equipment Qualification Seismic Test Report, Two-Bay Safeguards Test Cabinet (Seismic Design Verification Testing)", WCAP-8687 Supp 2-E16C (Proprietary)
3. Potochnik, L. M., "Seismic Testing of Electrical and Control Equipment (Low Seismic Plants)" WCAP-7817, Supplement 2 (Non-Proprietary), December 1971.
4. Vogeding, E. L., "Seismic Testing of Electrical and Control Equipment (Westinghouse Solid State Protection System (Low Seismic Plants)" WCAP-7817 Supplement 3, (Non-Proprietary), December 1971.
5. Potochnik, L. M., "Seismic Testing of Electrical and Control Equipment (High Seismic Plants)" WCAP-7821, Supplement 1 (Non-Proprietary), December 1971.
6. Potochnik, L. M., "Seismic Testing of Electrical and Control Equipment (High Seismic Plants)" WCAP-7821, Supplement 2 (Non-Proprietary), December 1971.
7. Potochnik, L. M., "Seismic Testing of Electrical and Control Equipment (PG&E Plants)" WCAP-8021 (Non-Proprietary), May 1973.

WESTINGHOUSE CLASS 3

8. Jarecki, S. J., Vogeding, E. L., "Multi-Frequency and Direction Seismic Testing of Relays WCAP 8673 (Proprietary) WCAP-8674 (Non-Proprietary), December 1975.
9. Jarecki, S. J., Vogeding, E. L., "Seismic Qualification of the Rotary Relay for Use in the Solid State Protection System" WCAP-8694 (Proprietary) WCAP-8655 (Non-Proprietary), January 1976.
10. Fischer, E. G., S. J. Jarecki, "Qualification of Westinghouse Seismic Testing Procedure for Electrical Equipment Tested Prior to May 1974", WCAP 8373 (Non-Proprietary), August 1974.
11. Vogeding, E. L., "Seismic Testing of Electrical and Control Equipment (Low Seismic Plants)," WCAP-7817, Supplement 7 (Non-Proprietary) September 1976.
12. Vogeding, E. L., "Seismic Testing of Electrical and Control Equipment (High Seismic Plants)" WCAP-7821, Supplement 5 (Non-Proprietary) September 1976.
13. Damerow, F. W., "Effects of Gamma Radiation Doses Below 10^4 Rads on the Mechanical Properties of Materials," WCAP-8587 Appendix C (Non-Proprietary).
14. Katz, D. N., "Solid State Logic Protection System Description" WCAP-7488L (Proprietary), January 1971.
15. Jabs, R., Parello, J., Huang, J., Yalich, M., "Equipment Qualification Test Report Short Term Component Aging Test Program," WCAP-8687, Supplement 2, Appendix A1 (Proprietary).

WESTINGHOUSE CLASS 3

16. "Equipment Qualification Test Report Materials Aging Analysis", WCAP-8687, Supplement 2, Appendix A2 (Proprietary).
17. Tang, D., Chang, S. M., E. L. Vogeding, "Equipment Qualification Combined Analysis and Test Report Four-Bay Cabinet of the Expanded Two-Train Solid State Protection System (SSPS) (Seismic Design Verification Analysis and Design)" WCAP-8687 Supp. 2 E16B (Proprietary).
18. Vogeding, E. L., "Seismic Testing of Electrical and Control Equipment (Engineered Safeguards Test Cabinet for P.G.&E. Plants)," WCAP-8021, Supplement 1 (Non-Proprietary) May 1977.
19. Chang, S. M., "Seismic Evaluation of the Single Frequency Sine-Beat Test Inputs Employed During 1971 Qualification Testing", ST-STA-218 (Proprietary) in progress.

WESTINGHOUSE CLASS 3

PART 3 - QUALIFICATION BY EXPERIENCE

Westinghouse does not employ operating experience in support of the Qualification Program for the Two Train SSPS and Safeguards Test Cabinet.

PART 4 - QUALIFICATION BY ANALYSIS

4.0 COMBINED ANALYSIS AND TEST FOR QUALIFICATION OF THE FOUR BAY SOLID STATE PROTECTION SYSTEM (SSPS)

4.1 Environmental Qualification and Aging

The component parts, sub-assemblies, power supplies and printed circuit boards of the Four Bay configuration of the Two Train Solid State Protection System are identical to those used for the Three Bay configuration of the system. Thus, the environmental testing, and the aging program tests and results referenced in the main body of this EQDP for the Three Bay configuration are equally applicable to the Four Bay configuration.

4.2 Seismic Qualification

A finite element analysis was performed using the Westinghouse WECAN computer code which shows that the in-equipment (device) response spectra envelopes for the Four Bay SSPS are comparable to those for the Three Bay Configuration (see Section 2 for discussion of tests) and the effects of the overturning moments of the Four Bay SSPS are enveloped by those of the Three Bay SSPS. This analysis reported in Reference 17 along with the testing of the Three Bay SSPS discussed in Section 2 demonstrate: the qualification of the Four Bay SSPS employing the practices recommended by Reg. Guide 1.100 and the Westinghouse Computer Analysis Users Manual, Revision P September 17, 1979.

TABLE 1

ACTUAL QUALIFICATION TEST CONDITIONS

EQUIPMENT (1) SYSTEM/CATEGORY	LOCATION STRUCTURE/AREA	MANUFACTURER TYPE/MODEL	ABNORMAL/ACCIDENT ENVIRONMENTAL EXTREMES		OPERABILITY		ACCURACY(%)		QUAL	QUAL	QUAL	QUAL
			PARAMETER	SPECIFIED (2)	QUALIFIED	REQ	DEM	REQ	DEM	LIFE	METHOD	REF
Solid state protection system and safeguards test cabinet/ RPS, ESF/ Category d	Control building/ MCR	W-NICD Two Train	Temperature		120 ⁰ F	12 hr.	Two	-	-	5	Seq.	ESE-
			Pressure		Atmos.	cycles	12			yrs.	Test	16
			Rel. humidity		88%		hr.			{3}		
			Radiation		10 ⁴ R(γ)		cycles					
			Chemistry		None							

WESTINGHOUSE CLASS 3

Notes:

- For definition of the category letters, refer to NUREG 0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment," Appendix E, Section 2.
- Plant specific environmental parameters are to be inserted by the applicant.
- Phase I of the Westinghouse Aging Evaluation Program as described in WCAP-8587 Appendix B has established a qualified life of at least 5 years for this equipment, Phase II of this program will extend the qualification life to a maximum of 20 years or as far as is achievable.




Figure 1 Temperature Versus Humidity - Enclosed Environments Outside Containment




Figure 2 Verification Test Profile

30




Figure 3 Refined Response Spectrum for Safe Shutdown Earthquake