

10CFR50.59 FORMAT FOR SAFETY EVALUATION

STATION LaSalle UNIT Ø 50-373
 SYSTEM RS TEST/PROCEDURE No LZP1330-21
 TEST/PROCEDURE TITLE DETERMINATION OF REACTOR COOLANT CHLORIDE CONCENTRATION AT THE HRSS REVISION 2
 EQUIPMENT NAME NA
 EQUIPMENT NUMBER NA

DESCRIPTION OF TEST/PROCEDURE: *Method of determining the reactor coolant chloride concentration during normal operating and post-accident conditions utilizing the HRSS Panels.*

SAFETY EVALUATION: Answer the following questions with a "yes" or "no", and provide specific reasons justifying the decision:

1. Is the probability of an occurrence or the consequence of an accident, or malfunction of equipment important to safety as previously evaluated in the Final Safety Analysis Report increased? Yes No, Because: *Chemistry procedure, and there are means of analyzing the reactor coolant if this fails.*
2. Is the possibility for an accident or malfunction of a different type than any previously evaluated in the Final Safety Analysis Report created? Yes No, Because: *does not affect no prohibition FSAR.*
3. Is the margin of safety, as defined in the basis for any Technical Specification, reduced? Yes No, Because: *more refined means of determining reactor coolant chloride concentration are available.*

* Note: Any answer checked "YES" should be reported in the Annual Report to the NRC

X005
5
1/1

Performed By Bul Knoll Date 4/29/82
 Approved By [Signature] Date 4/30/82

ATTACHMENT F

(Page 2 of 2)

SAFETY EVALUATION CHECKLIST (10 CFR 50.59)
TEST/PROCEDURE No. C2P/370-2/
REVISION 2

Does this constitute a change to procedures
as described in Safety Analysis Report?

Yes ()

No

Is a change in the Technical Specification
involved?

No

SAFETY EVALUATION: Answer the following questions with a 'yes' or 'no',
and provide specific reasons justifying the decision:

1. Is the probability of an occurrence, the consequence of an
accident, or malfunction of safety related equipment, as previously
evaluated in the Final Safety Analysis Report, increase?

Yes No

2. Is the possibility for an accident or malfunction of a different
type than any previously evaluated in the Final Safety Analysis
Report created? Yes No

3. Is the margin of safety, as defined in the basis for any Technical
Specification, reduced? Yes No

Any Answer = Yes ()

All Answers No

Request and receive Nuclear
Regulatory Commission
authorization for change.

Authorization Received ()

Initiate Procedure/Test
Implementation

NOTE:

Any answer checked 'yes'
should be reported in the
annual report to the NRC.

Performed by Paul Knoll

Date 4/29/82

10CFR50.59 FORMAT FOR SAFETY EVALUATION

STATION La Salle UNIT Ø
 SYSTEM PS TEST/PROCEDURE No L2P1330-22
 TEST/PROCEDURE TITLE CALIBRATION OF THE MODEL 10 DIONEX ION CHROMATOGRAPH REVISION 2
 EQUIPMENT NAME MODEL 10 DIONEX ION CHROMATOGRAPH ON CHEM. ANAL. PAPER
 EQUIPMENT NUMBER OPLE15.

DESCRIPTION OF TEST/PROCEDURE: Method of calibrating HRSS ion chromatograph for chloride analysis.

SAFETY EVALUATION: Answer the following questions with a "yes" or "no", and provide specific reasons justifying the decision:

1. Is the probability of an occurrence or the consequence of an accident, or malfunction of equipment important to safety as previously evaluated in the Final Safety Analysis Report increased? Yes No, because other means of analysis for chloride are available.
2. Is the possibility for an accident or malfunction of a different type than any previously evaluated in the Final Safety Analysis Report created? Yes No, because does not affect FSAR.
3. Is the margin of safety, as defined in the basis for any Technical Specification, reduced? Yes No, because other means of chloride analysis available.

* Note: Any answer checked "YES" should be reported in the Annual Report to the NRC

Performed By Paul Kroll Date 4/29/82
 Approved By J. Marshall Date 4/30/82

ATTACHMENT F

(Page 2 of 2)

SAFETY EVALUATION CHECKLIST (10 CFR 50.59)
TEST/PROCEDURE No. L2P1330-22
REVISION 2

Does this constitute a change to procedures
as described in Safety Analysis Report?

Yes ()

No

Is a change in the Technical Specification
involved?

No

SAFETY EVALUATION: Answer the following questions with a 'yes' or 'no',
and provide specific reasons justifying the decision:

1. Is the probability of an occurrence, the consequence of an
accident, or malfunction of safety related equipment, as previously
evaluated in the Final Safety Analysis Report, increase?
Yes No

2. Is the possibility for an accident or malfunction of a different
type than any previously evaluated in the Final Safety Analysis
Report created? Yes No

3. Is the margin of safety, as defined in the basis for any Technical
Specification, reduced? Yes No

Any Answer = Yes ()

All Answers No

Request and receive Nuclear
Regulatory Commission
authorization for change.

Authorization Received ()

Initiate Procedure/Test
Implementation

NOTE:

Any answer checked 'yes'
should be reported in the
annual report to the NRC.

Performed by Paul Knoll

Date 4/29/82

10CFR50.59 FORMAT FOR SAFETY EVALUATION

STATION LaSalle UNIT Ø
 SYSTEM RS TEST/PROCEDURE No LEP1330-23
 TEST/PROCEDURE TITLE DETERM. OF RX COOLANT PH, COND. + D.O. AT THE HRS REVISION 1
 EQUIPMENT NAME NA
 EQUIPMENT NUMBER NA

DESCRIPTION OF TEST/PROCEDURE *Method of determining Rx Coolant PH, conductivity and dissolved oxygen concentrations at the HRS panels during normal operating and post-accident conditions*

SAFETY EVALUATION: Answer the following questions with a "yes" or "no", and provide specific reasons justifying the decisions:

1. Is the probability of an occurrence or the consequence of an accident, or malfunction of equipment important to safety as previously evaluated in the Final Safety Analysis Report increased? Yes No, Because: *Chemistry Procedure, also backup methods are available if the equipment malfunctions*
2. Is the possibility for an accident or malfunction of a different type than any previously evaluated in the Final Safety Analysis Report created? Yes No, Because: *Does not affect previous FSAR.*
3. Is the margin of safety, as defined in the basis for any Technical Specification, reduced? Yes No, Because: *Backup and more accurate methods are available.*

* Note: Any answer checked "YES" should be reported in the Annual Report to the NRC

Performed By Paul Knoll Date 4/29/82
 Approved By J. Marshall Date 4/30/82

ATTACHMENT F

(Page 2 of 2)

SAFETY EVALUATION CHECKLIST (10 CFR 50.59)
TEST/PROCEDURE No. LAP 1330-23
REVISION 1

Does this constitute a change to procedures as described in Safety Analysis Report?

Yes ()

No

Is a change in the Technical Specification involved?

No

SAFETY EVALUATION: Answer the following questions with a 'yes' or 'no', and provide specific reasons justifying the decision:

1. Is the probability of an occurrence, the consequence of an accident, or malfunction of safety related equipment, as previously evaluated in the Final Safety Analysis Report, increase?

Yes No

2. Is the possibility for an accident or malfunction of a different type than any previously evaluated in the Final Safety Analysis Report created?

Yes No

3. Is the margin of safety, as defined in the basis for any Technical Specification, reduced?

Yes No

Any Answer = Yes ()

All Answers No

Request and receive Nuclear Regulatory Commission authorization for change.

Authorization Received ()

Initiate Procedure/Test Implementation

NOTE:

Any answer checked 'yes' should be reported in the annual report to the NRC.

Performed by Paul Kroll

Date 4/24/82

10CFR50.59 FORMAT FOR SAFETY EVALUATION

STATION LaSalle UNIT Ø
 SYSTEM CM TEST/PROCEDURE No L2P1330-26
 TEST/PROCEDURE TITLE SAMPLING OF CONTAINMENT AIR AT THE HRSS REVISION 2
 EQUIPMENT NAME _____
 EQUIPMENT NUMBER _____

DESCRIPTION OF TEST/PROCEDURE: *describes method of obtaining a containment air sample during post-accident and normal operating conditions at the HRSS.*

SAFETY EVALUATION: Answer the following questions with a "yes" or "no", and provide specific reasons justifying the decisions:

1. Is the probability of an occurrence or the consequence of an accident, or malfunction of equipment important to safety as previously evaluated in the Final Safety Analysis Report increased? Yes No, Because: *The sample partition is not mentioned in the FSAR, however the CCP + CASP are mentioned & this in no way changes the intent.*
2. Is the possibility for an accident or malfunction of a different type than any previously evaluated in the Final Safety Analysis Report created? Yes No, Because: *Sampling does not affect FSAR, and there are other means of monitoring containment air.*
3. Is the margin of safety, as defined in the basis for any Technical Specification, reduced? Yes No, Because: *It is a sampling procedure, & will aid in monitoring, it is not the only means of monitoring the containment.*

* Note: Any answer checked "YES" should be reported in the Annual Report to the NRC

Performed By Paul Kroll Date 5-6-82
 Approved By [Signature] Date 5-7-82

ATTACHMENT F

(Page 2 of 2)

SAFETY EVALUATION CHECKLIST (10 CFR 50.59)
TEST/PROCEDURE No. LCP 1330-26
REVISION 2

Does this constitute a change to procedures as described in Safety Analysis Report?

Yes ()

No

Is a change in the Technical Specification involved?

Yes ()

No

SAFETY EVALUATION: Answer the following questions with a 'yes' or 'no', and provide specific reasons justifying the decision:

1. Is the probability of an occurrence, the consequence of an accident, or malfunction of safety related equipment, as previously evaluated in the Final Safety Analysis Report, increase?
Yes No *does not change FSAR*

2. Is the possibility for an accident or malfunction of a different type than any previously evaluated in the Final Safety Analysis Report created? Yes No *does not change FSAR*

3. Is the margin of safety, as defined in the basis for any Technical Specification, reduced? Yes No *does not change, only an extra monitoring are*

Any Answer = Yes ()

All Answers No

Request and receive Nuclear Regulatory Commission authorization for change.

Authorization Received ()

Initiate Procedure/Test Implementation

NOTE:

Any answer checked 'yes' should be reported in the annual report to the NRC.

Performed by Paul Kroll

Date 5-6-82