(7-77)

# LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NJSGS2 (2) | 00-00000-00 (3) | 4111 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 05000311 (7) | 042482 (8) | 051982 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On April 24, 1982, while diluting with No. 22 Primary Water Makeup Pump, the Control
03 Room Operator discovered that No. 2C Vital Bus Infeed Breaker 22CSD had tripped, de-
04 energizing the bus. At 0830 hours, No. 2C Vital Bus was declared inoperable, and
05 Action Statement 3.8.2.1.a was entered. This occurrence constituted operation in a
06 degraded mode in accordance with Technical Specification 6.9.1.9.b. (82-019, 81-123,
07 81-109)
08

09 SYSTEM CODE IB (11) | CAUSE CODE B (12) | CAUSE SUBCODE A (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE X (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 031 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN F (18) | FUTURE ACTION F (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER A640 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Breaker 22CSD tripped as a result of a known noise problem with the Safeguards Equip-
11 ment Control (SEC) System. At 0835 hours, April 24, 1982, Breaker 21CSD was closed in
12 and No. 2C Vital Bus was re-energized. The bus was declared operable, and Action
13 Statement 3.8.2.1.a was terminated. Design Change Request 2EC1387 had been issued to
14 install noise suppression circuitry in the SEC System.

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS NA (30) | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY NA (35) | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES — NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES — NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY — TYPE Z (42) | DESCRIPTION NA (43)

20 PUBLICITY — ISSUED N (44) | DESCRIPTION (45) NA

8206100150 820519
PDR ADOCK 05000311
S PDR

NRC USE ONLY

NAME OF PREPARER R. Frahm PHONE: (609) 541-5900 629