

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 14 15 25 26 37 38 39 40 41 42 43 44 45

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 5 1 0 8 2 8 0 6 0 3 8 2 9  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 DURING NORMAL OPERATION, AN OPERATOR ON TOUR DISCOVERED THAT FIRE DOOR #226,  
0 3 "E" MDAFP ROOM, WOULD NOT FULLY CLOSE. THIS CONSTITUTED AN INOPERABLE PENE-  
0 4 TRATION FIRE BARRIER, CONTRARY TO T.S. 3.7.10. ACTION REQUIREMENTS WERE MET.  
0 5 PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.  
0 6  
0 7  
0 8

0 3 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE  
9 10 11 12 13 14 15 16 17 18 19 20  
A B 11 B 12 A 13 X X X X X X X 14 Z 15 Z 16  
17 LER RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
21 22 23 24 25 26 27 28 29 30 31 32  
8 2 0 3 3 0 3 L 0  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47  
X 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25 X 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE DOOR WOULD NOT CLOSE AGAINST THE FLOW OF THE THERMOSTATICALLY CONTROLLED  
1 1 VENTILATION SUPPLY FAN. A LARGER, ADDITIONAL CLOSURE MECHANISM WAS ADDED.  
1 2 THE DOOR OPERATED SATISFACTORILY.  
1 3  
1 4

1 5 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
E 28 1 0 0 0 29 NA 30 B 31 OPERATOR OBSERVATION 32  
1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
Z 33 Z 34 NA 35 NA 36  
1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
0 0 0 37 Z 38 NA 39  
1 8 PERSONNEL INJURIES NUMBER DESCRIPTION (41)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
0 0 0 40 NA 41  
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
Z 42 NA 43  
2 0 PUBLICITY ISSUED DESCRIPTION (45)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
N 44 NA 45

8206100264 820603  
PDR ADOCK 05000315  
S PDR

NRC USE ONLY

NAME OF PREPARER R. H. PIEHL

PHONE 616-465-5901