

JOSEPH M. FARLEY NUCLEAR PLANT
UNIT 2
NARRATIVE SUMMARY OF OPERATIONS
SEPTEMBER, 1981

There was one (1) automatic shutdown and one (1) power reduction in the month of September.

The following safety-related maintenance was performed in the month of September:

1. Performed miscellaneous maintenance on diesel generators.
2. Replaced seals and the outboard bearing on 2A Component Cooling Water pump.

OPERATING DATA REPORT

DOCKET NO. 50-364
 DATE 10/1/81
 COMPLETED BY W.G. Hairston, III
 TELEPHONE (205) 899-5156

OPERATING STATUS

1. Unit Name: Joseph M. Farley - Unit 2
2. Reporting Period: September, 1981
3. Licensed Thermal Power (MWt): 2652
4. Nameplate Rating (Gross MWe): 860
5. Design Electrical Rating (Net MWe): 829
6. Maximum Dependable Capacity (Gross MWe): 860*
7. Maximum Dependable Capacity (Net MWe): 829*

Notes: 1) Cumulative data since 7/30/81, date of commercial operation.

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A

10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>1,512</u>	<u>1,512</u>
12. Number Of Hours Reactor Was Critical	<u>709.3</u>	<u>1,478</u>	<u>1,478</u>
13. Reactor Reserve Shutdown Hours	<u>10.7</u>	<u>34.0</u>	<u>34.0</u>
14. Hours Generator On-Line	<u>705.5</u>	<u>1,467.1</u>	<u>1,467.1</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,837,260.6</u>	<u>3,786,082.5</u>	<u>3,786,082.5</u>
17. Gross Electrical Energy Generated (MWH)	<u>592,994</u>	<u>1,219,690</u>	<u>1,219,690</u>
18. Net Electrical Energy Generated (MWH)	<u>564,164</u>	<u>1,158,250</u>	<u>1,158,250</u>
19. Unit Service Factor	<u>98.0</u>	<u>97.0</u>	<u>97.0</u>
20. Unit Availability Factor	<u>98.0</u>	<u>97.0</u>	<u>97.0</u>
21. Unit Capacity Factor (Using MDC Net)	<u>94.5</u>	<u>92.4</u>	<u>92.4</u>
22. Unit Capacity Factor (Using DER Net)	<u>94.5</u>	<u>92.4</u>	<u>92.4</u>
23. Unit Forced Outage Rate	<u>02.0</u>	<u>03.0</u>	<u>03.0</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	<u>5/6/81</u>	<u>5/8/81</u>
INITIAL ELECTRICITY	<u>5/24/81</u>	<u>5/25/81</u>
COMMERCIAL OPERATION	<u>8/1/81</u>	<u>7/30/81</u>

* The Nameplate Rating/Design Electrical Rating will be used for the Maximum Dependable Capacity until an accurate value can be determined from operating experience.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-364UNIT 2DATE 10/1/81COMPLETED BY W. G. Hairston, IIITELEPHONE (205) 899-5156MONTH September, 1981

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>813</u>	17	<u>824</u>
2	<u>807</u>	18	<u>816</u>
3	<u>652</u>	19	<u>776</u>
4	<u>212</u>	20	<u>826</u>
5	<u>801</u>	21	<u>826</u>
6	<u>808</u>	22	<u>823</u>
7	<u>805</u>	23	<u>821</u>
8	<u>807</u>	24	<u>819</u>
9	<u>813</u>	25	<u>816</u>
10	<u>816</u>	26	<u>779</u>
11	<u>810</u>	27	<u>788</u>
12	<u>748</u>	28	<u>817</u>
13	<u>809</u>	29	<u>825</u>
14	<u>812</u>	30	<u>817</u>
15	<u>812</u>	31	<u>----</u>
16	<u>811</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

(9/77)

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-364UNIT NAME J.M. Farley-Unit 2DATE 10/1/81REPORT MONTH September, 1981COMPLETED BY W.G. Hairston, IIITELEPHONE (205) 899-5156

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
029	810903	F	14.5	H	3	N/A	HJ	RELAYX	Turbine Trip-Reactor Trip due to S/G 2A Low Low level. Lost 2B SGFP during STP performance. Relay in control circuitry was adjusted.
030	810927	F	0	D	4	81-067/03L-0	EE	ENGINE	With D/G 1C and D/G 2C inoperable, one D/G must be made operable within 2 hours or be in Mode 3 within the next 6 hours. Unit power reduced to 450 MWe before receiving an extension of T/S action statement time requirements. Returned to 100% power and initiated repairs to both D/G's.

¹
F: Forced
S: Scheduled

²
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

⁴
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

(9/77)

⁵
Exhibit I - Same Source

JOSEPH M. FARLEY NUCLEAR PLANT
UNIT 2
NARRATIVE SUMMARY OF OPERATIONS
SEPTEMBER, 1981

There was one (1) automatic shutdown and one (1) power reduction in the month of September.

The following safety-related maintenance was performed in the month of September:

1. Performed miscellaneous maintenance on diesel generators.
2. Replaced seals and the outboard bearing on 2A Component Cooling Water pump.

OPERATING DATA REPORT

DOCKET NO. 50-364
 DATE 10/1/81
 COMPLETED BY W.G. Hairston, III
 TELEPHONE (205) 899-5156

OPERATING STATUS

1. Unit Name: Joseph M. Farley - Unit 2
2. Reporting Period: September, 1981
3. Licensed Thermal Power (Mwt): 2652
4. Nameplate Rating (Gross MWe): 860
5. Design Electrical Rating (Net MWe): 829
6. Maximum Dependable Capacity (Gross MWe): 860*
7. Maximum Dependable Capacity (Net MWe): 829*

Notes: 1) Cumulative data since 7/30/81, date of commercial operation.

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A

10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	720	1,512	1,512
12. Number Of Hours Reactor Was Critical	709.3	1,478	1,478
13. Reactor Reserve Shutdown Hours	10.7	34.0	34.0
14. Hours Generator On-Line	705.5	1,467.1	1,467.1
15. Unit Reserve Shutdown Hours	0	0	0
16. Gross Thermal Energy Generated (MWH)	1,837,260.6	3,786,082.5	3,786,082.5
17. Gross Electrical Energy Generated (MWH)	592,994	1,219,690	1,219,690
18. Net Electrical Energy Generated (MWH)	564,164	1,158,250	1,158,250
19. Unit Service Factor	98.0	97.0	97.0
20. Unit Availability Factor	98.0	97.0	97.0
21. Unit Capacity Factor (Using MDC Net)	94.5	92.4	92.4
22. Unit Capacity Factor (Using DER Net)	94.5	92.4	92.4
23. Unit Forced Outage Rate	02.0	03.0	03.0

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A

26. Units In Test Status (Prior to Commercial Operation):	Forecast	Achieved
INITIAL CRITICALITY	5/6/81	5/8/81
INITIAL ELECTRICITY	5/24/81	5/25/81
COMMERCIAL OPERATION	8/1/81	7/30/81

* The Nameplate Rating/Design Electrical Rating will be used for the Maximum Dependable Capacity until an accurate value can be determined from operating experience.

DOCKET NO. 50-364UNIT 2DATE 10/1/81COMPLETED BY W. G. Hairston, IIITELEPHONE (205)899-5156MONTH September, 1981

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>813</u>	17	<u>824</u>
2	<u>807</u>	18	<u>816</u>
3	<u>652</u>	19	<u>776</u>
4	<u>212</u>	20	<u>826</u>
5	<u>801</u>	21	<u>826</u>
6	<u>808</u>	22	<u>823</u>
7	<u>805</u>	23	<u>821</u>
8	<u>807</u>	24	<u>819</u>
9	<u>813</u>	25	<u>816</u>
10	<u>816</u>	26	<u>779</u>
11	<u>810</u>	27	<u>788</u>
12	<u>748</u>	28	<u>817</u>
13	<u>809</u>	29	<u>825</u>
14	<u>812</u>	30	<u>817</u>
15	<u>812</u>	31	<u>-----</u>
16	<u>811</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH September, 1981DOCKET NO. 50-364UNIT NAME J.M. Farley-Unit 2DATE 10/1/81COMPLETED BY W.G. Hairston, IIITELEPHONE (201) 899-5156

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
029	810903	F	14.5	H	3	N/A	IIJ	RELAYX	Turbine Trip-Reactor Trip due to S/G 2A Low Low level. Lost 2B SGFP during STP performance. Relay in control circuitry was adjusted.
030	810927	F	0	D	4	81-067/03L-0	EE	ENGINE	With D/G 1C and D/G 2C inoperable, one D/G must be made operable within 2 hours or be in Mode 3 within the next 6 hours. Unit power reduced to 450 MWe before receiving an extension of T/S action statement time requirements. Returned to 100% power and initiated repairs to both D/G's.

1
F: Forced
S: Scheduled

2
Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3
Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4
Exhibit G - Instructions
for Preparation of Data
Entry Sheets for Licensee
Event Report (LER) File (NUREG-
0161)

5
Exhibit I - Same Source