NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S C N E E 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 6 9 (7) | 0 3 0 2 8 2 (8) | 0 4 0 1 8 2 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | On March 2, 1982, the 1A Reactor Building Spray Pump was declared inoperable
03 | due to inability to achieve the flow rate required by the Reactor Building
04 | Spray Pump Operability Test. During this incident all three Reactor Building
05 | Cooling Units were verified to be operating and the redundant Reactor Building
06 | Spray Pump was operable. Thus, the health and safety of the public were not
07 | affected by this incident.
08 |

09 | SYSTEM CODE S C (11) | CAUSE CODE A (12) | CAUSE SUBCODE A (13) | COMPONENT CODE P U M P X X (14) | COMP. SUBCODE B (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 2 | — | SEQUENTIAL REPORT NO. 0 0 5 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER I 0 7 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The failure of the 1A pump was the result of running the pump for approximately
11 | three hours with no suction flow. The pump was replaced, tested, and declared
12 | operable. The Control Room Operator was counseled and made aware of the results
13 | of his action.
14 |

15 | FACILITY STATUS E (28) | % POWER 1 0 0 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Reactor Bldg. Spray Pump Operab. Test

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

NAME OF PREPARER J. F. Norris PHONE: (704) 373-2844

8204160236 820401
PDR ADOCK 05000269
S PDR