

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 A L J M F 2 (2) 0 0 - 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) 57 CAT 58 (5)

REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 4 | 7 | 0 | 3 | 1 | 5 | 8 | 2 | 8 | 0 | 4 | 0 | 6 | 8 | 2 | 9
69 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

[012] At 1118 on 3/15/82 radiation monitors R-11 (Particulate Activity - RCS Leakage Detection), R-12, (Gaseous Activity - RCS Leakage Detection) and R-22 (Noble Gas Activity) [013] were declared inoperable when their supply power was interrupted due to a generator [014] trip. Tech. Spec. sections 3.3.3.1 and 3.3.3.11, in part, require these radiation [015] monitors to be operable. Tech. Spec. action statement requirements were met. Health/ [016] safety of the public was not affected.

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COPR. SUBCODE	VALVE SUBCODE			
J 0 9 6	B B 11	X 12	z 13	x x x x x x 14	z 15	z 16		
	9 10	11	12 13	18	19	20		
LEROHO REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.			
17	8 2 21	0 1 3 24	0 13 28	L 30	0 31	0 32		
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X 18	Z 19	Z 20	Z 21	0 0 0 0 22	N 23	N 24	Z 25	Z 9 9 9 26
33	34	35	36	37	40	41	43	44
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)								

10 | The power supply to radiation monitors R-11, R-12, and R-22 was de-energized as a re-
11 | sult of a generator trip which occurred while the 2A startup transformer was out of
12 | service for maintenance. The startup transformer was returned to service and R-11,
13 | R-12 and R-22 were declared operable at 1711 on 3/15/82.

1 9 Z 42 NA
I B S 8204160578 820406
2 0 PDR ADOCK 05000364
S P

W. G. Hairston, II

points

(205) 899-5156