NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Field	Value
01 Licensee Code (2)	N J S G S 2
License Number (3)	0 0 - 0 0 0 0 0 - 0 0
License Type (4)	4 1 1 1 1
CAT (5)	
CON'T 01 Report Source (6)	L
Docket Number (7)	0 5 0 0 0 3 1 1
Event Date (8)	0 3 1 3 8 2
Report Date (9)	0 3 3 1 8 2

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On March 13, 1982, during performance of Surveillance Procedure SP(O)4.0.5.p, No. 23 Auxiliary Feedwater Pump would not attain the specified minimum speed of 3500 RPM. At 1131 hours the pump was declared inoperable, and Action Statement 3.7.1.2.a was entered.

System Code (11)	Cause Code (12)	Cause Subcode (13)	Component Code (14)	Comp. Subcode (15)	Valve Subcode (16)
CH	E	B	PUMPXX	B	Z

LER/RO Report Number (17)

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
8 2	—	0 2 0	/	0 3	L	—	0

Action Taken (18)	Future Action (19)	Effect on Plant (20)	Shutdown Method (21)	Hours (22)	Attachment Submitted (23)	NPRD-4 Form Sub. (24)	Prime Comp. Supplier (25)	Component Manufacturer (26)
D	Z	Z	Z	0 0 0 0	Y	Y	N	T 1 4 7

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The auxiliary feedwater pump failed to reach speed due to leakage past the overspeed ball check valve and the governor linkage being out of adjustment. The overspeed ball check valve seated after being flushed and the governor linkage was properly adjusted. Surveillance Procedure SP(O)4.0.5.p was satisfactorily performed. At 1345 hours, March 14, 1982 the pump was declared operable and Action Statement 3.7.1.2.a was terminated.

Facility Status (28)	% Power (29)	Other Status (30)	Method of Discovery (31)	Discovery Description (32)
E	1 0 0	NA	B	Surveillance Test

Activity Released (33)	Content of Release (34)	Amount of Activity (35)	Location of Release (36)
Z	Z	NA	NA

Personnel Exposures

Number (37)	Type (38)	Description (39)
0 0 0	Z	NA

Personnel Injuries

Number (40)	Description (41)
0 0 0	NA

Loss of or Damage to Facility (43)

Type (42)	Description
Z	NA

Publicity: Issued S

NRC USE ONLY

8204160593 820331
PDR ADOCK 05000311
S PDR

NAME OF PREPARER R. Frahm PHONE: 609-935-0998

GPO 917-926