(7-77) .	
	CONTROL BLOCK: [] [] [(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 7 8	N J S G S 2 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 57 CAT 58
CON'T	REPORT LOG 0 5 0 0 0 3 1 1 7 0 6 0 6 8 1 8 0 7 0 6 8 1 9 SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
0 2	At 1700 hours, June 6, 1981, during a routine channel check, Pressurizer Pressure
	Channel 1 indicated greater than the maximum allowable tolerance. The channel was
0 3	declared inoperable and the bistables were tripped. Action Statements 3.3.1 and
0 4	3.3.2 were entered. This constituted operation in a degraded mode in accordance
0 5	
0 6	with Technical Specification 6.9.1.9.b.
0 7	
0 8	
0 9 7 B	SYSTEM CAUSE CAUSE SUBCODE SUB
	17 REPORT NUMBER 21 22 23 24 26 27 28 29 30 31 32
	ACTION FUTURE ON PLANT SHUTDOWN HOURS 22 ATTACHMENT NPRD-4 PRIME COMP. COMPONENT SUBMITTED FORM SUB. SUPPLIER MANUFACTURER E 18 Z 19 Z 20 Z 21 0 0 0 0 0 Y 23 Y 24 L 25 F 1 2 0 (
110	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) Pressure transmitter 2PT455 had drifted out of specification. Pressurizer Pressure
	Channel 1 was recalibrated; tested satisfactorily, and returned to service.
	Action Statements 3.3.1 and 3.3.2 were terminated at 2030 hours, on June 6, 1981.
112	
1 3	
	9 80 FACILITY (30) METHOD OF
	STATUS POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32) C 28 0 0 0 29 N/A A 31 Operator Observation
	PERSONNEL EXPOSURES 9 10 12 13 44 45 46 LOCATION OF RELEASE 36 NA 45 46 LOCATION OF RELEASE 36
1 7	NUMBER OF SCRIPTION (39) O O O O O O O O O O O O O O O O O O O
	PERSONNEL INJURIES NUMBER DESCRIPTION 41
7 8	O O O O O O O O O O O O O O O O O O O
1 9	Z (42) NA
7 B	9 10 PUBLICITY ISSUED DESCRIPTION 45
2 0	9 10 68 69 80
82041 PDR A	90161 810706 J. J. Espey PHONE 609-935-0998 DDCK 05000311 PDR