

UNITED STATES GOVERNMENT

# Memorandum

*W. O'Reilly  
compliance  
to Carlton  
of Sears &  
February 10, 1967  
Notan*

TO : R. S. Boyl Chief, Research & Power Reactor  
Safety Branch, Division of Reactor Licensing, HQ

DATE: February 10, 1967  
*Notan*

FROM : J. P. O'Reilly, Senior Reactor Inspector  
Region I, Division of Compliance

*J. P. O'Reilly*

SUBJECT: U. S. ARMY MATERIALS RESEARCH AGENCY - WATERTOWN ARSENAL  
DOCKET NO. 50-47

The attached report by our field inspector of an unannounced visit to the subject facility on January 19, 1967, is forwarded for information. No items of noncompliance and no safety problems were noted.

Tests of the absolute filters are not required at this facility and are not being conducted. Since the licensee is planning on raising the licensed maximum power level to 5 Mwt, you may wish to consider this fact during discussions on this subject.

Attachment:

CO Rpt. No. 47/67-1

by J. R. Sears

dtd 2/10/67

cc: L. Kornblith, Jr., CO:HQ

E. G. Case, DRL (2)

R. G. Page, SLR

CO:HQ File



8204210345 811005  
PDR FOIA  
KABAT-281-311 PDR