

APRIL 7 1982

DISTRIBUTION
Docket File

DMB 016

Dockets Nos. 50-321
and 50-366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

NRC PDR
L PDR
TERA
NSIC
ORB#4 Rdg
DEisenhut
OELD
AEOD
IE
ACRS-10
MFairtile
RIngram
Gray File
SCheng
GJohnson
WHazelton



By letters dated May 1, 1980 and March 11, 1982, you requested relief from the 1974 Edition of the ASME Section XI Code in regard to the Code required inservice inspection hydrostatic minimum test temperature of 100°F. You also requested that hydrostatic test duration times be adjusted for insulated and non-insulated systems. You requested a hydrostatic test temperature of no less than 70°F and hold times of four hours for insulated systems and 10 minutes for non-insulated systems in accordance with later addenda to the 1974 Edition of the Section XI Code. Your requests are based on the results of a nil ductility analyses and on the "undue hardship" considerations allowed by 10 CFR 50.55a.g.5.1v.

Based on our review of the information in your submittals, we have no objection to the use of the requested hydrostatic test temperature and hold times.

Sincerely,

ORIGINAL SIGNED BY
JOHN F. STOLZ

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page

8204210460 820407
PDR ADCK 05000321
Q PDR

OFFICE	ORB#4:DL	MEB LITEB	C-ORB#4:DL				
SURNAME	MFairtile;cf	WHazelton	JStolz				
DATE	4/7/82	4/7/82	4/7/82				

Hatch 1/2
Georgia Power Company

50-321/366

cc w/enclosure(s):

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Ruble A. Thomas
Vice President
P. O. Box 2625
Southern Company Services, Inc.
Birmingham, Alabama 35202

Ozen Batum
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. L. T. Gucwa
Georgia Power Company
Engineering Department
P. O. Box 4545
Atlanta, Georgia 30302

Mr. Max Manry
Georgia Power Company
Edwin I. Hatch Plant
P. O. Box 442
Baxley, Georgia 31513

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Appling County Public Library
301 City Hall Drive
Baxley, Georgia 31513

Mr. R. F. Rogers
U. S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Mr. James P. O'Reilly, Regional
Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

April 7, 1982

Dockets Nos. 50-321
and 50-366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
P. O. Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

By letters dated May 1, 1980 and March 11, 1982, you requested relief from the 1974 Edition of the ASME Section XI Code in regard to the Code required inservice inspection hydrostatic minimum test temperature of 100°F. You also requested that hydrostatic test duration times be adjusted for insulated and non-insulated systems. You requested a hydrostatic test temperature of no less than 70°F and hold times of four hours for insulated systems and 10 minutes for non-insulated systems in accordance with later addenda to the 1974 Edition of the Section XI Code. Your requests are based on the results of a nil ductility analyses and on the "undue hardship" considerations allowed by 10 CFR 50.55a.g.5.iv.

Based on our review of the information in your submittals, we have no objection to the use of the requested hydrostatic test temperature and hold times.

Sincerely,

John F. Stolz
John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page