

JUN 19 1961

Peter A. Morris, Assistant Director for
Reactors, Division of Compliance, Hdqs.

Robert W. Kirkman, Director
Compliance Division, NY

WATERTOWN ARSENAL REACTOR

CMP:JRS

Enclosed is an inspection report on the Watertown Arsenal
Reactor.

The reactor has not been extensively used as yet, due to
leaking of pool water through the concrete shield. There is
no health or safety problem in this leaking water, however.
The operating staff has taken advantage of this time to make
many training runs. O'Connor stated that he now has four
additional people, besides himself and Richard Stanton, who
he believes are qualified to take the operator's license
examination. In our judgement, the reactor has been and
will be operated with negligible risk of hazard to the health
and safety of the public.

Enclosure:
2 cys Rpt

B204210542 B11005
PDR FOIA
KABAT-781-311 PDR

Compliance

Sears:pm Kirkman
6/5/61

35