

License No. R-65

APPENDIX A

NOTICE OF VIOLATIONS

Based on the results of an NRC inspection conducted on November 25, 1975, it appears that certain of your activities were not conducted in full compliance with the conditions of your Facility License No. R-65 as indicated below:

- A. Contrary to Technical Specification 2.b.(3), which requires the Reactor Safeguards Committee to semiannually audit activities in the plant area, no such audits have been conducted.

This is an infraction.

- B. Contrary to Technical Specification 4.b.(1), which requires a weekly visual inspection of the heating and ventilation system, no inspection was conducted during the period November 4-19, 1975.

This is a deficiency.

- C. Contrary to Title 10, Code of Federal Regulations, Part 19.11(a), which requires the posting of a current copy of the license and amendments thereto, posted copies of these documents were not current.

This item is a deficiency.

B204210647 811005
PDR FOIA
KABAT-Z81-311 PDR