

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261



R. H. LEASBURG  
VICE PRESIDENT  
NUCLEAR OPERATIONS

April 16, 1982

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Robert A. Clark, Chief  
Operating Reactors Branch No. 3  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 228  
NO/JHL:acm  
Docket Nos. 50-338  
50-339  
License Nos. NPF-4  
NPF-7

Gentlemen:

AMENDMENT TO OPERATING LICENSES NPF-4 AND NPF-7  
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2  
PROPOSED TECHNICAL SPECIFICATION CHANGE

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment, in the form of changes to the Technical Specifications, to Operating Licenses NPF-4 and NPF-7 for the North Anna Power Station, Unit Nos. 1 and 2. The proposed changes are enclosed.

The proposed change exempts North Anna Unit Nos. 1 and 2 from the requirement to perform functional testing for large snubbers greater than 50,000 kips, around the steam generators and reactor coolant pumps, during the upcoming refueling and maintenance outages. The proposed change will prevent personnel radiation exposure and allow the current refueling and maintenance schedules to remain unchanged. The restart of North Anna Unit No. 2 is scheduled for May 14, 1982 and the restart of North Anna Unit No. 1 is scheduled for July 2, 1982.

Vepco will functionally test a representative sample of large snubbers greater than 50,000 kips each refueling outage and then functionally test all large snubbers greater than 50,000 kips within their seal lifetime.

This request has been reviewed by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff. It has been determined that this request does not involve an unreviewed safety question.

We have evaluated this request in accordance with the criteria in 10 CFR 170.22. It has been determined that this request requires a Class III amendment fee. Accordingly, a voucher check in the amount of \$4,400 is enclosed in payment of the required fee.

Very truly yours,

*R. H. Leasburg*  
R. H. Leasburg

*A001*  
*1/1*  
*w/check:*  
*\$4400.00*

8204220366 820416  
PDR ADDCK 05000338  
P PDR

Attachments:

1. Proposed Technical Specification Change - Unit 1
2. Proposed Technical Specification Change - Unit 2
3. Discussion of Proposed Technical Specification Changes
4. Voucher Check No. 18531 for \$4,400

cc: Mr. James P. O'Reilly, Regional Administrator  
Office of Inspection and Enforcement  
Region II

COMMONWEALTH OF VIRGINIA )  
  )  
CITY OF RICHMOND                         )

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart, who is Manager-Nuclear Operations and Maintenance, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 16<sup>th</sup> day of April, 19 82.

My Commission expires: 2-26, 19 85.

Ann C. McSee  
Notary Public

(SEAL)

M004

**Veeco**

WACHOVIA BANK & TRUST COMPANY N.A.

**VIRGINIA ELECTRIC AND POWER COMPANY**  
RICHMOND, VIRGINIA

531

VOID IF NOT CASHED IN 90 DAYS

03301 26 0018531 00000440000

PAY FOUR THOUSAND FOUR HUNDRED AND 00/100 DOLLARS

TO THE ORDER OF  
**UNITED STATES NUCLEAR  
REGULATORY COMMISSION  
NUCLEAR REG C DC 20555**

BK	CHECK NO	DATE	VENDOR NO	AMOUNT
26	18531	04/13/82	3301	\$4,400.00

03301 26 0018531 00000440000

⑈0288092⑈ ⑆053101529⑆ 3608 088819⑈

*O. J. Peterson*

