

BOSTON

Edison COMPANY

NUCLEAR OPERATIONS DEPARTMENT
PILGRIM NUCLEAR POWER STATION
Procedure No. TP 82-25

SSW/RBCCW HEAT EXCHANGER TEST PERFORMANCE

List of Effective Pages

82-25-1 Rev. 1
82-25-2 Rev. 1
82-25-3 Rev. 1
82-25-4 Rev. 1

Attachments

82-25A-1 Rev. 1
82-25B-1 Rev. 1
82-25C-1 Rev. 0
82-25C-2 Rev. 1
82-25D-1 Rev. 1
82-25E-1 Rev. 0
82-25F-1 Rev. 0
82-25G-1 Rev. 0
82-25H-1 Rev. 1

Approved

M. Armstrong
ORC Chairman

Date

4-27-82

I. PURPOSE

To monitor performance of the SSW system and RBCCW Heat Exchanger to assure that each operable loop of the SSW system can achieve a cooling capability equivalent to 5000 GPM flow at 65°F inlet SSW temperature through the respective RBCCW Heat Exchanger with the associated TBCCW Heat Exchanger throttled. This test will also be used to develop procedural guidance for backwashing and cleaning RBCCW Heat Exchangers.

II. REFERENCE

Report entitled "Cooling Water System Study, Rev. 1 - January 1982", Stone and Webster Engineering Corp.

III. FREQUENCY

This test will be conducted a minimum of four times during the startup from the 1981-1982 outage, as determined by the on-site safety and performance group. A test frequency will be established thereafter as a function of the cleanliness conditions determined from the test data.

IV. PREREQUISITES

- A. Two and only two SWW pumps running in the loop which is being tested.
- B. Screenwash pump should be off for the loop which is being tested. If this test must be performed and screenwash pumps cannot be secured due to plant conditions the resultant data must be adjusted to account for screenwash flow rate.
- C. RBCCW Heat Exchanger for the loop which is being tested must be backwashed just prior to (within 2 hour if practical) start of test.

V. PRECAUTIONS

Prior to start of test, those bearings which are cooled by TBCCW system and which are in alarm at 100% power condition, should be logged and monitored. During the test, TBCCW flow should be restored to normal if any bearing temperature increases more than about 5°F above its 100% power value and is in alarm. This precaution is not applicable during shutdown.

CAUTION: Remove annubar flow element from system tap after performing test.

VI. PROCEDURE

A. Data Collection

NOTE: This test requires data to be collected in the control room, in the screenhouse, and in the auxiliary bay. The procedure is written such that one or both loops can be tested.

SSW Loop A Test

1. Obtain approval of NWE to conduct the test.
- 1A. Insert annubar flow element into designated test point. (See Data Sheet.)

2. Close M03808 ("C" SSW Pump Discharge Block Valve) if pump C is not one of the two pumps to be used for the A loop test, or close M03813 if pump C is one of the two pumps to be used for the A loop test (in which case M03803 must be open).
3. Regulate SSW flow to 2000 GPM (as indicated by FI6240 on panel C-1) using jog valves M03801 (TBCCW Heat Exchanger "A" Serv. Water Outlet Valve) and M03800 (RBCCW Heat Exchanger "A" Serv. Water Outlet Valve).
4. Collect data as indicated on Attachment A.
5. Repeat steps 3 and 4 to obtain data at approximately 3000 GPM, 4000 GPM and 5000 GPM (plant conditions permitting) by further opening jog valve 3800 and throttling down on jog valve 3801.
6. If, after completing step 5, jog valve 3801 is not fully closed, close valve 3801 fully and record max. flow data on Attachment A.
7. Return M03800 to normal (open).
8. Return M03801 to normal (open).
9. Return M03808 and M03813 to normal.
10. Remove annubar from test point. Cap test point.

SSW Loop B Test

1. Obtain approval of NWE to conduct the test for loop B.
 - 1A. Insert annubar flow element into designated test point. (See Data Sheet.)
2. Close M03813 ("C" SSW Pump Discharge Block Valve) if pump C is not one of the two pumps to be used for the loop B test, or close M03308 if pump C is one of the pumps to be used for the loop B test (in which case M03813 must be open).
3. Regulate SSW flow to 2000 GPM (as indicated by FI6241 on panel C-1) using jog valves M03805 (TBCCW Heat Exchanger "B" Serv. Water Outlet Valve) and M03806 (RBCCW Heat Exchanger "B" Serv. Water Outlet Valve).
4. Collect data as indicated on Attachment B.
5. Repeat steps 3 and 4 to obtain data at approximately 3000 GPM, 4000 GPM, and 5000 GPM (plant conditions permitting) by further opening jog valve 3806 and throttling down on jog valve 3805.
6. If, after completing step 5, jog valve 3805 is not fully closed, close valve 3805 fully and record max. flow data on Attachment B.
7. Return M03806 to normal (open).
8. Return M03805 to normal (open).

9. Return M03808 and M03813 to normal.
10. Remove annubar from test point. Cap test point.
11. Return all data to Shift Technical Advisor for evaluation.

B. Calculations

1. Calculate the Heat Exchanger ΔP , by taking the difference in gage readings and subtracting 2.24 psi for each flow point and plot on Ht Exchanger ΔP vs. Flow Curve (Example - Attachment D).
2. For each flow point calculate $\Delta P/Q^2$ and plot versus SSW inlet temperature (Example - Attachment E).
3. Perform calculations on Attachment C for maximum flow point only and plot on hydraulic grade line curve (Attachment F).
4. For max flow point, calculate $\Delta P/Q^2$ and plot versus inlet temperature (Example - Attachment E). Use this point to compare to acceptance criteria. Points which lie below - left of design curve are $>5000\text{GPM}$ equivalent flow at 65°F SSW inlet temperature.

VII. ACCEPTANCE CRITERIA

<u>Acceptance Level</u>	<u>A Loop</u>	<u>B Loop</u>	<u>Corrective Action</u>
Acceptable: (Max flow >5000 GPM equivalent at 65°F .)	_____	_____	None
Unacceptable: (Max flow <5000 GPM equivalent at 65°F .)	_____	_____	Backwash & Retest. If still unacceptable, declare loop inoperable - remove RBCCW Ht. Exch. and Clean.

Watch Engineer Notified: _____ Date _____
 Performance Engineer or STA

Watch Engineer Acknowledged: _____ Date _____
 Watch Engineer

MR Issued _____

ATTACHMENT A
SSW PERFORMANCE TEST DATA - LOOP A

Date: _____

By: _____

Time: _____

CONTROL ROOM	2000 GPM	3000 GPM	4000 GPM	5000 GPM	MAX FLOW
SSW Loop A Inlet Temp. (Computer Point M077)					
Seawater Level-East (LI 3831A) Ft.					
SSW Flow Loop A (FI 6240) GPM					
SSW Pump Press. Loop A (PI 3828) PSI					
SALT SERVICE AUXILIARY BAY					
Press. Indicator at PX3839A					
Press. Indicator at FE6240					
Press. Indicator at PX3844					
Δ P Indicator RBCCW Ht. Exch. A					
SCREEN HOUSE					
SSW Pump "A" Dis. Press. PI3802					
SSW Pump "B" Dis. Press. PI3807					
SSW Pump "C" Dis. Press. PI3812					
Actual Seawater Level Below Grate at El. 11'0"					
Screenwash Pp 213B Suction Pressure*					
Discharge Pressure*					

**MCC B-15

***MCC B-10 (C.S.R.)

* Record if ON only

ADDITIONAL DATA (SSW BAY)

Annubar FI @ FE 6240 (GPM)					
Annubar FI @ TI 3872 (GPM)					
SSW Pump A AMPS **					
SSW Pump B AMPS **					
SSW Pump C AMPS ***					

ADDITIONAL DATA (SCREENHOUSE)

Annubar FI @ DISCHARGE HDR. (GPM)					
-----------------------------------	--	--	--	--	--

ATTACHMENT B
SSW PERFORMANCE TEST DATA - LOOP "B"

Date: _____

By: _____

Time: _____

	2000 GPM	3000 GPM	4000 GPM	5000 GPM	MAX FLOW
CONTROL ROOM					
SSW Loop B Inlet Temp. (Computer Point M078)					
Seawater Level-West (LI 3831B) Ft.					
SSW Flow Loop B (FI 6241) GPM					
SSW Pump Press. Loop B (PI 3829) PSI					
SALT SERVICE AUXILIARY BAY					
Press. Indicator at PX3839B					
Press. Indicator at FE6241					
Press. Indicator at PX3848					
Δ P Indicator RBCCW Ht. Exch B					
GREEN HOUSE					
SSW Pump "C" Dis. Press. PI3812					
SSW Pump "D" Dis. Press. PI3817					
SSW Pump "E" Dis. Press. PI3822					
Actual Seawater Level Below Grate at El. 11'0"					
Screenwash Pump 213A Suction Pressure*					
Discharge Pressure*					
**MCC B-14					
***MCC B-10 (C.S.R.)					
*Record if ON only					
ADDITIONAL DATA (SSW BAY)					
Annubar FI @ FE 6241 (GPM)					
Annubar FI @ FI 3849 (GPM)					
SSW Pump C AMPS***					
SSW Pump D AMPS**					
SSW Pump E AMPS**					
ADDITIONAL DATA (SCREENHOUSE)					
Annubar FI @ DISCHARGE HDR. (GPM)					

ATTACHMENT C
SSW MAX FLOW CALCULATION
AND HYDRAULIC GRADE LINE

I. MAX FLOW CALCULATION

A. Average tide level _____ ft.

B. Salt Service Water Pumps

<u>Pump</u> (Specify Off)	<u>Discharge</u> <u>Pressure</u>	<u>TDH Fresh</u> <u>Water</u> (C. Below)	<u>Total Flow</u> <u>from pump curve</u> <u>(upper line on</u> <u>Attachment G)</u>
P-208A	_____ psig	_____ Ft	_____ GPM
P-208B	_____ psig	_____ Ft	_____ GPM
P-208C	_____ psig	_____ Ft	_____ GPM
P-208C	_____ psig	A Loop _____ Ft	_____ GPM _____ GPM
P-208D	_____ psig	_____ Ft	_____ GPM
P-208E	_____ psig	_____ Ft	_____ GPM

C. Pump TDH (fresh water)

$$\text{TDH} = (\text{Pump Disc.} \times 2.239) + 30.6 - \text{ave. tide.}] \times 1.03 + 0.8 \text{ ft.}$$

Press.

D. Screenwash Flow Diversion. PERFORM ONLY IF screenwash pump remained in service.

P213B discharge press _____ psi	P213A discharge press _____ psi
P213B suction press _____ psi	P213A suction press _____ psi
P213B ΔP _____ psi	P213 ΔP _____ psi
P213B Head $\Delta P \times 2.307 =$ _____ Ft	P213A Head $\Delta P \times 2.307 =$ _____ Ft
P213B Flow _____ GPM from Attachment H	P213B Flow _____ GPM from Attachment H

Flow Adjustment:

A Loop Max Flow = A Loop Flow from B above _____ - P213B flow _____ = _____ GPM

B Loop Max Flow = B Loop Flow from B above _____ - P213A flow _____ = _____ GPM

II. P/Q² CALCULATION

	<u>A Loop</u>	<u>B Loop</u>
1. Max Flow (Attach C, Sect I)	_____ GPM	_____ GPM
2. ΔP RBCCW Ht Exch (Attach A or B)	_____ psi	_____ psi
3. $\Delta P/Q^2 = \textcircled{2} / \textcircled{1}^2$	_____ $\frac{10^{-6} \text{ psi}}{\text{GPM}^2}$	_____ $\frac{10^{-6} \text{ psi}}{\text{GPM}^2}$
4. SSW Inlet Temp (Attach A or B)	_____ °F	_____ °F


III. HYDRAULIC GRADE LINE POINTS

	<u>A Loop</u>	<u>B Loop</u>
1. Pump TDH (Salt Water)		
TDH _(sw) = TDH/Ave/1.03	_____ Ft	_____ Ft
2. Header Pressure:		
H = (P gage X 2.239) + 29.5 - ave. tide	_____ Ft	_____ Ft
3. Aux Bay Inlet:		
H = (P gage X 2.239) + 14.0 - ave. tide	_____ Ft	_____ Ft
4. Local Pressure at flow element:		
H = (P gage X 2.239) + 8.0 - ave. tide	_____ Ft	_____ Ft
5. Pressure/Vacuum Point:		
H = (\pm vac gage x 2.239) + 16.0 - ave. tide	_____ Ft	_____ Ft
(NOTE! P Vac gage = in Hg X 0.491 This point is often at vacuum)		
6. ΔP Heat Exchanger		
$\Delta H = P \text{ gage} \times 2.239 - 5 \text{ ft.}$	_____ Ft	_____ Ft

SEW COOLING WATER
SYSTEM STUDY
REV 1 JANUARY 1982

MEG.
CLEAN
(FSEMC)
#135

PRESSURE DROP
(PSI)



Hx Pressure Loss vs. Flow For
RBCW Hxs (CLEAN)


SSW Mlet Temp. vs. $\Delta P/Q^2$
 as defined by rows E-209A and C-209B
 (i.e. "A" and "B" sides)
 [note: ΔP does not include elevation
 change across E-209A or E-209B]

from: AT. 8, p. 6
 AT. 12, p. 5


EXAMPLE:

- (1) MX E-209B $\Delta P = 24$ PSI
- (2) SSW FLOW TO E-209B, $Q = 4500$ GPM
- (3) SEA WATER TEMP, $T_{in} = 56^\circ F$

$$\Delta P/Q^2 = 1.19 \times 10^{-6}$$



ATTACHMENT F
 BOSTON EDISON COMPANY PILGRIM STATION UNIT #1
 SALT SERVICE WATER SYSTEM
 HYDRAULIC GRADE LINE



NOTE:
 FRICTION LOSS, h_f BASED ON 50 FPM IN 10
 2500 CFM/FUAF FLOW FOR
 CLEAN STEEL PIPE WITH 1/4"
 RED RUBBER LINER

SCALE
 VERTICAL 1"=20'
 HORIZONTAL 1"=40'

* Piping from Pump Discharge to Inlet
 of RBCCW HX.

ATTACHMENT G


CURVES SHOW APPROXIMATELY THE CHARACTERISTICS WHEN PUMPING CLEAR NON-AERATED WATER. NO GUARANTEE IS MADE EXCEPT FOR THE RATED POINT

NOTE: NO COLUMN LOSSES ARE INCLUDED

BOSTON EDISON CO

P.O. NO. 41967

SO. NO. R 304548-5



IMPELLER CLOSED
 10 3/8 DIA.
 1770 R.P.M.
 12-78-597 J.B.



GOULDS PUMPS
 VERTICAL PUMP DIVISION

INDUSTRY, CALIFORNIA

PERFORMANCE ONE STAGE

12.16 DFLC

DEEP WELL TURBINE PUMP

1770

R.P.M.

7-78-597

82-25G-1 Rev. 0

