	LICENSEE EVENT REPORT
*	CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1	0 H D B 5 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 5 CAT 58
CON'T 0 1 7 8	REPORT L 6 0 5 0 0 0 3 4 6 7 0 5 2 2 8 2 8 0 6 2 1 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) (NP-33-82-30) On May 22, 1982 at 1648 hours, an equipment operator making his rounds
0 3	found MI 348, the discharge valve from Boric Acid Pump 1-1, in the closed position.
0 4	This left the station without a boration flowpath required by Technical Specification
0 5	3.1.2.1 in Mode 5. There was no danger to the health and safety of the public or to
0 6	station personnel. The action statement limits core alterations or positive
0 7	reactivity changes until at least one flowpath is restored. The conditions were met.
0 8	The valve could have been readily opened had there been a need to borate.
7 8	SYSTEM CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCOD
10	ACTION FUTURE TAKEN ACTION ON PLANT METHOD HOURS 22 ATTACHMENT SUBMITTED FORM SUB. PRIME COMP. SUPPLIER MANUFACTURER H 18 X 19 Z 20 Z 21 0 0 0 0 Y 23 N 24 Z 25 Z 9 9 9 26 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27 The cause was personnel error by an operator during a previous operation involving the
1 1	recirculation of Boric Acid Addition Tank 1-2. An existing temporary modification to
1 2	SP1104.03 was incorrectly copied into the procedure indicating MU 348 should be left
1 3	closed. The responsible individual was counseled. The entire operating staff has
7 8	been made aware of the incident. 3 FACILITY STATUS SPOWER OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 H (28) O O O (29) NA A (31) Operator Making Rounds
7 8	9 10 12 13 44 45 46 ACTIVITY CONTENT RELEASE OF RELEASE AMOUNT OF ACTIVITY (35) 9 10 10 12 13 44 45 46 NA N
7 8	NUMBER TYPE DESCRIPTION (39) NA PERSONNEL INJURIES NUMBER DESCRIPTION (41) O O O O (40) NA
7 8	9 11 12 LOSS OF OR DAMAGE TO FACILITY 43 TYPE DESCRIPTION Z 42 NA
2 0	PUBLICITY SSUED DESCRIPTION 45 B206290379 820621 NRC USE ONLY SSUED DESCRIPTION 45 PDR ADDCK 05000346 PDR