

LICENSEE EVENT REPORT

CONTROL BLOCK / / / / / (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

/0/1/ /V/A/N/A/S/2/ (2) /0/0/-/0/0/0/0/0/-/0/0/ (3) /4/1/1/1/1/ (4) / / / (5)
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

/0/1/ REPORT /L/ (6) /0/5/0/0/0/3/3/9/ (7) /0/6/0/1/8/2/ (8) /0/6/2/3/8/2/ (9)
SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

/0/2/ / On June 1, 1982, with the Unit in Mode 3, the Individual Rod Position Indication /
/0/3/ / (IRPI) for rod G-13 in shutdown bank A deviated from the group demand position /
/0/4/ / by greater than 12 steps in that the indicator read 0 and the rod bottom light /
/0/5/ / illuminated. The Reactor Trip Breakers were immediately opened in compliance /
/0/6/ / with T.S. 3.1.3.3, and the health and safety of the general public were not /
/0/7/ / affected. This event is reportable pursuant to T.S. 6.9.1.9.b. /
/0/8/ /

SYSTEM CAUSE CAUSE COMP. VALVE
CODE CODE SUBCODE COMPONENT CODE SUBCODE SUBCODE
/0/9/ /I/E/ (11) /E/ (12) /E/ (13) /I/N/S/T/R/U/ (14) /Y/ (15) /Z/ (16)
LER/RO EVENT YEAR SEQUENTIAL OCCURRENCE REPORT REVISION
(17) REPORT NO. NO.
NUMBER /8/2/ /-/ /0/3/0/ / / /0/3/ /L/ /-/ /0/
ACTION FUTURE EFFECT SHUTDOWN ATTACHMENT NPRD-4 PRIME COMP. COMPONENT
TAKEN ACTION ON PLANT METHOD HOURS SUBMITTED FORM SUB. SUPPLIER MANUFACTURER
/A/ (18) /Z/ (19) /Z/ (20) /Z/ (21) /0/0/0/0/ (22) /N/ (23) /N/ (24) /N/ (25) /W/1/2/0/ (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

/1/0/ / The indicator disagreement was caused by a failed signal conditioning module in /
/1/1/ / the IRPI circuit. A new module was installed and calibrated using an approved /
/1/2/ / calibration procedure and the IRPI channel was returned to service. No further /
/1/3/ / action is required to prevent recurrence. This event has no generic implications. /
/1/4/ /

FACILITY METHOD OF
STATUS %POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32)
/1/5/ /C/ (28) /0/0/0/ (29) / NA / (30) /A/ (31) /Operator Observation/
ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
/1/6/ /Z/ (33) /Z/ (34) / NA / / NA /
PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39)
/1/7/ /0/0/0/ (37) /Z/ (38) / NA /
PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
/1/8/ /0/0/0/ (40) / NA /
LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
/1/9/ /Z/ (42) / NA /
PUBLICITY
ISSUED DESCRIPTION (45) NRC USE ONLY
/2/0/ /N/ (44) / NA / / / / / / / / / / / / /

NAME OF PREPARER W. R. CARTWRIGHT PHONE (703) 894-5151