

TABLE 15.4.1-1 (CONTINUED)

<u>Channel Description</u>	<u>Check</u>	<u>Calibrate</u>	<u>Test</u>	<u>Remarks</u>
10. Rod Position Bank Counters	S (1)**	N.A.	N.A.	1) With analog rod position
11. Steam Generator Level	S **	R	M (1)**	1) Includes test of logic for reactor trip on low-low level and automatic actuation logic for auxiliary feedwater pumps
12. Steam Generator Flow Mismatch	S **	R	M**	
13. Charging Flow	N.A.	R	N.A.	
14. Residual Heat Removal Pump Flow	N.A.	R	N.A.	
15. Boric Acid Tank Level	D	R	N.A.	
16. Refueling Water Storage Tank Level	N.A.	R	N.A.	
17. Volume Control Tank Level	N.A.	R	N.A.	
18. Reactor Containment Pressure	D	R	B/W (1)**	1) Isolation valve signal 15/21
19. Radiation Monitoring System	D	R	M	
20. Boric Acid Control	N.A.	R	N.A.	
21. Containment Sump Level	N.A.	R	N.A.	
22. Turbine Overspeed Trip*	N.A.	R	M (1)**	1) Block trip 15/21
23. Accumulator Level and Pressure	S	R	N.A.	

* Overspeed Trip Mechanism, and Independent Turbine Speed Detection and Valve Trip System.

* Not required during periods of refueling shutdown, but must be performed prior to starting up if it has not been performed during the previous surveillance period.

8207060215 820630
PDR ADOCK 05000266
P PDR