

PILGRIM NUCLEAR POWER STATION UNIT 1 REACTOR VESSEL IRRADIATION SURVEILLANCE PROGRAM

by
E. B. Norris

FINAL REPORT
SwRI Project No. 02-5951

for
Boston Edison Company
800 Boylston Street
Boston, Massachusetts 02199

July 1981



SOUTHWEST RESEARCH INSTITUTE
SAN ANTONIO HOUSTON

8207080133 820702
PDR ADOCK 05000293
Q PDR

SOUTHWEST RESEARCH INSTITUTE
Post Office Drawer 28510, 6220 Culebra Road
San Antonio, Texas 78284

**PILGRIM NUCLEAR POWER STATION UNIT 1
REACTOR VESSEL IRRADIATION
SURVEILLANCE PROGRAM**


by
E. B. Norris

FINAL REPORT
SwRI Project No. 02-5951

for
Boston Edison Company
800 Boylston Street
Boston, Massachusetts 02199

July 1981

Approved:



U. S. Lindholm, Director
Department of Materials Sciences

ABSTRACT

The first vessel material surveillance capsule removed from Pilgrim 1 has been tested and the results analyzed. The results project a maximum shift in the reference nil ductility temperature of 136°F after 32 effective full power years of operation. Also, the vessel beltline material toughness is projected to remain well above 10CFR50, Appendix G, requirements throughout the design lifetime of the unit.

TABLE OF CONTENTS

	<u>Page</u>
LIST OF FIGURES	iii
LIST OF TABLES	iv
I. SUMMARY OF RESULTS AND CONCLUSIONS	1
II. BACKGROUND	3
III. DESCRIPTION OF MATERIAL SURVEILLANCE PROGRAM	7
IV. TESTING OF IRRADIATED SPECIMENS	11
A. Shipment, Opening, and Inspection of Capsule	11
B. Neutron Dosimetry	12
C. Mechanical Property Tests	19
D. Check Analyses for Copper	28
V. ANALYSIS OF RESULTS	31
A. RT _{NDT} Projections	31
B. Shelf Energy Projections	33
VI. REFERENCES	39
APPENDIX A - SURVEILLANCE SPECIMEN AND CAPSULE DRAWINGS [12]	41
APPENDIX B - TENSILE AND CHARPY V-NOTCH PROPERTIES OF UNIRRADIATED PILGRIM 1 SURVEILLANCE MATERIALS [13]	49
APPENDIX C - PHOTOGRAPHS OF IMPACT AND TENSILE CAPSULES	55
APPENDIX D - PHOTOGRAPHS OF TESTED SPECIMENS AND TENSILE TEST RECORDS	61

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Locations of Pilgrim 1 Vessel Surveillance Capsules	8
2	Longitudinal Base Metal Charpy V-Notch Impact Properties, Pilgrim 1	24
3	Weld Metal Charpy V-Notch Impact Properties, Pilgrim 1	25
4	HAZ Material Charpy V-Notch Impact Properties, Pilgrim 1	26
5	Vessel Wall Fluence as a Function of Operation of Pilgrim 1	32
6	Effect of Neutron Fluence on RT _{NDT} Shift, Pilgrim 1	34
7	RT _{NDT} + 60°F as a Function of Plant Operation and Neutron Fluence	36
8	Dependence of C _v Upper Shelf Energy on Neutron Fluence, Pilgrim 1	37

LIST OF TABLES

<u>Table</u>		<u>Page</u>
I	Chemical Analysis of Broken Charpy Specimens from Pilgrim Baseline Program [14]	10
II	Operations Summary - Pilgrim Nuclear Station	14
III	Results of Discrete Ordinates Sn Transport Analysis, Pilgrim 1	16
IV	Summary of Neutron Dosimetry Results, Pilgrim 1, First Surveillance Specimen Capsule	18
V	Hardness Properties of Surveillance Materials, Pilgrim 1	20
VI	Charpy V-Notch Impact Properties of Surveillance Materials, Base Metal - Pilgrim 1	21
VII	Charpy V-Notch Impact Properties of Surveillance Materials, Weld Metal - Pilgrim 1	22
VIII	Charpy V-Notch Impact Properties of Surveillance Materials, HAZ Material - Pilgrim 1	23
IX	Effect of Irradiation on Vessel Surveillance Materials, Pilgrim 1	27
X	Tensile Properties of Surveillance Materials, Pilgrim 1	29
XI	Check Copper Analyses	30
XII	Projected Values of RT _{NDT} for Pilgrim 1	35

I. SUMMARY OF RESULTS AND CONCLUSIONS

The analysis of the vessel material surveillance capsule removed from the Pilgrim 1 pressure vessel during the 1980 refuelling outage led to the following results and conclusions.

(1) Based on a calculated neutron spectral distribution, the capsule received an average fast fluence of 2.3×10^{17} n/cm², E > 1 MeV.

(2) The surveillance weld metal experienced the largest shift in RT_{NDT} (55°F) and is projected to control the system RT_{NDT} to the end of the design lifetime of the pressure vessel.

(3) The shelf energies of the surveillance materials are projected to remain well above the 50 ft-lb minimum required by 10CFR50, Appendix G, throughout the design lifetime of the pressure vessel.

(4) The estimated maximum neutron fluence of 2.6×10^{17} n/cm², E > 1 MeV, incident on the I.D. of the pressure vessel wall accrued in 4.17 effective full power years (EFPY). Therefore, the projected maximum neutron fluence after 32 EFPY is 2.0×10^{18} n/cm², E > 1 MeV.

(5) Using Regulatory Guide 1.99 procedures, the projected maximum values of Δ RT_{NDT} for the Pilgrim 1 vessel core beltline materials at the 1/4T location are 82°F after 12 EFPY and 136°F after 32 EFPY of operation. In addition, a graph showing RT_{NDT} + 60°F as a function of plant operation was prepared.

II. BACKGROUND

The allowable loadings on nuclear pressure vessels are determined by applying the rules in Appendix G, "Fracture Toughness Requirements," of 10CFR50 [1]. In the case of pressure-retaining components made of ferritic materials, the allowable loadings depend on the reference stress intensity factor (K_{IR}) curve indexed to the reference nil ductility temperature (RT_{NDT}) presented in Appendix G, "Protection Against Non-ductile Failure," of Section III of the ASME Code [2]. Further, the materials in the beltline region of the reactor vessel must be monitored for radiation-induced changes in RT_{NDT} per the requirements of Appendix H, "Reactor Vessel Material Surveillance Program Requirements," of 10CFR50.

The RT_{NDT} is defined in paragraph NB-2331 of Section III of the ASME Code as the highest of the following temperatures:

- (1) Drop-weight Nil Ductility Temperature (DW-NDT) per ASTM E 208 [3];
- (2) 60 deg F below the 50 ft-lb Charpy V-notch (C_V) temperature;
- (3) 60 deg F below the 35 mil C_V temperature.

The RT_{NDT} must be established for all materials, including weld metal and heat-affected zone (HAZ) material as well as base plates and forgings, which comprise the reactor coolant pressure boundary.

It is well established that ferritic materials undergo an increase in strength and hardness and a decrease in ductility and toughness when exposed to neutron fluences in excess of 10^{17} neutrons per cm² (E > 1 MeV) [4]. Also, it has been established that tramp elements, particularly

copper and phosphorus, affect the radiation embrittlement response of ferritic materials [5-7]. The relationship between increase in RT_{NDT} and copper content is not defined completely. For example, Regulatory Guide 1.99, originally issued in July 1975, and revised in April 1977 [7], proposes an adjustment to RT_{NDT} proportional to the square root of the neutron fluence. Westinghouse Electric Corporation, in their comments on the 1975 issue of Regulatory Guide 1.99 [8], believed that the proposed relationship overestimates the shift at fluences greater than 1.9×10^{19} and underestimates the shift at fluences less than 1.9×10^{19} . On the other hand, Combustion Engineering, in their comments on the 1975 issue of Regulatory Guide 1.99 [9], suggested that the proposed relationship is overly conservative at fluences below 10^{19} neutrons per cm^2 ($E > 1$ MeV). There is also disagreement concerning the prediction of C_v upper shelf response to exposure to neutron irradiation [7-9]. After reviewing the comments and evaluating additional surveillance program data, the NRC issued a revision to Regulatory Guide 1.99 which raised the upper limit of the transition temperature curve. Although Regulatory Guide 1.99 is currently being revised to reflect a more recent evaluation of neutron embrittlement data by the Metal Properties Council [10], in this report estimates of shifts in RT_{NDT} are based on Regulatory Guide 1.99, Revision 1 [7].

In general, the only ferritic pressure boundary materials in a nuclear plant which are expected to receive a fluence sufficient to affect RT_{NDT} are those materials which are located in the core beltline region of the reactor pressure vessel. Therefore, material surveillance programs include specimens machined from the plate or forging material

and weldments which are located in such a region of high neutron flux density. ASTM E 185 [11] describes the current recommended practice for monitoring and evaluating the radiation-induced changes occurring in the mechanical properties of pressure vessel beltline materials.

General Electric has provided such a surveillance program for the Pilgrim 1 Nuclear Power Station. The encapsulated C_v specimens are located near the I.D. surface of the pressure vessel where the fast neutron flux density is slightly higher than that at the adjacent vessel wall surface. However, because of azimuthal variations in neutron flux density, the capsule fluences lag the maximum vessel fluence in a corresponding exposure period. The capsules also contain several dosimeter materials for experimentally determining the average neutron flux density at each capsule location during the exposure period.

The Pilgrim 1 mechanical property surveillance capsules also include tensile specimens as recommended by ASTM E 185. At the present time, irradiated tensile properties are used to indicate that the materials tested continue to meet the requirements of the appropriate material specification and to judge credibility of the surveillance capsule data.

This report describes the results obtained from testing the contents of the first mechanical property surveillance capsule from the Pilgrim 1. These data are analyzed to estimate the radiation-induced changes in the mechanical properties of the pressure vessel at the time of the refuelling outage as well as predicting the changes expected to occur at selected times in the future operation of the Pilgrim 1 Nuclear Power Station.


III. DESCRIPTION OF MATERIAL SURVEILLANCE PROGRAM

The Pilgrim 1 material surveillance program is described in detail in APED-5490 [12] and NEDO-10115 [13]. Three baskets containing encapsulated Charpy V-notch and tensile specimens were placed in the reactor vessel near the wall prior to startup, see Figure 1. Each capsule basket is located opposite the vertical center of the core.

The surveillance basket removed during the 1980 refuelling outage contained three impact capsules (each holding 12 Charpy V-notch specimens plus an iron, a nickel, and a copper flux wire) and four tensile capsules (each holding two tensile specimens). The capsules do not contain thermal monitors. Drawings of the impact and tensile specimens, the impact and tensile capsules, and the surveillance basket are shown in Appendix A.

The Pilgrim 1 base metal specimens were "made from flat slabs cut parallel to and one-quarter plate thickness from both of the plate surfaces ... with their longest dimension parallel to the plate rolling direction," and the weld metal and heat affected zone (HAZ) specimens were cut from a "test weld representing a vessel welded joint ... fabricated from vessel base material" [12]. The weld and HAZ Charpy V-notch specimens were oriented transverse to the weld direction, and the weld tensile specimens were taken parallel to the weld direction with the gage length made entirely of weld metal. The notches of all Charpy V-notch specimens were perpendicular to the original plate surfaces.

The mechanical and chemical properties of the unirradiated (baseline) surveillance specimens for the Pilgrim 1 vessel were determined



PWT	BASNET CODE				LOCATION	AZIMUTH	REMOVAL PERIOD YEARS
	1	2	3	4			
1	●	○	○	○	WALL	30°	4
2	○	○	○	○	WALL	120°	12
3	○	○	○	○	WALL	300°	32
4	MANUF. SER. NO.				WALL	30°	1

FIGURE 1. LOCATIONS OF PILGRIM I VESSEL SURVEILLANCE CAPSULES

prior to the removal of the first capsule basket [14]. The chemical analyses reported for 20 of the broken unirradiated impact specimens are given in Table I. The tensile and Charpy V-notch properties determined from the unirradiated surveillance specimens are given in Appendix B.

TABLE I

CHEMICAL ANALYSIS OF BROKEN CHARPY SPECIMENS FROM PILGRIM BASELINE PROGRAM [14]

Specimen Identification	Material	Weight Percent of Indicated Elements									
		C	Mn	S	P	Si	Cu	Cr	Ni	Mo	V
Y1D	Base	0.23	1.44	0.013	0.014	0.19	0.13	0.14	0.62	0.58	0.014
Y1L	Base	0.24	1.42	0.013	0.014	0.16	0.14	0.12	0.64	0.60	0.017
Y12	Base	0.24	1.41	0.013	0.013	0.18	0.13	0.13	0.64	0.56	0.017
Y17	Base	0.24	1.41	0.014	0.015	0.16	0.14	0.14	0.65	0.60	0.017
Y2C	Base	0.24	1.26	0.014	0.017	0.15	0.13	0.13	0.64	0.59	0.017
Y2D	Base	0.24	1.27	0.013	0.015	0.19	0.14	0.13	0.62	0.61	0.017
Y22	Base	0.24	1.27	0.014	0.014	0.17	0.13	0.14	0.64	0.60	0.019
Y24	Base	0.24	1.27	0.015	0.013	0.18	0.14	0.14	0.65	0.61	0.019
Y25	Base	0.20	1.29	0.013	0.017	0.19	0.13	0.14	0.62	0.62	0.014
Y32	Base	0.20	1.33	0.014	0.013	0.18	0.13	0.14	0.62	0.59	0.014
Y4A	Weld	0.13	1.18	0.009	0.014	0.23	0.14	0.11	0.81	0.65	0.012
Y45	Weld	0.14	1.16	0.009	0.015	0.22	0.16	0.10	0.81	0.64	0.014
Y5M	Weld	0.13	1.16	0.010	0.014	0.25	0.17	0.10	0.78	0.60	0.014
Y6U	Weld	0.11	1.08	0.008	0.015	0.26	0.17	0.09	0.81	0.61	0.014
Y6Y	Weld	0.09	1.09	0.009	0.014	0.26	0.16	0.10	0.77	0.62	0.014
Y61	Weld	0.13	1.11	0.010	0.015	0.25	0.16	0.09	0.79	0.63	0.013
Y65	Weld	0.11	1.10	0.010	0.015	0.25	0.17	0.09	0.80	0.59	0.014
Y66	Weld	0.13	1.10	0.010	0.014	0.24	0.16	0.11	0.77	0.64	0.014
Y67	Weld	0.13	1.09	0.010	0.013	0.24	0.16	0.11	0.79	0.59	0.014
Y5T	Weld	0.12	1.15	0.010	0.015	0.25	0.16	0.09	0.81	0.61	0.014

IV. TESTING OF IRRADIATED SPECIMENS

The capsule shipment, capsule opening, specimen testing, and reporting of results were carried out in accordance with the Project Plan for Pilgrim 1 Nuclear Power Plant Reactor Vessel Irradiation Surveillance Program. The SwRI Nuclear Projects Operating Procedures called out in this plan include:

- (1) XI-MS-101-0, "Determination of Specific Activity and Analysis of Radiation Detector Specimens"
- (2) XI-MS-103-0, "Conducting Tension Tests on Metallic Specimens"
- (3) XI-MS-104-0, "Charpy Impact Tests on Metallic Specimens"
- (4) XIII-MS-103-0, "Opening Radiation Surveillance Capsules and Handling and Storing Specimens"

Copies of the above documents are on file at SwRI.

A. Shipment, Opening, and Inspection of Capsule

After visually inspecting the basket and observing no damage, SwRI personnel assisted BeCo personnel in opening the basket and loading the impact and tensile capsules into the SwRI radioactive material shipping cask. SwRI personnel then transported the cask to San Antonio.

Upon arrival at SwRI, the individual capsules were inspected. Other than minor surface scuffing and discoloration, no physical damage was observed. Photographs showing the capsule identifications are included in Appendix C.

The capsules were opened and the contents identified and stored in accordance with Procedure XIII-MS-103-0. The end plugs were cut from

each capsule with a band saw set up in the hot cell. The test specimens and dosimeter wires were removed from the shell and placed in indexed receptacles.

Each mechanical test specimen was inspected for identification number, which was checked against the master list in NEDO-10115 [13], and no discrepancies were found. The neutron dosimeter wires were identified and placed in tagged containers.

B. Neutron Dosimetry

The gamma activities of the dosimeters were determined in accordance with Procedure XI-MS-101-0 using an IT-5400 multichannel analyzer and a Ge(Li) coaxial detector system. The calibration of the equipment was accomplished with ^{54}Mn , ^{60}Co , and ^{137}Cs radioactivity standards obtained from the U.S. Department of Commerce National Bureau of Standards. All activities were corrected to the time-of-removal (TOR) at reactor shutdown.

The dosimeter wires were weighed on a Mettler Type H6T balance. Infinitely dilute saturated activities (A_{SAT}) were calculated for each of the dosimeters because A_{SAT} is directly related to the product of the energy-dependent microscopic activation cross section and the neutron flux density. The relationship between A_{TOR} and A_{SAT} is given by:

$$\frac{A_{\text{TOR}}}{A_{\text{SAT}}} = \sum_{m=1}^{m=n} (1 - e^{-\lambda T_m}) (e^{-\lambda t_m})$$

where: λ = decay constant for the activation product, day^{-1} ;
 T_m = equivalent operating days at 1998 MwTh for operating period m ; and
 t_m = decay time after operating period m , days.

The Pilgrim 1 operating history up to the 1980 refuelling outage, which was used in the calculation of A_{TOR} , is presented in Table II.

The primary result desired from the dosimeter analysis is the total fast neutron fluence (> 1 MeV) which the surveillance specimens received. The average flux density at full power is given by:

$$\phi = \frac{A_{SAT}}{N_0 \bar{\sigma}}$$

where: ϕ = energy-dependent neutron flux density, n/cm²-sec;
 A_{SAT} = saturated activity, dps/mg target element;
 $\bar{\sigma}$ = spectrum-averaged activation cross section, cm²; and
 N_0 = number of target atoms per mg.

The total neutron fluence is then equal to the product of the average neutron flux density and the equivalent reactor operating time at full power.

A discrete ordinates Sn transport analysis for the Pilgrim 1 reactor vessel was performed to determine the radial and azimuthal dependence of the fast neutron ($E > 1.0$ MeV) flux density and energy spectrum within the reactor vessel and surveillance capsules. These results were used to calculate the spectrum-averaged cross sections for the threshold detectors and the lead factors for use in relating neutron exposure of the pressure vessel to that of the surveillance capsules. The pertinent factors obtained from this transport analysis are summarized in Table III.

The calculated cross section for the $^{54}\text{Fe}(n,p)^{54}\text{Mn}$ reaction is considerably higher than the 130 mb value assumed at the time of the vessel

TABLE II

OPERATIONS SUMMARY - PILGRIM NUCLEAR STATION

Operating Period, m	Dates		Shutdown Days	Operating Days	Reactor Power MWDth	Equivalent ^(a) Operating Days, T _m	Decay Time in Days, t _m
	Start	Stop					
1	07/16/72	07/24/72	-	9	1,353	0.68	2716
	07/25/72	09/17/72	55	-	-	-	-
2	09/18/72	10/02/72	-	15	9,311	4.66	2646
	10/03/72	10/10/72	8	-	-	-	-
3	10/11/72	10/17/72	-	7	4,993	2.50	2631
	10/18/72	10/18/72	1	-	-	-	-
4	10/19/72	10/26/72	-	8	8,971	4.49	2622
	10/27/72	10/28/72	2	-	-	-	-
5	10/29/72	11/29/72	-	32	48,945	24.50	2588
	11/30/72	12/6/72	7	-	-	-	-
6	12/07/72	12/29/72	-	23	37,018	18.53	2558
	12/30/72	01/01/73	3	-	-	-	-
7	01/02/73	03/06/73	-	64	116,620	58.37	2491
	03/07/73	03/07/73	1	-	-	-	-
8	03/08/73	03/30/73	-	23	39,660	19.85	2467
	03/31/73	04/05/73	6	-	-	-	-
9	04/06/73	05/04/73	-	29	51,915	25.98	2432
	05/05/73	05/06/73	2	-	-	-	-
10	05/07/73	07/16/73	-	71	130,211	65.17	2359
	07/17/73	07/29/73	13	-	-	-	-
11	07/30/73	09/01/73	-	34	57,918	28.99	2312
	09/02/73	09/04/73	3	-	-	-	-
12	09/05/73	09/08/73	-	4	3,298	1.65	2305
	09/09/73	09/10/73	2	-	-	-	-
13	09/11/73	11/07/73	-	58	79,361	39.72	2245
	11/08/73	11/11/73	4	-	-	-	-
14	11/12/73	11/20/73	-	9	8,001	4.00	2232
	11/21/73	11/21/73	1	-	-	-	-
15	11/22/73	12/07/73	-	16	15,788	7.90	2215
	12/08/73	12/08/73	1	-	-	-	-
16	12/09/73	12/28/73	-	20	19,699	9.86	2194
	12/29/73	07/26/74	210	-	-	-	-
17	07/27/74	09/17/74	-	53	83,968	42.03	1931
	09/18/74	09/21/74	4	-	-	-	-
18	09/22/74	10/24/74	-	33	61,866	30.96	1894
	10/25/74	10/26/74	2	-	-	-	-
19	10/27/74	11/02/74	-	7	10,176	5.09	1885
	11/03/74	11/03/74	1	-	-	-	-
20	11/04/74	12/12/74	-	39	68,252	34.16	1845
	12/13/74	12/16/74	4	-	-	-	-
21	12/17/74	01/10/75	-	25	42,739	21.39	1816
	01/11/75	01/23/75	13	-	-	-	-
22	01/24/75	01/30/75	-	7	5,596	2.80	1796
	01/31/75	02/11/75	12	-	-	-	-
23	02/12/75	04/15/75	-	63	90,383	45.24	1721
	04/16/75	04/20/75	5	-	-	-	-
24	04/21/75	04/22/75	-	2	1,687	0.84	1714
	04/23/75	04/28/75	6	-	-	-	-
25	04/29/75	05/21/75	-	23	28,558	14.29	1685
	05/22/75	05/24/75	3	-	-	-	-
26	05/25/75	06/30/75	-	37	48,593	24.32	1645
	07/01/75	07/05/75	5	-	-	-	-
27	07/06/75	07/20/75	-	15	15,364	7.94	1625
	07/21/75	07/21/75	1	-	-	-	-

TABLE II (CONT.)

Operating Period, m	Dates		Shutdown Days	Operating Days	Reactor Power MWDch	Equivalent ^(a) Operating Days, T _m	Decay Time in Days, C _m
	Start	Stop					
28	07/22/75	08/08/75	-	18	22,178	11.10	1606
	08/09/75	08/09/75	1	-	-	-	-
29	08/10/75	08/18/75	-	9	10,347	5.43	1596
	08/19/75	08/19/75	1	-	-	-	-
30	08/20/75	09/10/75	-	22	25,332	12.68	1573
	09/11/75	09/11/75	1	-	-	-	-
31	09/12/75	09/13/75	-	2	230	.12	1570
	09/14/75	10/27/75	44	-	-	-	-
32	10/28/75	01/05/76	-	70	75,815	37.95	1456
	01/06/76	01/18/76	13	-	-	-	-
33	01/19/76	01/27/76	-	9	7,452	3.73	1434
	01/28/76	05/31/76	125	-	-	-	-
34	06/01/76	01/28/77	-	242	350,129	175.24	1067
	01/29/77	02/02/77	5	-	-	-	-
35	02/03/77	03/22/77	-	48	80,232	40.16	1014
	03/23/77	03/23/77	1	-	-	-	-
36	03/24/77	05/01/77	-	39	61,553	30.81	974
	05/02/77	05/02/77	1	-	-	-	-
37	05/03/77	05/10/77	-	8	7,189	3.60	965
	05/11/77	05/11/77	1	-	-	-	-
38	05/12/77	08/07/77	-	87	138,608	69.37	877
	08/07/77	11/16/77	102	-	-	-	-
39	11/17/77	11/17/77	-	1	147	0.07	774
	11/18/77	11/21/77	4	-	-	-	-
40	11/22/77	11/22/77	-	1	9	0.01	769
	11/23/77	12/11/77	19	-	-	-	-
41	12/12/77	01/10/78	-	30	18,981	9.50	720
	01/11/78	02/04/78	25	-	-	-	-
42	02/05/78	02/06/78	-	2	252	0.13	693
	02/07/78	02/07/78	1	-	-	-	-
43	02/08/78	04/07/78	-	59	103,787	51.94	633
	04/08/78	04/10/78	3	-	-	-	-
44	04/11/78	04/28/78	-	18	27,400	13.71	612
	04/29/78	05/05/78	7	-	-	-	-
45	05/06/78	10/09/78	-	157	291,537	145.91	448
	10/10/78	10/27/78	18	-	-	-	-
46	10/28/78	03/25/79	-	149	286,368	143.33	281
	03/26/79	03/29/79	4	-	-	-	-
47	03/30/79	05/11/79	-	43	84,057	42.07	234
	05/12/79	05/29/79	18	-	-	-	-
48	05/30/79	06/13/79	-	17	31,975	16.00	199
	06/16/79	06/16/79	1	-	-	-	-
49	06/17/79	07/11/79	-	25	42,471	21.26	173
	07/12/79	07/16/79	5	-	-	-	-
50	07/17/79	07/27/79	-	11	14,879	7.45	157
	07/28/79	07/29/79	2	-	-	-	-
51	07/30/79	12/31/79	-	155	273,292	136.78	0
Totals					3,045,464	1524.26 ^(b)	

(a) At 1998 MW_e

(b) 1524.25 = 4.17 effective full power years

TABLE III
RESULTS OF DISCRETE ORDINATES Sn TRANSPORT ANALYSIS
PILGRIM 1

A. Calculated Reaction Cross-Sections for Analysis of Fast Neutron Monitors (E > 1.0 MeV)

<u>Reaction</u>	<u>$\bar{\sigma}$ (barns)</u>
$^{54}\text{Fe}(n,p)^{54}\text{Mn}$	0.194
$^{58}\text{Ni}(n,p)^{58}\text{Co}$	0.237
$^{63}\text{Cu}(n,\alpha)^{60}\text{Co}$	0.00327

B. Calculated Capsule Lead Factors

<u>Position(a)</u>	<u>Location within Vessel Wall</u>	<u>Lead Factor(b)</u>
30°	I.D. Surface	0.97
30°	1/4T	1.3
30°	3/4T	3.8

(a) Azimuthal position from reference

(b) $\frac{\text{Capsule neutron flux density, } E > 1.0 \text{ MeV}}{\text{Maximum neutron flux density at vessel I.D., } E > 1.0 \text{ MeV}}$

wall dosimeter analysis [15]. It is believed that the values given in Table III are valid because SwRI-computed reaction cross sections for Browns Ferry Unit 3 [16] agree well with those measured by General Electric during the same core cycle [17].

The dosimetry results are presented in Table IV. A summary of the capsule and vessel I.D. fluxes calculated for full-power operation is as follows:

Dosimeter Type	Measured Capsule Flux $\text{cm}^{-2}\cdot\text{sec}^{-1}$, $E > 1 \text{ MeV}$	Lead Factor	Peak Vessel Flux at I.D. $\text{cm}^{-2}\cdot\text{sec}^{-1}$, $E > 1 \text{ MeV}$
Copper	1.93×10^9	0.87	2.2×10^9
Iron	1.55×10^9 *	0.87	1.8×10^9
Nickel	1.73×10^9	0.87	2.0×10^9

* If a fission-spectrum energy distribution is assumed at the capsule location, the cross section for the $^{54}\text{Fe}(n,p)^{54}\text{Mn}$ reaction ($E > 1.0 \text{ MeV}$) would be 98.26 mb [4], and the resulting value for fast flux at the capsule location would be $3.1 \times 10^9 \text{ cm}^{-2}\cdot\text{sec}^{-1}$. This value is reported for reference only and has not been used in the analysis of results.

The discrepancies in the peak vessel flux values determined from the several dosimeter materials are attributed primarily to the uncertainties in the calculated spectra and in the reaction cross sections. Other neutronic factors contributing to the estimated $\pm 16.5\%$ uncertainty (1σ) in a calculated flux value are the determination of disintegration rates and the calculation of reaction rates (A_{SAT}/N_0).

Averaging the results obtained from all neutron dosimeters, the neutron flux at the surveillance capsule location during fuel cycle 1 is

TABLE IV

SUMMARY OF NEUTRON DOSIMETRY RESULTS
 PILGRIM 1, FIRST SURVEILLANCE SPECIMEN CAPSULE

Dosimeter I.D.		Activation Reaction	Weight (mg)	A_{TOR} (dps/mg)	A_{SAT} (dps/mg)	Flux, $E > 1 \text{ MeV}^{(a)}$ ($\text{cm}^{-2} \cdot \text{sec}^{-1}$)
Material	Capsule					
Fe	G1	$^{54}\text{Fe}(n,p)^{54}\text{Mn}$	156.3	1.569×10^2	1.84×10^2	1.52×10^9
	G2		151.8	1.567×10^2	1.84×10^2	1.52×10^9
	G3		168.5	1.674×10^2	1.97×10^2	1.62×10^9
	Average = 1.55×10^9					
Cu	G1	$^{63}\text{Cu}(n,\alpha)^{60}\text{Co}$	232.1	1.461×10^1	3.94×10^1	1.84×10^9
	G2		252.9	1.588×10^1	4.28×10^1	2.00×10^9
	G3		246.7	1.547×10^1	4.17×10^1	1.95×10^9
	Average = 1.93×10^9					
Ni	G1	$^{58}\text{Ni}(n,p)^{58}\text{Co}$	328.6	2.443×10^3	2.71×10^3	1.63×10^9
	G2		376.0	2.627×10^3	2.91×10^3	1.76×10^9
	G3		384.7	2.703×10^3	3.00×10^3	1.81×10^9
	Average = 1.73×10^9					

(a) Calculated flux values subject to a $\pm 16.5\%$ uncertainty (1σ).

calculated to be $1.74 \times 10^9 \text{ cm}^{-2} \cdot \text{sec}^{-1}$, $E > 1 \text{ MeV}$. The peak full power neutron flux for the pressure vessel I.D. is given by:

$$1.74 \times 10^9 \div 0.87 = 2.0 \times 10^9 .$$

Since Pilgrim 1 operated for 4.17 effective full power years (EFPY) up to the October 1979 refuelling, the calculated capsule and vessel fluences to that time are as follows:

- Surveillance Capsule - $2.3 \times 10^{17} \text{ n/cm}^2$
- Pressure Vessel I.D. Surface - $2.6 \times 10^{17} \text{ n/cm}^2$
- Pressure Vessel 1/4T - $1.8 \times 10^{17} \text{ n/cm}^2$
- Pressure Vessel 3/4T - $6.0 \times 10^{16} \text{ n/cm}^2$

C. Mechanical Property Tests

Hardness tests were run in accordance with ASTM Method E 18 [18] on one untested Charpy V-notch specimen selected from each material group. The results are given in Table V.

The irradiated Charpy V-notch specimens were tested on a SATEC impact machine in accordance with Procedure XI-MS-104-0. The test temperatures were selected to develop the ductile-brittle transition and upper shelf regions. The Charpy V-notch impact data obtained on the irradiated materials are presented in Tables VI through VIII. The Charpy V-notch transition curves for the plate material, the weld metal, and the HAZ material are compared to the unirradiated data in Figures 2 through 4. The radiation-induced shift in transition temperatures are indicated at the 50 ft-lb, 30 ft-lb, and 35 mil lateral expansion levels. A summary of the shifts in RT_{NDT} and C_v upper shelf energies for each material are presented in Table IX.

TABLE V
HARDNESS PROPERTIES OF SURVEILLANCE MATERIALS
PILGRIM 1

<u>Test Material</u>	<u>Charpy Specimen No.</u>	<u>Hardness</u>	
		<u>HRA</u>	<u>HRB (a)</u>
Base Metal	Y14	55.0	
		55.2	
		54.8	
		54.8	
		<u>55.7</u>	
		Avg.	55.1
Weld Metal	Y41	54.2	
		54.2	
		54.2	
		53.9	
		<u>54.1</u>	
		Avg.	54.1
HAZ Material	Y73	56.8	
		57.2	
		55.8	
		55.9	
		<u>56.2</u>	
		Avg.	56.4

(a) Converted from HRA numbers per ASTM E 140-77.

TABLE VI

CHARPY V-NOTCH IMPACT PROPERTIES OF SURVEILLANCE MATERIALS
BASE METAL - PILGRIM 1

<u>Specimen No.</u>	<u>Temp. (°F)</u>	<u>Energy (ft-lb)</u>	<u>Lateral Exp. (mils)</u>	<u>Fracture App. (% shear)</u>
Y3P	-50	6.0	6	nil
Y2E	0	14.5	15	5
Y2B	25	17.0	18	10
Y3K	40	30.0	29	10
Y1U	50	41.0	37	20
Y35	60	55.0	47	20
Y2J	60	72.5	59	20
Y14	75	58.0	49	25
Y1P	110	90.0	68	60
Y15	150	112.5	82	100
Y16	210	118.0	89	100
Y1C	300	122.0	96	100

TABLE VII

CHARPY V-NOTCH IMPACT PROPERTIES OF SURVEILLANCE MATERIALS
WELD METAL - PILGRIM 1

<u>Specimen No.</u>	<u>Temp. (°F)</u>	<u>Energy (ft-lb)</u>	<u>Lateral Exp. (mils)</u>	<u>Fracture App. (% shear)</u>
Y6J	-100	21.0	20	nil
Y6C	-75	40.0	33	5
Y6B	-50	52.0	45	10
Y5P	-25	37.5	42	10
Y5L	0	41.0	40	10
Y5A	25	57.0	53	20
Y53	50	61.0	59	30
Y4I	75	69.5	64	60
Y4T	110	86.5	80	90
Y42	150	89.5	85	100
Y4E	210	93.0	88	100
Y4J	300	93.5	89	100

TABLE VIII

CHARPY V-NOTCH IMPACT PROPERTIES OF SURVEILLANCE MATERIALS
HAZ MATERIAL - PILGRIM 1

<u>Specimen No.</u>	<u>Temp. (°F)</u>	<u>Energy (ft-lb)</u>	<u>Lateral Exp. (mils)</u>	<u>Fracture App. (% shear)</u>
YBY	-100	9.0	8	nil
YBC	-100	40.0	28	5
YBM	-75	48.5	44	10
YBA	-75	74.5	55	10
YBS	-50	83.5	55	20
YB3	-25	100.0	68	50
YAD	0	70.0	51	20
YAI	25	105.0	70	60
Y73	75	129.5	80	100
Y75	150	91.0	67	100
Y7D	210	110.5	89	100
Y7Y	300	90.5	85	100




FIGURE 2. LONGITUDINAL BASE METAL CHARPY V-NOTCH IMPACT PROPERTIES, PILGRIM 1




FIGURE 3. WELD METAL CHARPY V-NOTCH IMPACT PROPERTIES, PILGRIM 1




FIGURE 4. HAZ MATERIAL CHARPY V-NOTCH IMPACT PROPERTIES, PILGRIM 1

TABLE IX

EFFECT OF IRRADIATION ON VESSEL SURVEILLANCE MATERIALS
PILGRIM I

<u>Criterion⁽¹⁾</u>	<u>Base Metal⁽²⁾</u>	<u>Weld Metal</u>	<u>HAZ Material</u>
Transition Temperature Shift			
@ 50 ft-lb	25°F	55°F	nil
@ 30 ft-lb	25°F	55°F	nil
@ 35 mil	25°F	55°F	nil
ΔRT_{NDT}	25°F	55°F	nil
C_V Upper Shelf Drop	13 ft-lb (10%)	21 ft-lb (18%)	11 ft-lb (9%)

(1) Refer to Figures 2-4.

(2) Longitudinal orientation:

Use 77 ft-lb shift to estimate 50 ft-lb shift for transverse orientation.

Use 46 ft-lb shift to estimate 30 ft-lb shift for transverse orientation.

Use 54 mil shift to estimate 35 mil shift for transverse orientation.

Tensile tests were carried out on the irradiated materials in accordance with Procedure XI-MS-103-0 using a 50-kip capacity tester equipped with a strain gage extensometer, load cell, and autographic recording equipment. Tensile tests were run at room temperature, 150°F, and 550°F. The results are presented in Table X. The load-strain records and photographs of the tested specimens are included in Appendix D.

D. Check Analyses for Copper

One tested Charpy specimen from each material group was analyzed for copper content with an X-ray fluorescent technique per ASTM E 322-67 [19]. The results, summarized in Table XI, agree well with the analyses performed on the unirradiated specimens [14].

TABLE X
 TENSILE PROPERTIES OF SURVEILLANCE MATERIALS
 PILGRIM 1

Test Material	Spec. No.	Temp. (°F)	0.2% YS (ksi)	UTS (ksi)	Fracture Load (lb)	Fracture Stress (ksi)	Uniform Elongation (%)	Total Elongation (%)	R.A. (%)
Base Metal	YCM	72	71.2	93.0	2770	194	15.5	25.4	70.9
	YCA	150	67.9	89.4	2704	189	16.9	26.0	71.1
	YCI	550	61.5	85.2	2789	181	13.1	22.3	68.6
Weld Metal	YD7	150	69.7	87.7	2670	164	15.9	25.8	66.8
	YD5	550	60.3	81.1	2780	162	15.1	23.0	65.0
HAZ Material	YEB	72	71.7	89.8	2770	185	13.9	21.5	69.5
	YEL	72	70.1	88.0	2608	174	14.3	23.8	69.5
	YEK	550	55.9	79.5	2678	160	12.5	20.4	66.0

TABLE XI
CHECK COPPER ANALYSES

<u>Material</u>	<u>Specimen No.</u>	<u>Copper (%)</u>	<u>Note</u>
Base Metal	Y3P	0.14	(a)
Weld Metal	Y6J	0.15	(b)
HAZ Material	YBY	0.17	(c)

-
- (a) Average copper content of ten unirradiated base metal specimens = $0.13 \pm 0.01\%$ [14].
- (b) Average copper content of ten unirradiated weld metal specimens = $0.16 \pm 0.01\%$ [14].
- (c) No data reported for HAZ specimens [14].

V. ANALYSIS OF RESULTS

The analysis of data obtained from surveillance program specimens has the following goals.

(1) Estimate the period of time over which the properties of the vessel beltline materials will meet the fracture toughness requirements of Appendix G of 10CFR50. This requires a projection of the measured reduction in C_v upper shelf energy to the vessel wall using knowledge of the energy and spatial distribution of the neutron flux and the dependence of C_v upper shelf energy on the neutron fluence.

(2) Determine the adjustment of the pressure vessel RT_{NDT} as a function of plant operations. This requires a projection of the measured shift in RT_{NDT} to the vessel wall using knowledge of the dependence of the shift in RT_{NDT} on the neutron fluence and the energy and spatial distribution of the neutron flux.

The energy and spatial distribution of the neutron flux for Pilgrim 1 was calculated with a discrete ordinates transport code. This analysis predicted that the lead factor (ratio of fast flux at the capsule basket location to the maximum pressure vessel flux) was 0.89. This analysis also predicted that the fast flux at the 1/4T and 3/4T positions in the 5.65-in. pressure vessel wall would be 67% and 23%, respectively, of that at the vessel I.D. The vessel wall fluence as a function of plant operation is shown in Figure 5.

A. RT_{NDT} Projections

A method for estimating the increase in RT_{NDT} as a function of neutron fluence and chemistry is given in Regulatory Guide 1.99, Revision 1 [7].




FIGURE 5. VESSEL WALL FLUENCE AS A FUNCTION OF OPERATION OF PILGRIM 1

However, the Guide also permits the extrapolation of credible surveillance data by constructing response curves through the data points and parallel to the Guide trend curves, as shown in Figure 6.

The Pilgrim 1 surveillance weld metal is more sensitive than the other core beltline surveillance materials to irradiation embrittlement. Also, since the RT_{NDT} of the unirradiated weld metal was higher than that of the unirradiated base material [14], the weld metal will control the adjusted value of RT_{NDT} throughout the 40-year design life of the plant. A summary of the projected values of RT_{NDT} for 12 and 32 EFPY is presented in Table XII.

The peak value of $RT_{NDT} + 60^{\circ}F$ as a function of neutron fluence and plant operation (in terms of EFPY) is shown in Figure 7. The horizontal line at $RT_{NDT} + 60^{\circ}F = 100^{\circ}F$ is based on the initial system RT_{NDT} [20]. After 3 EFPY, the value of $RT_{NDT} + 60^{\circ}F$ is controlled by the beltline weld metal.

B. Shelf Energy Projections

Regulatory Guide 1.99 also gives a method for estimating the reduction in C_v upper shelf energy as a function of neutron fluence [7]. The Pilgrim 1 surveillance results are compared to applicable Regulatory Guide 1.99 trend curves in Figure 8. The weld metal is more sensitive to neutron embrittlement than the base plate and HAZ materials, and also is more sensitive than predicted by the Regulatory Guide 1.99 trend curve for 0.15% Cu weld metal.

Using the extrapolated curve through the weld metal surveillance data point, a shelf energy reduction of approximately 30% is predicted




FIGURE 6. EFFECT OF NEUTRON FLUENCE ON RTNDT SHIFT, PILGRIM I

TABLE XII

PROJECTED VALUES OF RT_{NDT} FOR PILGRIM 1Material Property Basis

Weld Metal Copper = 0.16%

Initial RT_{NDT} = 0°F

<u>EFP%</u>	<u>Location</u>	<u>Fluence</u>	<u>ΔRT_{NDT}</u>	<u>Adj. RT_{NDT}</u>
12	I.D.	7.5×10^{17}	100	100
	1/4T	5.1×10^{17}	82	82
	3/4T	1.7×10^{17}	47	47
32	I.D.	2.0×10^{18}	162	162
	1/4T	1.4×10^{18}	136	136
	3/4T	4.6×10^{17}	78	78

Neutron Fluence at 1/4T, n/cm², E > 1 MeV




FIGURE 7. RT_{NDT} + 60°F AS A FUNCTION OF PLANT OPERATION AND NEUTRON FLUENCE




FIGURE 8. DEPENDENCE OF C_V UPPER SHELF ENERGY ON NEUTRON FLUENCE, PILGRIM 1

at the 32 EFPY vessel fluence of 2.0×10^{18} n/cm², E > 1 MeV. Since the initial value of weld metal toughness was 113 ft-lb, the projected weld metal shelf energy after 32 EFPY of operation is 79 ft-lb, well above the 50 ft-lb limit required by 10CFR50, Appendix 5 [1].


VI. REFERENCES

1. Title 10, Code of Federal Regulations, Part 50, "Licensing of Production and Utilization Facilities."
2. ASME Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," 1974 Edition.
3. ASTM E 208-69, "Standard Method for Conducting Drop-Weight Test to Determine Nil-Ductility Transition Temperature of Ferritic Steels," 1975 Annual Book of ASTM Standards.
4. Steele, L. E., and Serpan, C. Z., Jr., "Analysis of Reactor Vessel Radiation Effects Surveillance Programs," ASTM STP 481, December 1970.
5. Steele, L. E., "Neutron Irradiation Embrittlement of Reactor Pressure Vessel Steels," International Atomic Energy Agency, Technical Reports Series No. 163, 1975.
6. ASME Boiler and Pressure Vessel Code, Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," 1974 Edition.
7. Regulatory Guide 1.99, Revision 1, Office of Standards Development, U.S. Nuclear Regulatory Commission, April 1977.
8. Comments on Regulatory Guide 1.99, Westinghouse Electric Corporation, obtained from NRC Public Document Room, Washington, D.C.
9. Position on Regulatory Guide 1.99, Combustion Engineering Power Systems, obtained from NRC Public Document Room, Washington, D.C.
10. "Prediction of Shift in the Ductile-Brittle Transition Temperature of LWR Pressure Vessel Materials," prepared by the Metal Properties Council, Subcommittee 6 on Nuclear Materials, July 1, 1980.
11. ASTM E 185-73, "Standard Recommended Practice for Surveillance Tests for Nuclear Reactor Vessels," 1975 Annual Book of ASTM Standards.
12. Higgins, J. P., "Modified Surveillance Program for General Electric BWR Pressure Vessel Steels," AEPD-5490, April 1967.
13. Higgins, J. P., and Brandt, F. A., "Mechanical Property Surveillance of General Electric BWR Vessels," July 1969.

14. Perrin, J. S., et al, "Evaluation of Mechanical Properties of Unirradiated Specimens from Pilgrim Unit No. 1," October 25, 1979.
15. Norris, E. B., "Vessel Material Surveillance Program for Pilgrim Nuclear Power Station," Topical Report No. 1, Vessel Wall Dosimeter Analysis, SwRI Project 02-3812-001, August 15, 1974.
16. Norris, E. B., "Analysis of Vessel Wall Neutron Dosimeter from Browns Ferry Unit 3 Pressure Vessel," Final Report, SwRI Project 02-4884-003, September 1979.
17. Martin, G. C., "Browns Ferry Unit 3 In-Vessel Neutron Spectral Analysis," NEDO-24793, August 1980.
18. ASTM E 18-81, "Standard Methods of Test for Rockwell Hardness and Rockwell Superficial Hardness of Metallic Materials," 1981 Annual Book of ASTM Standards.
19. ASTM E 322-67, "Standard Method for Spectrochemical Analysis of Low-Alloy Steels and Cast Irons Using an X-ray Fluorescence Spectrometer," 1974 Annual Book of ASTM Standards.
20. Final Safety Analysis Report, Pilgrim Nuclear Power Station, p. 4.2-9, Revision June 11, 1970.

APPENDIX A

SURVEILLANCE SPECIMEN AND CAPSULE DRAWINGS [12]



UNLESS OTHERWISE SPECIFIED USE THE FOLLOWING		DATE	
APPLIED PRACTICES	SURFACES	117C3913	
145A5431	✓	IMPACT SPECIMEN CAPSULE	
		PART MADE FOR SURVEILLANCE PROGRAM	
		PL 133450	

FCF-01-05-117C3911
66-610-117C4370

- NOTES:
1. THE HOLE PATTERN IS A BINARY NUMBER MADE BY ADDING THE VALUES OF THE HOLES AS INDICATED BELOW:

1	2	3	5	10
•	•	•	•	•
•	•	•	•	•


 - CODING REFERENCE HOLES
 2. EXHAUST AIR TO REDUCE CARBULE INTERNAL PRESSURE TO ONE (1) TORR. BACKFILL WITH WELDING GRADE HELIUM AT ATMOSPHERIC PRESSURE AND SEAL WELD HOLES.
 3. MASS SPECTROMETER LEAK TEST COMPLETED ASSEMBLY. ALLOWABLE LEAKAGE 1x10⁻⁶ CC/MIN.

GROUP	HOLE PATTERN
1	• • • • •
2	• • • • •
3	• • • • •
4	• • • • •
5	• • • • •
6	• • • • •
7	• • • • •
8	• • • • •
9	• • • • •
10	• • • • •

117C3913

REVISIONS	DATE	BY	CHK'D	APPROVED
1	11/11/66	WES	WES	WES
2	11/15/66	WES	WES	WES

APPROVED: WES
SAN JOSE
117C3913
REV 2
10 5 66





MC-10.2

117C407A
CAPSULE BASKET
REF: 017003-117C407S

NOTES:
1 THE HOLE PATTERN IS A BINARY NUMBER MADE BY ADDING THE VALUES OF THE HOLES AS INDICATED BELOW:
COOLING REFERENCE HOLES
2 THE HOLE PATTERN IS A BINARY NUMBER MADE BY ADDING THE VALUES OF THE HOLES AS INDICATED BELOW:
COOLING REFERENCE HOLES
3 WELDING ARE 208A4220
4 ARRANGEMENT OF CHARLES WITHIN BASKET IS OPTIONAL
5 CLEAN WITH ACETONE WASH
6 CLEAN ARE 200PP107
7 INSTALL PLUGS FIRMLY AGAINST BEACH OF CAPSULES AND BRACERS TO TAKE UP ALL END PLAY OF PARTS AND WELD.

HOLE PATTERN	FIG.
1 0 0 0 0 0 0 0 0 0 0 0	1
2 0 0 0 0 0 0 0 0 0 0 0	2
3 0 0 0 0 0 0 0 0 0 0 0	3

METAL STRAPS WITH HIGH CHARACTERISTICS (SEE 5.08) / TYPICAL SPRING CLIP NO. 17.0 DIA. FOR HOLE PATTERN 17.0 DIA. HOLE AT POSITION SHOWN
REACTOR CODE NO. COOLING REFERENCE HOLES (SEE NOTE 1)



THIS IS A
REDUCED PRINT

DEC 5 1968

APPENDIX B

TENSILE AND CHARPY V-NOTCH PROPERTIES OF
UNIRRADIATED PILGRIM 1 SURVEILLANCE MATERIALS [13]

TABLE 2. CHARPY V-NOTCH IMPACT RESULTS FOR PILGRIM BASE METAL

Specimen Identification	Test Temperature, F	Impact Energy, ft-lb	Lateral Expansion, mils	Fracture Appearance, Percent Shear
Y2/C	-100	3.1	2.4	1
Y1/L	-50	8.3	9.0	5
Y2/4	0	24.0	23.2	25
Y3/2	25	52.0	43.2	30
Y2/0	30	44.0	37.4	25
Y1/2	50	74.9	54.2	45
Y3/Y	50	71.3	61.2	40
Y2/1	50	56.4	50.0	45
Y1/0	80	83.8	67.0	60
Y2/2	115	110.0	85.2	85
Y2/5	150	131.9	75.0	100
Y3/M	250	130.3	92.0	100
Y1/7	300	130.2	84.2	100

TABLE 3. CHARPY V-NOTCH IMPACT RESULTS FOR PILGRIM WELD METAL

Specimen Identification	Test Temperature, F	Impact Energy, ft-lb	Lateral Expansion, mils	Fracture Appearance, Percent Shear
Y4/B	-200	11.0	9.4	0
Y5/M	-150	14.5	17.0	1
Y6/U	-125	6.8	6.8	5
Y6/5	-125	37.0	31.6	10
Y6/Y	-100	41.0	54.0	20
Y4/5	-50	62.0	54.8	35
Y6/7	0	73.4	68.2	65
Y5/T	50	85.8	79.0	75
Y4/D	60	81.0	72.8	80
Y5/U	60	98.0	83.8	85
Y4/7	60	89.0	77.8	85
Y6/1	80	96.9	86.6	90
Y4/A	150	111.1	93.8	100
Y4/3	230	114.8	85.4	100
Y6/6	300	112.2	75.0	100

TABLE 4. CHARPY V-NOTCH IMPACT RESULTS FOR PILGRIM HAZ METAL

Specimen Identification	Test Temperature, F	Impact Energy, ft-lb	Lateral Expansion, mils	Fracture Appearance, Percent Shear
YA/J	-200	4.5	3.8	0
Y7/P	-165	21.5	16.0	5
Y7/A	-135	13.0	10.8	1
YB/1	-100	13.0	12.4	5
Y7/U	-50	37.5	30.0	15
YA/3	-40	68.6	53.4	35
YA/P	-35	74.5	58.4	45
YA/T	0	68.0	60.4	75
Y7/2	35	97.5	84.0	85
YB/2	50	135.7	79.4	100
YB/6	81	107.9	77.2	90
Y7/7	150	99.9	84.8	100
YB/E	300	112.0	87.8	100

TABLE 6. TENSILE TEST RESULTS FOR PILGRIM UNIRRADIATED BASELINE SPECIMENS

Material	Specimen Number	Test Temp, F	0.2 Percent Offset Yield Strength, ksi	Ultimate Tensile Strength, ksi	Fracture		Reduction in Area, percent	Elongation, %		
					Load, lb	Strength, ksi		Stress, ksi	Uni-form	Total
Base	YC-5	72	64.5	86.4	2800	55.7	185	69.90	12.4	25.5
Base	YC-6	550	57.7	82.8	2925	58.2	166	65.00	10.6	21.4
Weld	YD-T	72	68.8	78.4	2450	49.6	178	72.02	14.5	28.6
Weld	YD-K	550	54.6	78.3	2725	54.7	148	63.04	12.0	23.0
HAZ	YE-D	72	61.7	79.6	2475	49.7	178	72.17	8.5	22.9
HAZ	YE-E	550	57.2	78.1	2410	48.4	136	64.48	7.9	18.9

APPENDIX C

PHOTOGRAPHS OF IMPACT AND TENSILE CAPSULES




WESTCOTT  RULER




WESTCOTT  RULER

176015




WESTCOTT RULER

1704073
Q3





G-4



APPENDIX D

PHOTOGRAPHS OF TESTED SPECIMENS
AND TENSILE TEST RECORDS





YEK
+550°F



YEL
RT



YEB
RT



YD5
+550°F



YD7
+150°F



YC1
+550°F



YCA
+150°F



YCM
RT

Southwest Research Institut
Department of Materials Sciences

TENSILE TEST DATA SHEET

Test No. T- _____ Est. U. T. S. _____ psi Project No. 02-5651-00
Spec. No. VE-L Initial G. L. 1.013 in. Machine No. 22K12
Temperature 72 °F Initial Dia. .250 in. Date 28 Aug 1980
Strain Rate .005 in/in/min Initial Thickness _____ in. Initial Area .049 in²
Initial Width _____ in.

Top Temperature _____ °F Maximum Load 4320 lb
Bottom Temperature _____ °F 0.2% Offset Load 3440 lb
Final Gage Length 1.254 in. 0.02% Offset Load _____ lb
Final Diameter .138 in. Upper Yield Point _____ lb
Final Area .0149 ~~.0150~~ in.²

$$\text{U. T. S.} = \frac{\text{Maximum Load}}{\text{Initial Area}} = \frac{88.0}{88.2} \text{ psi Ksi}$$

$$0.2\% \text{ Y. S.} = \frac{0.2\% \text{ Offset Load}}{\text{Initial Area}} = \frac{70.1}{70.2} \text{ psi Ksi}$$

$$0.02\% \text{ Y. S.} = \frac{0.02\% \text{ Offset Load}}{\text{Initial Area}} = \text{_____} \text{ psi}$$

$$\text{Upper Y. S.} = \frac{\text{Upper Yield Point}}{\text{Initial Area}} = \text{_____} \text{ psi}$$

$$\% \text{ Elongation} = \frac{\text{Final G. L.} - \text{Initial G. L.}}{\text{Initial G. L.}} \times 100 = \underline{23.8} \%$$

$$\% \text{ R. A.} = \frac{\text{Initial Area} - \text{Final Area}}{\text{Initial Area}} \times 100 = \underline{69.5} \%$$

Signature: *[Signature]*

Spec # YE-1

DL 5957-001

28 Aug 1972

172°F


$k = .005 \text{ in}^2/\text{in}^2$

Load/Displacement Record

Pin 1 (24316)
Pin 2 (24316)
Pin 3 (24316)

20%

Area = .57 in



SP-4 YE-L

CD - 58511-001 NA

CD - 58511-001

72 F

V = 1003 1/2 / in

Lead/Strain Record

NOV 1964

DEC 1964

JAN 1965

FEB 1965

MAR 1965

APR 1965

MAY 1965

JUN 1965

JUL 1965

AUG 1965

SEP 1965

OCT 1965

NOV 1965

DEC 1965

JAN 1966

FEB 1966

MAR 1966

APR 1966

MAY 1966

JUN 1966

JUL 1966

AUG 1966

SEP 1966

OCT 1966

NOV 1966

DEC 1966

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

1003 1/2

Southwest Research Institute
Department of Materials Sciences
TENSILE TEST DATA SHEET

Test No. T- _____ Est. U. T. S. _____ psi Project No. 02-5451-001
 Spec. No. 1/E-B Initial G. L. 1.013 in. Machine No. 221K1P
 Temperature 72 °F Initial Dia. .250 in. Date 28 Aug 1980
 Strain Rate .005 in/in/min Initial Thickness _____ in. Initial Area .0491 in²
 Initial Width _____ in.

Top Temperature _____ °F Maximum Load 4408 lb
 Bottom Temperature _____ °F 0.2% Offset Load 3520 lb
 Final Gage Length 1.231 in. 0.02% Offset Load _____ lb
 Final Diameter .138 in. Upper Yield Point _____ lb
 Final Area ~~.049~~ .0150 in.²

U. T. S. = $\frac{\text{Maximum Load}}{\text{Initial Area}} = \frac{89.8}{89.9} \text{ psi Ksi}$
 0.2% Y. S. = $\frac{0.2\% \text{ Offset Load}}{\text{Initial Area}} = \frac{71.7}{71.8} \text{ psi Ksi}$
 0.02% Y. S. = $\frac{0.02\% \text{ Offset Load}}{\text{Initial Area}} = \text{_____ psi}$
 Upper Y. S. = $\frac{\text{Upper Yield Point}}{\text{Initial Area}} = \text{_____ psi}$
 % Elongation = $\frac{\text{Final G. L.} - \text{Initial G. L.}}{\text{Initial G. L.}} \times 100 = \frac{21.5}{21.5} \%$
 % R. A. = $\frac{\text{Initial Area} - \text{Final Area}}{\text{Initial Area}} \times 100 = \frac{69.5}{69.5} \%$

Signature: [Signature]

SAC # YE-B


04-25-1964
24 A-3-1111

72°F

R = 1005 Volts

10000 / 10000000000

10000
10000000000



10000

Six # VE-B
 DE-545-001
 ST King 1288

72°F
 2 spots of 1/4 phen
 load/strain Record

Area : 1340m²
 PWS : 254 (GFS) 14
 PWS : 11.1 (GFS) 15

Total Area = 1340 m²
 PWS = 3520 m²
 PWS = 11.1 m² = 81.91
 PWS = 11.1 m² = 81.91
 PWS = 11.1 m² = 81.91

we say

Area 1/4 m

Southwest Research Institute
Department of Materials Sciences

TENSILE TEST DATA SHEET

Test No. T- _____ Est. U. T. S. _____ psi Project No. 02-5951-001
Spec. No. YC-M Initial G. L. 1.013 in. Machine No. 22K1P
Temperature 72 °F Initial Dia. .250 in. Date 28 Aug 1980
Strain Rate .005 ⁱⁿ/_{in} / min Initial Thickness _____ in. Initial Area .0491 in²
Initial Width _____ in.

Top Temperature _____ °F Maximum Load 4568 lb
Bottom Temperature _____ °F 0.2% Offset Load 3496 lb
Final Gage Length 1.270 in. 0.02% Offset Load _____ lb
Final Diameter .135 in. Upper Yield Point _____ lb
Final Area .0143 in.²

U. T. S. = $\frac{\text{Maximum Load}}{\text{Initial Area}}$ = $\frac{93.0}{93.2}$ psi Ksi
0.2% Y. S. = $\frac{0.2\% \text{ Offset Load}}{\text{Initial Area}}$ = $\frac{71.2}{71.4}$ psi Ksi
0.02% Y. S. = $\frac{0.02\% \text{ Offset Load}}{\text{Initial Area}}$ = _____ psi
Upper Y. S. = $\frac{\text{Upper Yield Point}}{\text{Initial Area}}$ = _____ psi
% Elongation = $\frac{\text{Final G. L.} - \text{Initial G. L.}}{\text{Initial G. L.}} \times 100$ = 25.4 %
% R. A. = $\frac{\text{Initial Area} - \text{Final Area}}{\text{Initial Area}} \times 100$ = $\frac{70.9}{70.8}$ %

Signature: Sie O...


Sheet 4-M
 1000 ft. 1000 ft. 1000 ft.
 2000 ft. 1000 ft.
 1000 ft. 1000 ft.
 1000 ft. 1000 ft.

Range 1000 ft.
 Value 1000 ft.

1000

1000

1000 ft.



1000

Speed V_{cr} = m


DE 25-151-1001
28 AUG 1970

DR F
V_{cr} = 2005 / 1000
Load / Strain Record

Area = 0.111 m²
Gross = 0.235 m²
Net = 0.124 m²

June 20/70

Peak = 14.5 GPa
V_{cr} = 3160 ft/min
Gross = 48000 ft³ / 13.2 GPa
Net = 28000 ft³ / 13.2 GPa



Southwest Research Institute
Department of Materials Sciences

TENSILE TEST DATA SHEET

Test No. T- _____ Est. U. T. S. _____ psi Project No. 02-S9S1-001
Spec. No. YC-A Initial G. L. 1.013 in. Machine No. 22K1P
Temperature 150 °F Initial Dia. .251 in. Date 28 Aug 1980
Strain Rate .005 ⁱⁿ/_{in}/min Initial Thickness _____ in. Initial Area .04948 in²
Initial Width _____ in.

Top Temperature _____ °F Maximum Load 4424 lbs
Bottom Temperature _____ °F 0.2% Offset Load 3360 lb
Final Gage Length 1.276 in. 0.02% Offset Load _____ lb
Final Diameter .135 in. Upper Yield Point _____ lb
Final Area .01431 in.²

$$\text{U. T. S.} = \frac{\text{Maximum Load}}{\text{Initial Area}} = \underline{89.4} \text{ psi Ksi}$$

$$0.2\% \text{ Y. S.} = \frac{0.2\% \text{ Offset Load}}{\text{Initial Area}} = \underline{67.9} \text{ psi Ksi}$$

$$0.02\% \text{ Y. S.} = \frac{0.02\% \text{ Offset Load}}{\text{Initial Area}} = \underline{\hspace{2cm}} \text{ psi}$$

$$\text{Upper Y. S.} = \frac{\text{Upper Yield Point}}{\text{Initial Area}} = \underline{\hspace{2cm}} \text{ psi}$$

$$\% \text{ Elongation} = \frac{\text{Final G. L.} - \text{Initial G. L.}}{\text{Initial G. L.}} \times 100 = \underline{26.0} \%$$

$$\% \text{ R. A.} = \frac{\text{Initial Area} - \text{Final Area}}{\text{Initial Area}} \times 100 = \underline{71.1} \%$$

Signature: *[Signature]*

Spec # YC-A

02-5751-004

21 MS 1180

150°K

R = 0.05 w/w/min


lead/displacement

Phase: 1. 2. 3. 4. 5. 6. 7. 8. 9. 10. 11. 12. 13. 14. 15. 16. 17. 18. 19. 20. 21. 22. 23. 24. 25. 26. 27. 28. 29. 30. 31. 32. 33. 34. 35. 36. 37. 38. 39. 40. 41. 42. 43. 44. 45. 46. 47. 48. 49. 50. 51. 52. 53. 54. 55. 56. 57. 58. 59. 60. 61. 62. 63. 64. 65. 66. 67. 68. 69. 70. 71. 72. 73. 74. 75. 76. 77. 78. 79. 80. 81. 82. 83. 84. 85. 86. 87. 88. 89. 90. 91. 92. 93. 94. 95. 96. 97. 98. 99. 100.

1

10

100



1/20/74

Spec # Yc-A

QZ - 5421-001

EP - Aug 1978

150' A

K = 0.05 Pa/min

Load/Strain Record

Area = 114.813

Orig. = 87.145

EP = 67.465

max 204

100%

Area = 114.813

100%

EP

Points: 20

Area = 114.813

max = 204.1 - 67.465

EP = 67.465

Southwest Research Institute
Department of Materials Sciences
TENSILE TEST DATA SHEET

Test No. T- 4D-3 ^{well} Est. U. T. S. _____ psi Project No. 02-5951-00
 Spec. No. VD-7 Initial G. L. 1.013 in. Machine No. 22 KIP
 Temperature 150 °F Initial Dia. .250 in. Date 28 Aug 1980
 Strain Rate .005 ^{in/in}/min Initial Thickness _____ in. Initial Area .0491 in.²
 Initial Width _____ in.

Top Temperature _____ °F Maximum Load 4208 lb
 Bottom Temperature _____ °F 0.2% Offset Load 3424 lb
 Final Gage Length 1.274 in. 0.02% Offset Load _____ lb
 Final Diameter .144 in. Upper Yield Point _____ lb
 Final Area .0163 in.²

U. T. S. = $\frac{\text{Maximum Load}}{\text{Initial Area}}$ = $\frac{4208}{85.7}$ ^{85.7} ~~85.9~~ psi Ksi
 0.2% Y. S. = $\frac{0.2\% \text{ Offset Load}}{\text{Initial Area}}$ = $\frac{3424}{69.7}$ ^{69.7} ~~69.9~~ psi Ksi
 0.02% Y. S. = $\frac{0.02\% \text{ Offset Load}}{\text{Initial Area}}$ = _____ psi
 Upper Y. S. = $\frac{\text{Upper Yield Point}}{\text{Initial Area}}$ = _____ psi
 % Elongation = $\frac{\text{Final G. L.} - \text{Initial G. L.}}{\text{Initial G. L.}} \times 100$ = $\frac{1.274 - 1.013}{1.013} \times 100$ = 25.8 %
 % R. A. = $\frac{\text{Initial Area} - \text{Final Area}}{\text{Initial Area}} \times 100$ = $\frac{.0491 - .0163}{.0491} \times 100$ = $\frac{66.8}{66.7}$ ^{66.8} %

Signature: Vic Owen
 witnessed by Tan 28 Aug 80

Spec # YD-7

RF Aug 1950

DR 5831-081

X = 1005 $\frac{1}{100}$ in

150°F

Load/Displacement


see notes on page 10

Time = 41.00 min

Failure = 26.78 lb

Y-axis 20%

X-axis @ 0.5 in



Spec # Yp-7

4-8 Aug 1988
102-0165-000

X 1005 10/1/88

1500 ft

Lead/Stream

10/1/88

100
100
33

102-0165-000

Area: 1000 ft

1000 ft

1000 ft

1000 ft

1000 ft

1000 ft

1000 ft

1000 ft

1000 ft

1000 ft

Southwest Research Institute
Department of Materials Sciences

TENSILE TEST DATA SHEET

Test No. T-YE-K Est. U. T. S. _____ psi Project No. 02-5951-001
Spec. No. _____ Initial G. L. 1.0130 in. Machine No. 22K12
Temperature 550 °F Initial Dia. .250 in. Date 27 Aug 1980
Strain Rate .005 ⁱⁿ/_{in} min Initial Thickness _____ in. Initial Area .0491 in²
Initial Width _____ in.

Top Temperature _____ °F Maximum Load 3904 lb
Bottom Temperature _____ °F 0.2% Offset Load 2744 lb
Final Gage Length 1.220 in. 0.02% Offset Load _____ lb
Final Diameter .146 in. Upper Yield Point _____ lb
Final Area .0167 in.²


U. T. S. = $\frac{\text{Maximum Load}}{\text{Initial Area}} = \frac{79.5}{79.7} \text{ @ } \text{psi Ksi}$
0.2% Y. S. = $\frac{0.2\% \text{ Offset Load}}{\text{Initial Area}} = \frac{55.9}{56.0} \text{ @ } \text{psi Ksi}$
0.02% Y. S. = $\frac{0.02\% \text{ Offset Load}}{\text{Initial Area}} = \text{_____ psi}$
Upper Y. S. = $\frac{\text{Upper Yield Point}}{\text{Initial Area}} = \text{_____ psi}$
% Elongation = $\frac{\text{Final G. L.} - \text{Initial G. L.}}{\text{Initial G. L.}} \times 100 = \frac{20.4}{\text{_____}} \%$
% R. A. = $\frac{\text{Initial Area} - \text{Final Area}}{\text{Initial Area}} \times 100 = \frac{66.0}{65.9} \%$

Signature: [Signature]

witnessed by TAM 27 Aug 80

Spec # Y/E-K
 27 Aug 1981 UK
 02-5857-001
 $\dot{\gamma} = 1000 \text{ 1/min}$
 Load/Displacement
 550°

Modulus 3.8 x 10¹¹ dyn/cm²
 Poisson's Ratio 0.25
 P. 478



Rate 2.0%

Sec # 1E-K

27 Aug 1980

CR-5057-004

low strain

550°K

Area = 0.015


Height = 1.15

D.P.S. = 16.0

1000

47 1023

K.M. KEVTEL & BERRY CO. NEW YORK



X max @ 1.15 .175/1.14

Southwest Research Institute
Department of Materials Sciences

TENSILE TEST DATA SHEET

Test No. T- _____ Est. U. T. S. _____ psi Project No. 02-5951-001
Spec. No. YC-1 Initial G. L. 1.013 in. Machine No. 22K17
Temperature 550 °F Initial Dia. .250 in. Date 27 Aug 1980
Strain Rate .005ⁱⁿ/min. Initial Thickness _____ in. Initial Area .0491ⁱⁿ²
Initial Width _____ in.

Top Temperature _____ °F Maximum Load 4184 lb
Bottom Temperature _____ °F 0.2% Offset Load 3020 lb
Final Gage Length 1.239 in. 0.02% Offset Load _____ lb
Final Diameter .140 in. Upper Yield Point _____ lb
Final Area .0154 in.²

$$\text{U. T. S.} = \frac{\text{Maximum Load}}{\text{Initial Area}} = \frac{85.20}{85.4} \text{ psi Ksi}$$

$$0.2\% \text{ Y. S.} = \frac{0.2\% \text{ Offset Load}}{\text{Initial Area}} = \frac{61.50}{61.6} \text{ psi Ksi}$$

$$0.02\% \text{ Y. S.} = \frac{0.02\% \text{ Offset Load}}{\text{Initial Area}} = \text{_____} \text{ psi}$$

$$\text{Upper Y. S.} = \frac{\text{Upper Yield Point}}{\text{Initial Area}} = \text{_____} \text{ psi}$$

$$\% \text{ Elongation} = \frac{\text{Final G. L.} - \text{Initial G. L.}}{\text{Initial G. L.}} \times 100 = \frac{22.3}{1.013} \%$$

$$\% \text{ R. A.} = \frac{\text{Initial Area} - \text{Final Area}}{\text{Initial Area}} \times 100 = \frac{68.6}{100} \%$$

Signature: Die Aron

Spec # YC-1 JR

FM Aug 1918

02-3451-000

Long/Displacement - R

3200' F


$\lambda = 10005 \text{ m/m} / \text{min}$

1000'

Point - 1000' F
Position - 1000' F

100'


X @ 5%_m



Spec # Y-1
 20 2 1/2 MPa
 CR = 5451-001
 Load/Strain Recorder
 5500 F
 $E = 1005 \text{ MPa/m}$

Area = 16.17 in²
 Yield = 835.4 Ks
 Yield = 61.5 MPa

Phase 1120N 1A
 P.P. 1200N
 Phase 1120N 1A
 P.P. 1200N
 Phase 1120N 1A
 P.P. 1200N



Southwest Research Institute
Department of Materials Sciences

TENSILE TEST DATA SHEET

Test No. T- _____ Est. U. T. S. _____ psi Project No. 02-5951-001
Spec. No. YD-5 Initial G. L. 1.013 in. Machine No. 22 K12
Temperature 550 °F Initial Dia. .250 in. Date 28 Aug 1980
Strain Rate .005 in./min Initial Thickness _____ in. Initial Area .0491 in²
Initial Width _____ in.

Top Temperature _____ °F Maximum Load 3984 lb
Bottom Temperature _____ °F 0.2% Offset Load 2960 lb
Final Gage Length 1.246 in. 0.02% Offset Load _____ lb
Final Diameter .148 in. Upper Yield Point _____ lb
Final Area .0172 in.²

$$\text{U. T. S.} = \frac{\text{Maximum Load}}{\text{Initial Area}} = \frac{81.8 \text{ Ksi}}{81.6} \text{ psi Ksi}$$

$$0.2\% \text{ Y. S.} = \frac{0.2\% \text{ Offset Load}}{\text{Initial Area}} = \frac{60.3 \text{ Ksi}}{60.4} \text{ psi Ksi}$$

$$0.02\% \text{ Y. S.} = \frac{0.02\% \text{ Offset Load}}{\text{Initial Area}} = \text{_____} \text{ psi}$$

$$\text{Upper Y. S.} = \frac{\text{Upper Yield Point}}{\text{Initial Area}} = \text{_____} \text{ psi}$$

$$\% \text{ Elongation} = \frac{\text{Final G. L.} - \text{Initial G. L.}}{\text{Initial G. L.}} \times 100 = \frac{23.0}{100} \%$$

$$\% \text{ R. A.} = \frac{\text{Initial Area} - \text{Final Area}}{\text{Initial Area}} \times 100 = \frac{65.0}{100} \%$$

Signature: Dick

witnessed by TAM 28 Aug 80

SEC # YD-5

CR: 5457.001

28 AUG 1976


LOAD/Displacement Record

5500 F

$X = .005 \text{ in/in}$


calculated by 2011.000000

2011.000000
2011.000000
2011.000000



Sheet 10-5

28 Aug 1960
1007/51100-1
55000
2 x 1000 1/2 x 1/2



X-axis = 0.1/1.0

10